

KIRKJA, Faroe Islands

WMO: 060120

Lat: 62.319N

Lon: 6.321W

Elev: 56

StdP: 100.65

Time Zone: 0.00 (EUW)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.5	-1.8	N/A	N/A	N/A	N/A	N/A	N/A	17.7	5.3	15.0	5.2	4.5	340	0.753

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	15.2	N/A	14.3	N/A	13.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.2	11.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	4.6	4.7	4.8	5.7	6.9	9.3	9.8	11.4	10.9	8.2	6.5	5.2
	DBStd	3.49	2.43	2.81	2.54	2.42	2.28	1.78	4.07	1.30	1.67	2.50	2.84	2.73
	HDD10.0	1111	167	149	161	131	99	33	38	2	9	64	108	149
	HDD18.3	4012	425	382	419	380	355	272	266	214	222	314	356	407
	CDD10.0	142	0	0	0	1	3	12	31	47	37	8	2	1
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.9	5.9	5.5	5.4	4.8	4.5	3.9	3.9	3.9	3.7	4.4	6.3	6.8
Precipitation	PrecAvg	2253	271	205	217	167	124	96	96	133	198	243	260	243
	PrecMax	2653	457	376	329	253	336	183	173	251	354	417	364	394
	PrecMin	1810	164	91	113	83	39	36	22	66	75	126	153	106
	PrecStd	209	64	66	59	47	59	41	31	49	71	68	60	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	11.2	11.3	15.0	15.2	16.0	16.8	17.0	15.5	14.0	13.6	12.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.8	10.3	9.6	10.7	12.6	13.7	14.5	14.9	14.7	12.9	12.3	11.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	8.8	9.4	8.6	9.5	10.8	12.5	13.6	13.8	14.1	12.0	11.0	9.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	7.8	8.3	7.9	8.7	9.7	11.6	13.0	13.1	13.4	11.2	10.0	8.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.0	3.1	3.2	3.2	2.9	2.7	2.8	2.9	3.0	3.3	3.4
		MCDBR	4.6	4.2	4.1	3.9	4.6	4.2	3.7	3.8	4.0	3.6	5.4	5.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.302	0.343	0.354	0.376	0.369	0.361	0.364	0.358	0.358	0.337	0.295	0.378	
	taud	2.058	2.196	2.307	2.298	2.390	2.461	2.476	2.494	2.419	2.296	2.083	2.373	
	Ebn at Noon	330	587	746	806	849	864	850	825	742	593	330	184	
	Edh at Noon	38	67	86	105	104	99	95	86	77	59	35	23	
All-Sky Solar Radiation	RadAvg	0.16	0.58	1.60	3.04	4.32	4.66	4.22	3.37	2.03	0.87	0.23	0.09	
	RadStd	0.01	0.07	0.15	0.24	0.32	0.45	0.27	0.33	0.14	0.07	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.51	+1.14	N/A	N/A	N/A	N/A	N/A	N/A	+30	N/A

Nomenclature: See separate page