

STENHOEJ, Denmark

WMO: 060320

Lat: 57.383N

Lon: 10.335E

Elev: 180

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.8	20.3	12.2	10.3	19.7	15.5	12.2	22.7	31.7	40.9	29.2	39.3	7.1	70	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	76.9	65.0	73.6	63.6	70.5	62.1	66.5	73.2	64.9	70.9	63.4	68.9	9.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.1	69.0	62.6	85.5	67.7	61.1	80.8	65.9	31.2	73.5	30.0	70.7	28.9	69.1	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.1	24.9	22.1	DB	13.4	81.1	6.0	2.9	9.1	83.1	5.7	84.8	2.3	86.4	-2.0	88.5	(4)
(5)			WB	12.0	69.4	5.0	1.7	8.4	70.5	5.4	71.5	2.6	72.4	-1.0	73.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	33.0	32.9	36.8	44.7	51.3	56.7	61.9	60.6	55.7	48.1	41.3	36.5		
	DBStd	11.56	6.52	6.48	6.46	5.54	5.87	4.65	4.63	3.67	4.11	4.80	5.52	6.77		
	HDD50	2428	528	478	409	177	52	3	0	0	5	93	264	419		
	HDD65	6719	993	898	873	610	425	253	125	144	280	523	711	884		
	CDD50	1224	0	0	1	17	93	204	367	329	175	35	3	0		
	CDD65	42	0	0	0	0	1	4	27	9	1	0	0	0		
	CDH74	247	0	0	0	0	5	33	187	20	2	0	0	0		
	CDH80	22	0	0	0	0	0	1	20	1	0	0	0	0		
	WSAvg	10.7	12.3	11.9	11.7	10.7	9.7	9.3	8.6	9.3	10.1	11.0	11.2	12.3		
	PrecAvg	30.4	2.6	1.9	1.8	1.7	1.9	2.8	2.7	3.2	3.1	3.3	2.7	2.5		
	PrecMax	38.4	4.4	3.7	3.7	3.9	3.4	5.9	6.6	5.6	9.3	6.4	4.8	4.6		
(15) Precipitation	PrecMin	21.3	0.5	0.5	0.3	0.4	0.4	0.0	0.5	0.3	1.6	0.6	1.0	0.6		
	PrecStd	5.0	1.1	0.9	0.8	1.0	0.9	1.4	1.6	1.4	1.7	1.5	1.0	1.1		
	DB	47.4	47.5	54.6	65.3	74.0	77.9	82.7	76.5	70.6	61.2	55.4	51.2	49.9		
	MCWB	45.9	44.2	47.4	53.7	61.2	63.9	65.7	65.2	62.4	57.7	53.6	49.8	49.8		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	45.4	44.8	50.2	61.1	69.5	73.4	79.0	73.1	67.0	58.8	52.6	48.7	48.7		
	2% MCWB	44.1	43.0	45.2	51.8	59.2	61.6	65.2	63.6	60.8	56.2	51.2	47.5	47.5		
	5% DB	43.8	43.2	46.8	57.2	65.6	69.5	75.6	70.5	64.3	56.9	50.9	47.0	47.0		
	5% MCWB	42.5	41.7	43.4	50.2	57.2	60.9	65.0	62.3	59.3	54.8	49.5	45.8	45.8		
	10% DB	42.2	41.5	44.6	53.4	61.9	66.0	72.1	68.0	62.4	55.2	49.1	45.3	45.3		
	10% MCWB	40.8	40.2	41.9	47.9	55.3	58.9	63.5	61.0	58.0	53.3	47.8	44.1	44.1		
	0.4% WB	46.3	45.5	48.9	56.3	63.7	66.0	69.5	67.6	64.3	58.9	53.9	49.9	49.9		
	0.4% MCDB	46.9	46.4	52.5	62.0	70.5	72.8	77.3	73.1	67.9	60.3	55.1	50.8	50.8		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	44.5	43.4	45.9	52.9	61.0	63.9	67.5	65.6	61.9	56.8	51.5	47.8	47.8		
	2% MCDB	45.2	44.5	48.9	58.9	67.0	71.1	74.9	70.4	65.7	57.9	52.4	48.5	48.5		
	5% WB	42.8	41.9	43.9	50.6	58.4	61.9	65.7	63.8	60.4	55.1	49.8	46.0	46.0		
	5% MCDB	43.5	42.9	46.1	55.6	64.1	68.5	72.6	68.0	63.4	56.4	50.7	46.8	46.8		
	10% WB	41.0	40.3	42.4	48.3	55.9	59.7	64.3	62.3	58.9	53.6	48.0	44.4	44.4		
	10% MCDB	42.0	41.4	44.3	53.0	60.7	64.6	70.5	66.4	61.3	55.0	48.9	45.2	45.2		
	MDBR	6.6	6.5	8.8	12.2	13.8	13.8	14.9	13.2	10.9	8.9	6.9	6.5	6.5		
	5% DB	7.8	8.0	11.6	17.4	18.8	19.3	20.3	16.7	13.4	9.9	7.5	7.3	7.3		
(36) Mean Daily Temperature Range	MCDBR	7.9	7.1	7.9	10.3	11.0	10.8	9.5	8.6	8.3	7.8	7.1	7.4	7.4		
	5% WB	7.7	7.7	10.7	15.8	17.3	17.2	17.8	14.1	11.5	8.9	7.1	7.3	7.3		
	MCWBR	8.0	7.1	7.8	10.1	11.2	10.8	9.7	8.7	7.9	7.6	7.0	7.5	7.5		
	MCWBR	8.0	7.1	7.8	10.1	11.2	10.8	9.7	8.7	7.9	7.6	7.0	7.5	7.5		
(40) Clear-Sky Solar Irradiance	taub	0.304	0.330	0.346	0.383	0.376	0.366	0.386	0.387	0.360	0.344	0.320	0.288	0.288		
	taud	2.243	2.309	2.347	2.300	2.384	2.435	2.398	2.400	2.465	2.421	2.298	2.203	2.203		
	Ebn at Noon	175	225	255	262	273	277	268	259	250	219	168	144	144		
	Edh at Noon	16	23	29	35	35	33	34	32	26	21	15	12	12		
(44) All-Sky Solar Radiation	RadAvg	117	293	754	1286	1717	1901	1747	1363	921	429	156	81	81		
	RadStd	24	53	70	146	141	138	161	90	89	56	27	9	9		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (51 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-212	-284	N/A	N/A

Nomenclature: See separate page