

STENHOEJ, Denmark

WMO: 060320

Lat: 57.383N

Lon: 10.335E

Elev: 55

StdP: 100.67

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.4	-6.5	-11.0	1.5	-6.8	-9.1	1.7	-5.2	14.2	4.9	13.1	4.1	3.2	70	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	24.9	18.3	23.1	17.6	21.4	16.7	19.2	22.9	18.3	21.6	17.4	20.5	4.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.9	20.6	17.0	12.2	19.8	16.1	11.5	18.8	54.7	23.1	51.9	21.5	49.3	20.6	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.1	9.9	DB	-10.3	27.3	3.3	1.6	-12.7	28.4	-14.6	29.3	-16.5	30.2	-18.9	31.4	(4)
(5)			WB	-11.1	20.8	2.8	0.9	-13.1	21.4	-14.8	22.0	-16.3	22.5	-18.3	23.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	0.5	0.5	2.7	7.0	10.7	13.7	16.6	15.9	13.2	9.0	5.2	2.5		
	DBStd	6.42	3.62	3.60	3.59	3.08	3.26	2.58	2.57	2.04	2.28	2.67	3.07	3.76		
	HDD10.0	1349	293	266	227	98	29	2	0	0	3	52	147	233		
	HDD18.3	3733	552	499	485	339	236	141	69	80	156	291	395	491		
	CDD10.0	680	0	0	1	9	52	113	204	183	97	19	2	0		
	CDD18.3	23	0	0	0	0	1	2	15	5	1	0	0	0		
	CDH23.3	137	0	0	0	0	3	18	104	11	1	0	0	0		
	CDH26.7	12	0	0	0	0	0	1	11	1	0	0	0	0		
	WSAvg	4.8	5.5	5.3	5.3	4.8	4.3	4.2	3.9	4.2	4.5	4.9	5.0	5.5		
(15) Precipitation	PrecAvg	773	67	49	45	42	48	72	69	81	78	85	68	64		
	PrecMax	975	113	95	94	98	86	150	167	143	236	162	123	117		
	PrecMin	542	12	12	7	9	10	0	12	8	40	14	25	16		
	PrecStd	126	29	24	20	26	22	35	41	36	44	39	25	29		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	8.6	12.6	18.5	23.3	25.5	28.1	24.7	21.4	16.2	13.0	10.7		
		MCWB	7.7	6.8	8.5	12.1	16.2	17.7	18.7	18.4	16.9	14.3	12.0	9.9		
	2%	DB	7.4	7.1	10.1	16.2	20.8	23.0	26.1	22.8	19.5	14.9	11.4	9.3		
		MCWB	6.7	6.1	7.4	11.0	15.1	16.4	18.4	17.6	16.0	13.4	10.6	8.6		
	5%	DB	6.5	6.2	8.2	14.0	18.7	20.8	24.2	21.4	18.0	13.8	10.5	8.3		
		MCWB	5.8	5.4	6.3	10.1	14.0	16.1	18.4	16.8	15.2	12.6	9.7	7.7		
	10%	DB	5.6	5.3	7.0	11.9	16.6	18.9	22.3	20.0	16.9	12.9	9.5	7.4		
		MCWB	4.9	4.5	5.5	8.8	12.9	14.9	17.5	16.1	14.4	11.8	8.8	6.7		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	7.5	9.4	13.5	17.6	18.9	20.9	19.8	17.9	14.9	12.2	9.9		
		MCDB	8.3	8.0	11.4	16.7	21.4	22.6	25.2	22.8	20.0	15.7	12.8	10.4		
	2%	WB	6.9	6.3	7.7	11.6	16.1	17.7	19.7	18.6	16.6	13.8	10.8	8.8		
		MCDB	7.4	7.0	9.4	15.0	19.5	21.7	23.8	21.3	18.7	14.4	11.3	9.2		
	5%	WB	6.0	5.5	6.6	10.3	14.7	16.6	18.7	17.7	15.8	12.8	9.9	7.8		
		MCDB	6.4	6.1	7.8	13.1	17.9	20.3	22.6	20.0	17.4	13.6	10.4	8.2		
	10%	WB	5.0	4.6	5.8	9.1	13.3	15.4	17.9	16.8	15.0	12.0	8.9	6.9		
		MCDB	5.5	5.2	6.8	11.7	15.9	18.1	21.4	19.1	16.3	12.8	9.4	7.3		
(36) Mean Daily Temperature Range	MDBR		3.7	3.6	4.9	6.8	7.7	7.7	8.3	7.4	6.1	4.9	3.8	3.6		
	5% DB	MCDBR	4.3	4.4	6.4	9.7	10.4	10.7	11.3	9.3	7.4	5.5	4.2	4.1		
		MCWBR	4.4	4.0	4.4	5.7	6.1	6.0	5.3	4.8	4.6	4.3	3.9	4.1		
	5% WB	MCDBR	4.3	4.3	5.9	8.8	9.6	9.5	9.9	7.8	6.4	5.0	3.9	4.1		
		MCWBR	4.4	4.0	4.3	5.6	6.2	6.0	5.4	4.9	4.4	4.2	3.9	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.304	0.330	0.346	0.383	0.376	0.366	0.386	0.387	0.360	0.344	0.320	0.288		
	taud		2.243	2.309	2.347	2.300	2.384	2.435	2.398	2.400	2.465	2.421	2.298	2.203		
	Ebn at Noon		553	710	805	827	860	874	845	817	788	690	529	455		
	Edh at Noon		51	73	91	111	109	105	107	100	81	65	48	39		
(44) All-Sky Solar Radiation	RadAvg		0.37	0.93	2.38	4.05	5.41	5.99	5.51	4.30	2.90	1.35	0.49	0.26		
	RadStd		0.08	0.17	0.22	0.46	0.45	0.44	0.51	0.28	0.28	0.18	0.09	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (51 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	-118	-158	N/A	N/A

Nomenclature: See separate page