

SKAGEN FYR, Denmark

WMO: 060410

Lat: 57.7366N

Lon: 10.6318E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.1	23.9	14.5	11.5	24.6	17.5	13.3	26.2	42.5	34.9	39.9	33.5	15.4	60	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	73.3	66.9	70.9	65.6	68.7	64.1	68.0	71.6	66.3	69.9	64.8	68.0	10.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	97.7	70.2	64.8	92.0	68.7	63.3	87.0	67.1	32.3	71.8	31.0	70.1	29.8	68.0	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.1	33.1	30.1	DB	17.5	77.0	4.8	3.5	14.0	79.6	11.2	81.6	8.5	83.6	5.0	86.2	(4)
(5)			WB	16.3	70.0	4.4	3.2	13.1	72.3	10.5	74.2	8.0	76.0	4.8	78.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	35.4	34.4	37.4	44.2	51.4	57.5	62.3	62.3	57.2	50.0	43.2	38.2	(6)	
	DBStd	11.04	5.75	5.80	5.07	4.34	4.79	3.95	3.94	3.75	3.75	4.38	5.07	6.13	(7)	
	HDD50	2131	453	436	392	181	39	0	0	0	2	55	206	367	(8)	
	HDD65	6301	918	856	857	624	423	230	104	104	234	466	653	832	(9)	
	CDD50	1351	0	0	0	7	82	224	382	380	218	54	4	0	(10)	
	CDD65	46	0	0	0	0	1	3	22	19	1	0	0	0	(11)	
	CDH74	49	0	0	0	0	1	6	27	15	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	15.8	18.8	17.5	16.1	13.7	13.4	13.6	12.7	13.5	15.7	17.6	18.7	18.1	(14)	
(15) Precipitation	PrecAvg	29.3	2.6	1.7	1.6	1.5	2.1	3.1	2.4	3.3	2.8	3.6	2.3	2.4	(15)	
	PrecMax	42.3	4.3	3.5	4.6	3.7	4.2	5.9	5.4	6.2	12.4	9.1	4.4	5.2	(16)	
	PrecMin	21.3	0.7	0.4	0.2	0.6	0.3	0.6	0.2	0.4	0.7	0.5	0.5	0.6	(17)	
	PrecStd	5.1	1.1	0.8	0.9	0.9	0.9	1.3	1.4	1.4	2.1	1.9	1.0	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	46.9	50.4	59.4	68.9	74.2	77.2	76.0	67.9	60.2	54.9	50.7	(19)	
		MCWB	45.5	44.6	45.8	51.3	60.6	63.4	67.8	68.8	63.4	57.5	53.0	48.9	(20)	
	2%	DB	45.6	44.7	47.0	54.7	64.4	69.3	73.8	72.7	65.5	58.3	53.1	48.8	(21)	
		MCWB	43.6	42.8	43.5	50.0	58.5	62.3	67.6	67.1	61.8	55.8	51.2	47.2	(22)	
	5%	DB	44.2	43.2	45.0	52.1	61.1	66.1	71.4	70.5	64.1	57.1	51.6	47.5	(23)	
		MCWB	42.3	41.5	42.1	48.2	55.6	60.5	66.3	65.9	60.5	55.1	49.7	45.9	(24)	
	10%	DB	42.9	41.9	43.5	50.1	58.5	63.7	69.2	68.4	62.7	56.0	50.0	46.1	(25)	
		MCWB	41.2	40.4	41.1	46.7	53.9	58.8	64.6	64.3	59.3	53.9	48.2	44.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	45.4	46.4	53.5	63.6	65.5	71.2	70.2	64.9	58.5	53.7	49.5	(27)	
		MCDB	47.2	46.5	49.5	56.7	66.8	70.5	73.5	73.7	66.6	59.5	54.5	50.3	(28)	
	2%	WB	44.1	43.3	44.2	50.5	58.9	62.9	68.3	68.2	62.9	56.8	51.6	47.7	(29)	
		MCDB	45.1	44.2	46.4	53.3	63.1	67.8	72.1	71.5	64.7	57.6	52.6	48.5	(30)	
	5%	WB	42.8	41.9	42.8	48.7	56.5	61.2	66.7	66.5	61.3	55.6	50.1	46.3	(31)	
		MCDB	43.8	42.9	44.4	51.4	60.0	65.2	70.4	69.8	63.2	56.7	51.4	47.3	(32)	
	10%	WB	41.4	40.7	41.6	47.3	54.6	59.7	65.2	64.9	60.0	54.3	48.4	44.7	(33)	
		MCDB	42.6	41.8	43.0	49.8	57.8	63.2	68.8	68.0	62.0	55.6	49.7	45.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	5.6	6.7	8.2	9.2	9.2	9.5	8.5	7.2	5.9	5.3	5.5	(35)	
		MCDBR	6.1	6.3	8.5	10.7	12.4	12.4	12.5	10.6	8.3	6.2	5.8	5.5	(36)	
	5% WB	MCWBR	6.2	5.7	6.3	6.8	7.6	7.7	7.4	6.8	6.2	5.6	6.2	6.0	(37)	
		MCWBR	5.8	6.3	7.8	9.6	11.1	11.5	11.3	10.0	7.3	5.6	5.5	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.305	0.332	0.348	0.386	0.379	0.367	0.388	0.389	0.360	0.346	0.321	0.288	(40)	
		taud	2.248	2.311	2.354	2.300	2.399	2.457	2.417	2.414	2.480	2.420	2.294	2.202	(41)	
	Ebn at Noon		172	223	254	261	272	277	267	258	249	216	164	140	(42)	
		Edh at Noon	16	23	29	35	34	32	33	31	25	21	15	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		113	292	757	1282	1718	1915	1757	1369	922	422	151	78	(44)	
	RadStd		23	53	71	150	139	130	162	87	89	57	27	8	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	-1.69	-1.78	-1.62	N/A	N/A	N/A	-32
Regional (52 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	-211	-283	N/A	N/A

Nomenclature: See separate page