

SKAGEN FYR, Denmark

WMO: 060410

Lat: 57.7366N

Lon: 10.6318E

Elev: 5

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-4.5	-9.7	1.6	-4.1	-8.1	1.9	-3.2	19.0	1.6	17.8	0.8	6.9	60	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	22.9	19.4	21.6	18.7	20.4	17.8	20.0	22.0	19.1	21.0	18.2	20.0	4.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	21.2	18.2	13.1	20.4	17.4	12.4	19.5	57.2	22.1	54.2	21.2	51.5	20.0	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.6	14.8	13.4	-8.1	25.0	2.7	2.0	-10.0	26.4	-11.5	27.6	-13.1	28.7	-15.0	30.1		
			-8.7	21.1	2.4	1.8	-10.5	22.4	-11.9	23.4	-13.3	24.4	-15.1	25.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	1.9	1.3	3.0	6.8	10.8	14.1	16.9	16.8	14.0	10.0	6.2	3.4
	DBStd	6.13	3.20	3.22	2.81	2.41	2.66	2.19	2.19	2.09	2.08	2.44	2.82	3.41
	HDD10.0	1184	252	242	218	101	22	0	0	0	1	31	114	204
	HDD18.3	3501	510	476	476	347	235	128	58	58	130	259	363	462
	CDD10.0	751	0	0	0	4	46	124	212	211	121	30	2	0
	CDD18.3	26	0	0	0	0	1	2	12	11	1	0	0	0
	CDH23.3	27	0	0	0	0	1	3	15	8	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	7.0	8.4	7.8	7.2	6.1	6.0	6.1	5.7	6.0	7.0	7.9	8.4	8.1
(15) Precipitation	PrecAvg	743	67	42	40	39	53	78	61	83	70	92	58	60
	PrecMax	1074	110	89	118	94	106	150	136	158	316	230	113	132
	PrecMin	542	17	11	6	14	8	14	6	11	19	13	12	14
	PrecStd	130	28	21	23	23	23	33	35	35	54	49	26	29
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	8.3	10.2	15.2	20.5	23.5	25.1	24.4	19.9	15.7	12.7	10.4
		MCWB	7.5	7.0	7.7	10.7	15.9	17.5	19.9	20.5	17.5	14.1	11.7	9.4
	2%	DB	7.5	7.1	8.3	12.6	18.0	20.7	23.2	22.6	18.6	14.6	11.7	9.3
		MCWB	6.4	6.0	6.4	10.0	14.7	16.8	19.8	19.5	16.5	13.2	10.7	8.4
	5%	DB	6.8	6.2	7.2	11.2	16.2	18.9	21.9	21.4	17.8	14.0	10.9	8.6
		MCWB	5.7	5.3	5.6	9.0	13.1	15.8	19.0	18.8	15.8	12.8	9.9	7.7
	10%	DB	6.0	5.5	6.4	10.0	14.7	17.6	20.6	20.2	17.1	13.3	10.0	7.8
		MCWB	5.1	4.7	5.1	8.2	12.2	14.9	18.1	18.0	15.1	12.1	9.0	6.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	7.4	8.0	11.9	17.6	18.6	21.8	21.2	18.3	14.7	12.1	9.7
		MCDB	8.5	8.1	9.7	13.7	19.3	21.4	23.1	23.2	19.2	15.3	12.5	10.2
	2%	WB	6.7	6.3	6.8	10.3	14.9	17.1	20.2	20.1	17.2	13.8	10.9	8.7
		MCDB	7.3	6.8	8.0	11.8	17.3	19.9	22.3	21.9	18.2	14.2	11.5	9.2
	5%	WB	6.0	5.5	6.0	9.3	13.6	16.2	19.3	19.1	16.3	13.1	10.1	7.9
		MCDB	6.6	6.0	6.9	10.8	15.6	18.4	21.4	21.0	17.3	13.7	10.8	8.5
	10%	WB	5.2	4.8	5.3	8.5	12.5	15.4	18.5	18.3	15.5	12.4	9.1	7.0
		MCDB	5.9	5.4	6.1	9.9	14.3	17.3	20.4	20.0	16.6	13.1	9.9	7.7
(35) Mean Daily Temperature Range	5% DB	MDBR	3.1	3.1	3.7	4.6	5.1	5.1	5.3	4.7	4.0	3.3	2.9	3.0
		MCDBR	3.4	3.5	4.7	5.9	6.9	6.9	7.0	5.9	4.6	3.5	3.2	3.0
		MCWBR	3.5	3.2	3.5	3.8	4.2	4.3	4.1	3.8	3.5	3.1	3.4	3.3
	5% WB	MCDBR	3.2	3.5	4.3	5.4	6.2	6.4	6.3	5.6	4.1	3.1	3.0	3.1
		MCWBR	3.4	3.4	3.4	3.6	4.2	4.4	4.2	3.9	3.4	3.0	3.3	3.4
(40) Clear-Sky Solar Irradiance	taub	0.305	0.332	0.348	0.386	0.379	0.367	0.388	0.389	0.360	0.346	0.321	0.288	
	taud	2.248	2.311	2.354	2.300	2.399	2.457	2.417	2.414	2.480	2.420	2.294	2.202	
	Ebn at Noon	543	702	800	822	857	872	842	814	785	682	517	441	
	Edh at Noon	49	72	90	111	107	102	105	98	80	65	47	38	
(44) All-Sky Solar Radiation	RadAvg	0.36	0.92	2.38	4.04	5.42	6.04	5.54	4.32	2.91	1.33	0.48	0.24	
	RadStd	0.07	0.17	0.23	0.47	0.44	0.41	0.51	0.27	0.28	0.18	0.08	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	-0.94	-0.99	-0.90	N/A	N/A	N/A	-18
Regional (52 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	-117	-157	N/A	N/A

Nomenclature: See separate page