

FORNAES FYR, Denmark

WMO: 060710

Lat: 56.443N

Lon: 10.957E

Elev: 8

StdP: 101.23

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.7	-4.7	-9.4	1.7	-5.1	-7.5	2.0	-3.1	18.6	1.7	17.6	1.1	5.4	270	0.763

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	22.9	19.1	21.8	18.2	20.7	17.3	19.9	22.3	18.8	21.1	17.8	20.0	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.7	21.6	17.8	12.8	20.5	16.8	12.0	19.4	57.0	22.4	53.5	21.2	50.2	20.0	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	14.0	12.4	DB	-7.4	24.8	3.5	1.2	-9.9	25.6	-12.0	26.3	-14.0	26.9	-16.5	27.8	(4)
(5)			WB	-7.7	20.8	3.2	1.5	-10.0	21.9	-11.8	22.8	-13.6	23.7	-15.9	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	1.7	1.6	2.8	5.9	10.6	13.9	16.2	16.0	13.1	9.4	5.3	2.8	(6)
(7)		DBStd	6.04	3.54	3.48	2.99	2.56	2.61	2.76	2.46	2.43	2.24	2.41	2.64	2.89	(7)
(8)		HDD10.0	1273	256	235	222	127	23	2	0	0	3	39	143	223	(8)
(9)		HDD18.3	3676	514	468	480	374	239	136	75	81	156	277	392	482	(9)
(10)		CDD10.0	659	0	0	0	2	42	117	192	187	97	21	1	0	(10)
(11)		CDD18.3	21	0	0	0	0	0	2	9	9	0	0	0	0	(11)
(12)		CDH23.3	18	0	0	0	0	0	2	11	6	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.5	7.5	7.5	7.1	6.1	5.5	5.1	5.2	5.7	6.2	7.0	7.2	7.4	(14)
(15)	Precipitation	PrecAvg	651	50	38	37	37	53	66	59	73	63	69	55	52	(15)
(16)		PrecMax	841	92	83	82	92	101	154	116	172	174	111	113	105	(16)
(17)		PrecMin	458	4	13	7	5	19	3	6	13	11	24	9	9	(17)
(18)		PrecStd	87	25	19	21	23	21	32	31	39	39	23	24	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	10.4	11.5	16.0	19.4	23.1	24.7	24.1	19.8	15.1	12.4	10.5	(19)
(20)			MCWB	8.3	9.2	9.3	12.0	15.6	18.4	20.3	19.8	17.5	13.1	11.4	9.7	(20)
(21)		2%	DB	8.2	9.1	9.0	12.6	17.6	21.5	23.2	22.8	18.3	13.9	10.8	9.0	(21)
(22)			MCWB	7.4	8.1	7.4	10.0	14.4	17.3	19.3	19.3	16.0	12.6	9.7	8.2	(22)
(23)		5%	DB	7.3	7.7	7.7	11.0	16.3	20.2	21.9	21.7	17.3	13.3	9.8	7.9	(23)
(24)			MCWB	6.5	6.8	6.4	9.0	13.5	16.3	18.3	18.6	15.2	12.2	8.9	7.0	(24)
(25)		10%	DB	6.2	6.5	6.6	9.7	14.9	18.7	20.8	20.4	16.5	12.7	8.9	6.8	(25)
(26)			MCWB	5.4	5.7	5.4	8.2	12.4	15.5	17.4	17.5	14.6	11.6	8.0	6.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.3	9.5	12.3	15.9	19.4	21.2	21.1	18.0	14.0	11.6	9.9	(27)
(28)			MCDWB	9.2	10.0	11.3	15.0	19.0	22.2	23.8	23.0	19.4	14.4	12.5	10.3	(28)
(29)		2%	WB	7.6	8.3	7.8	10.3	14.9	18.0	20.2	20.0	16.7	13.2	9.9	8.3	(29)
(30)			MCDWB	8.2	9.0	8.7	12.2	17.2	20.5	22.8	22.1	17.8	13.7	10.6	8.9	(30)
(31)		5%	WB	6.6	6.8	6.6	9.2	13.9	16.8	18.9	19.0	15.9	12.5	9.0	7.1	(31)
(32)			MCDWB	7.2	7.5	7.5	10.6	15.9	19.5	21.1	21.3	16.8	13.0	9.7	7.7	(32)
(33)		10%	WB	5.4	5.7	5.6	8.3	12.7	15.8	17.8	17.9	15.1	11.8	8.1	6.1	(33)
(34)			MCDWB	6.0	6.4	6.4	9.6	14.5	18.3	20.1	19.9	16.2	12.4	8.8	6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.0	3.1	3.5	4.4	5.3	6.2	6.5	5.9	4.8	3.8	3.2	3.5	(35)
(36)			MCDBR	3.9	4.3	5.5	6.2	6.6	8.0	7.3	6.5	5.8	4.5	4.2	4.2	(36)
(37)			MCWBR	3.9	4.0	4.5	4.2	4.6	5.1	4.6	4.3	4.0	3.7	4.1	4.2	(37)
(38)		5% WB	MCDWB	4.1	4.3	5.1	5.4	5.7	7.2	6.6	6.0	4.3	3.8	3.8	4.2	(38)
(39)			MCWBR	4.0	4.1	4.5	4.0	4.4	5.2	4.7	4.2	3.6	3.6	3.8	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.313	0.336	0.356	0.392	0.385	0.376	0.398	0.398	0.371	0.352	0.331	0.300	(40)
(41)		taud		2.267	2.313	2.329	2.287	2.373	2.424	2.381	2.385	2.443	2.415	2.314	2.239	(41)
(42)		Ebn at Noon		571	716	801	823	855	867	837	810	782	693	545	482	(42)
(43)		Edh at Noon		53	75	94	114	111	107	109	102	84	68	51	42	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.41	0.98	2.41	4.07	5.36	5.80	5.37	4.23	2.95	1.44	0.54	0.30	(44)
(45)		RadStd		0.08	0.17	0.22	0.47	0.47	0.45	0.55	0.32	0.30	0.18	0.09	0.04	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	-117	-168	N/A	N/A

Nomenclature: See separate page