

ANHOLT, Denmark

WMO: 060790

Lat: 56.7169N

Lon: 11.5097E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.6	25.0	14.8	11.7	25.3	17.6	13.4	25.8	41.3	36.1	38.2	37.0	14.5	90	0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	74.2	65.9	72.0	65.6	70.0	64.6	68.1	72.0	66.7	70.7	65.2	69.2	10.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	97.8	70.7	65.0	92.7	69.4	63.4	87.5	68.0	32.4	72.1	31.3	70.9	30.1	69.3	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
37.9	33.6	30.5	21.2	78.5	4.6	3.0	17.9	80.7	15.2	82.5	12.7	84.2	9.3	86.4		
			18.7	68.6	4.4	2.5	15.5	70.5	13.0	71.9	10.5	73.4	7.3	75.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	35.1	34.5	37.1	44.6	53.0	59.6	64.2	64.5	58.5	51.0	44.0	38.6	
	DBStd	11.67	5.11	4.87	4.51	4.90	4.82	3.98	4.19	3.58	3.61	4.22	4.49	5.60	
	HDD50	2068	461	434	401	176	21	0	0	0	0	40	183	352	
	HDD65	5998	926	854	866	613	373	169	68	53	196	434	629	817	
	CDD50	1633	0	0	0	13	114	288	439	450	256	70	3	0	
	CDD65	90	0	0	0	0	1	7	42	38	2	0	0	0	
	CDH74	83	0	0	0	0	2	3	48	30	0	0	0	0	
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0	
Wind	WSAvg	16.0	18.1	16.9	15.4	13.2	14.0	15.0	13.7	14.9	16.5	17.6	18.5	18.6	
Precipitation	PrecAvg	22.6	1.9	1.2	1.2	1.2	1.6	2.2	2.3	3.0	2.1	2.1	1.9	1.9	
	PrecMax	31.6	3.2	2.7	2.7	3.4	3.9	4.6	6.5	8.1	6.5	3.8	3.8	4.5	
	PrecMin	15.1	0.2	0.4	0.0	0.2	0.2	0.1	0.5	0.7	0.3	0.7	0.1	0.6	
	PrecStd	3.9	0.8	0.6	0.7	0.9	0.9	1.1	1.2	2.0	1.3	0.9	0.9	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	43.8	48.8	62.2	70.1	73.7	79.0	77.5	69.7	60.1	54.5	48.7	
		MCWB	44.3	41.4	44.1	52.4	59.5	62.4	66.6	65.7	62.9	56.9	52.8	46.5	
	2%	DB	44.9	42.4	45.2	56.7	65.3	70.2	74.7	74.0	66.8	58.4	52.5	47.4	
		MCWB	42.6	40.3	42.4	49.7	58.0	62.7	66.8	66.0	61.8	55.8	50.6	45.6	
	5%	DB	43.2	41.3	43.4	53.7	62.2	67.6	72.5	71.7	64.9	57.3	51.2	46.4	
		MCWB	41.2	39.8	41.1	48.7	56.5	61.5	66.3	65.8	60.5	54.9	49.0	44.7	
	10%	DB	41.9	40.3	42.2	51.0	59.6	65.4	70.5	69.7	63.3	56.2	49.7	45.1	
		MCWB	40.1	39.0	40.2	47.3	54.6	60.3	65.3	64.8	59.3	53.8	47.4	43.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	42.1	45.1	54.8	62.3	66.2	70.2	69.3	64.5	58.0	53.2	47.2
			MCDB	46.5	43.0	47.3	59.7	67.8	70.8	73.9	72.8	67.7	59.1	54.2	48.2
2%		WB	43.0	40.9	43.0	51.2	59.3	64.2	68.8	67.8	62.8	56.4	51.2	46.0	
		MCDB	44.5	41.8	44.7	55.0	63.7	68.2	72.6	71.5	65.9	57.8	52.3	47.0	
5%		WB	41.5	40.1	41.6	49.4	57.2	62.6	67.4	66.6	61.3	55.3	49.4	45.0	
		MCDB	43.0	41.0	43.0	52.7	61.3	66.3	71.5	70.3	64.2	56.8	50.8	46.0	
10%		WB	40.3	39.2	40.5	47.6	55.1	61.0	65.7	65.3	59.9	54.3	47.8	43.8	
		MCDB	41.7	40.2	41.9	50.7	58.6	64.7	69.9	69.1	62.8	55.9	49.4	44.9	
Mean Daily Temperature Range	5% DB	MDBR	4.0	3.8	4.6	6.3	6.7	6.6	6.4	6.0	4.8	4.0	3.8	4.0	
		MCDBR	4.0	3.6	5.8	11.5	10.9	9.6	9.4	9.4	6.6	4.5	4.1	3.7	
		MCWBR	4.2	3.2	4.5	6.7	6.8	6.4	5.8	5.4	4.8	4.3	4.5	3.9	
	5% WB	MCDWR	3.9	3.7	5.5	9.2	9.1	8.5	7.8	7.5	5.8	4.0	4.0	3.6	
		MCWBR	4.2	3.5	4.6	5.9	6.6	6.4	5.8	5.5	5.0	4.3	4.5	3.9	
Clear-Sky Solar Irradiance	taub	0.312	0.336	0.355	0.390	0.385	0.375	0.398	0.399	0.369	0.353	0.331	0.299		
	taud	2.268	2.315	2.340	2.298	2.394	2.449	2.400	2.397	2.460	2.412	2.309	2.238		
	Ebn at Noon	179	226	254	261	271	275	265	256	248	218	170	150		
	Edh at Noon	16	23	30	36	34	33	34	32	26	22	16	13		
All-Sky Solar Radiation	RadAvg	125	305	762	1289	1705	1855	1713	1346	932	448	167	90		
	RadStd	26	55	71	148	146	141	172	99	93	57	28	11		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (60 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	-221	-310	N/A	N/A	

Nomenclature: See separate page