

ANHOLT, Denmark

WMO: 060790

Lat: 56.7169N

Lon: 11.5097E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.2	-3.9	-9.5	1.7	-3.7	-8.0	1.9	-3.5	18.4	2.3	17.1	2.8	6.5	90	0.783

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	23.5	18.8	22.2	18.7	21.1	18.1	20.1	22.2	19.3	21.5	18.5	20.7	4.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.0	21.5	18.4	13.2	20.8	17.5	12.5	20.0	57.5	22.3	54.9	21.6	52.2	20.7	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	15.0	13.6	-6.0	25.9	2.5	1.7	-7.8	27.1	-9.3	28.0	-10.7	29.0	-12.6	30.2		
(5)			-7.4	20.4	2.4	1.4	-9.2	21.4	-10.6	22.2	-11.9	23.0	-13.7	24.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.7	1.4	2.8	7.0	11.7	15.3	17.9	18.1	14.7	10.6	6.7	3.7	(6)
(7)		DBStd	6.48	2.84	2.71	2.50	2.72	2.68	2.21	2.33	1.99	2.00	2.34	2.50	3.11	(7)
(8)		HDD10.0	1149	256	241	223	98	12	0	0	0	0	22	102	196	(8)
(9)		HDD18.3	3332	514	474	481	341	207	94	38	29	109	241	349	454	(9)
(10)		CDD10.0	907	0	0	0	7	63	160	244	250	142	39	2	0	(10)
(11)		CDD18.3	50	0	0	0	0	1	4	23	21	1	0	0	0	(11)
(12)		CDH23.3	46	0	0	0	0	1	2	27	17	0	0	0	0	(12)
(13)		CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.2	8.1	7.6	6.9	5.9	6.2	6.7	6.1	6.7	7.4	7.9	8.3	8.3	(14)
(15)	Precipitation	PrecAvg	573	47	30	30	30	40	57	58	77	53	54	49	47	(15)
(16)		PrecMax	802	82	69	68	87	98	116	166	205	164	97	96	114	(16)
(17)		PrecMin	383	6	11	1	5	4	3	13	18	8	17	3	14	(17)
(18)		PrecStd	100	21	15	18	22	23	29	31	51	33	23	22	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	6.5	9.3	16.8	21.2	23.2	26.1	25.3	20.9	15.6	12.5	9.3	(19)
(20)			MCWB	6.8	5.2	6.7	11.3	15.3	16.9	19.2	18.7	17.2	13.8	11.6	8.1	(20)
(21)		2%	DB	7.2	5.8	7.3	13.7	18.5	21.2	23.7	23.3	19.3	14.7	11.4	8.6	(21)
(22)			MCWB	5.9	4.6	5.8	9.9	14.5	17.0	19.3	18.9	16.5	13.2	10.4	7.5	(22)
(23)		5%	DB	6.2	5.2	6.3	12.0	16.8	19.8	22.5	22.0	18.3	14.0	10.7	8.0	(23)
(24)			MCWB	5.1	4.3	5.1	9.3	13.6	16.4	19.1	18.8	15.8	12.7	9.5	7.0	(24)
(25)		10%	DB	5.5	4.6	5.7	10.5	15.3	18.6	21.4	21.0	17.4	13.4	9.9	7.3	(25)
(26)			MCWB	4.5	3.9	4.6	8.5	12.6	15.7	18.5	18.2	15.2	12.1	8.6	6.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	5.6	7.3	12.7	16.8	19.0	21.2	20.7	18.1	14.4	11.8	8.4	(27)
(28)			MCDWB	8.0	6.1	8.5	15.4	19.9	21.5	23.3	22.7	19.8	15.1	12.3	9.0	(28)
(29)		2%	WB	6.1	5.0	6.1	10.7	15.2	17.9	20.4	19.9	17.1	13.6	10.7	7.8	(29)
(30)			MCDWB	6.9	5.4	7.1	12.8	17.6	20.1	22.6	21.9	18.8	14.3	11.3	8.3	(30)
(31)		5%	WB	5.3	4.5	5.3	9.7	14.0	17.0	19.6	19.2	16.3	13.0	9.7	7.2	(31)
(32)			MCDWB	6.1	5.0	6.1	11.5	16.3	19.0	22.0	21.3	17.9	13.8	10.5	7.8	(32)
(33)		10%	WB	4.6	4.0	4.7	8.7	12.8	16.1	18.7	18.5	15.5	12.4	8.8	6.6	(33)
(34)			MCDWB	5.4	4.5	5.5	10.4	14.8	18.2	21.1	20.6	17.1	13.3	9.6	7.2	(34)
(35)	Mean Daily Temperature Range	MDBR	2.2	2.1	2.6	3.5	3.7	3.6	3.6	3.3	2.7	2.2	2.1	2.2	(35)	
(36)		5% DB	MCDBR	2.2	2.0	3.2	6.4	6.1	5.3	5.2	3.6	2.5	2.3	2.0	(36)	
(37)			MCWBR	2.4	1.8	2.5	3.7	3.8	3.6	3.2	3.0	2.7	2.4	2.5	2.2	(37)
(38)			5% WB	MCDWB	2.1	2.0	3.1	5.1	5.1	4.7	4.3	4.2	3.2	2.2	2.2	2.0
(39)		MCWBR		2.4	1.9	2.5	3.3	3.6	3.6	3.2	3.0	2.8	2.4	2.5	2.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.336	0.355	0.390	0.385	0.375	0.398	0.399	0.369	0.353	0.331	0.299	(40)	
(41)		taud	2.268	2.315	2.340	2.298	2.394	2.449	2.400	2.397	2.460	2.412	2.309	2.238	(41)	
(42)		Ebn at Noon	565	712	800	823	854	868	836	808	782	688	536	472	(42)	
(43)		Edh at Noon	52	74	93	112	108	104	107	101	83	68	50	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.39	0.96	2.40	4.06	5.38	5.85	5.40	4.24	2.94	1.41	0.53	0.28	(44)	
(45)		RadStd	0.08	0.17	0.22	0.47	0.46	0.44	0.54	0.31	0.29	0.18	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (60 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	-123	-172	N/A	N/A

Nomenclature: See separate page