

ROEMOE JUVRE, Denmark

WMO: 060960

Lat: 55.1906N

Lon: 8.5600E

Elev: 30

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	22.5	14.4	11.4	21.4	17.8	13.5	23.7	47.5	44.0	42.7	43.1	12.0	130	0.809

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	78.3	66.8	74.4	64.9	71.1	63.4	68.1	75.5	66.3	72.3	64.7	69.8	14.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	94.1	71.5	63.9	88.9	69.7	62.4	84.3	67.8	32.4	75.9	31.0	72.5	29.7	70.0	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
36.9	32.5	29.3		17.6	84.2	4.9	3.0	14.0	86.3	11.2	88.0	8.4	89.7	4.9	91.9	
				16.6	71.8	4.8	1.7	13.2	73.0	10.4	74.0	7.8	75.0	4.3	76.2	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	34.9	35.4	38.7	45.7	53.0	58.1	62.6	63.2	57.9	50.4	43.0	37.6	(6)
(7)		DBStd	11.45	6.43	6.09	5.13	5.32	5.36	4.73	4.71	4.11	3.94	5.03	5.71	7.00	(7)
(8)		HDD50	2065	469	410	351	151	26	0	0	0	1	58	215	384	(8)
(9)		HDD65	6120	934	830	816	578	374	215	109	87	216	453	659	849	(9)
(10)		CDD50	1496	0	0	0	23	118	244	389	408	238	70	6	0	(10)
(11)		CDD65	76	0	0	0	0	2	8	33	30	3	0	0	0	(11)
(12)		CDH74	358	0	0	0	0	8	43	172	127	8	0	0	0	(12)
(13)		CDH80	52	0	0	0	0	0	3	29	20	0	0	0	0	(13)
(14)	Wind	WSAvg	15.7	17.2	16.7	16.6	15.3	15.3	15.7	14.3	14.3	15.1	15.4	16.0	16.2	(14)
(15)	Precipitation	PrecAvg	31.0	2.5	2.1	1.9	1.4	1.7	2.4	2.6	3.5	3.2	3.7	3.2	2.8	(15)
(16)		PrecMax	39.0	4.8	3.8	3.8	3.0	3.1	4.4	4.7	8.0	7.2	7.0	5.9	6.3	(16)
(17)		PrecMin	19.2	0.1	0.7	0.3	0.1	0.1	0.1	0.8	1.2	1.0	1.5	1.4	0.9	(17)
(18)		PrecStd	4.7	1.3	0.8	1.0	0.7	0.8	1.1	1.2	1.8	1.7	1.3	1.3	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	47.8	55.5	67.4	74.8	78.7	83.7	82.8	74.4	63.1	56.6	50.8	(19)
(20)			MCWB	46.6	44.5	48.5	55.5	63.3	66.2	68.5	68.0	65.4	59.0	54.6	49.2	(20)
(21)		2%	DB	46.3	45.2	49.4	62.4	70.5	74.3	79.0	77.6	69.1	60.3	54.0	48.9	(21)
(22)			MCWB	44.7	43.4	46.0	53.2	59.4	63.2	67.1	67.0	62.4	57.3	52.2	47.5	(22)
(23)		5%	DB	44.6	43.9	46.6	58.1	66.1	69.7	74.5	73.2	65.8	58.6	52.2	47.5	(23)
(24)			MCWB	43.1	42.4	44.0	51.2	57.2	62.1	65.4	65.5	61.0	55.9	50.3	46.2	(24)
(25)		10%	DB	43.2	42.7	44.9	54.0	62.1	65.8	70.8	69.9	63.6	57.1	50.5	46.0	(25)
(26)			MCWB	42.1	41.4	42.9	49.4	55.7	60.0	63.9	64.0	59.5	54.7	48.6	44.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.4	45.5	49.2	57.7	65.2	68.3	70.8	70.7	66.4	60.0	54.9	49.6	(27)
(28)			MCDWB	48.1	47.2	52.2	64.2	72.8	76.5	80.1	78.4	72.0	62.0	56.0	50.5	(28)
(29)		2%	WB	45.0	43.9	46.5	54.3	61.1	65.1	68.4	68.0	63.6	58.1	52.6	48.0	(29)
(30)			MCDWB	45.9	44.9	49.4	60.7	67.2	71.3	76.0	75.2	67.6	59.8	53.8	48.8	(30)
(31)		5%	WB	43.5	42.8	44.6	51.9	58.4	62.7	66.4	66.3	61.8	56.4	50.5	46.5	(31)
(32)			MCDWB	44.4	43.7	46.0	56.4	64.3	67.8	72.4	71.9	65.0	58.1	51.8	47.2	(32)
(33)		10%	WB	42.2	41.6	43.2	49.7	56.1	60.5	64.6	64.7	60.2	55.1	48.8	45.0	(33)
(34)			MCDWB	43.2	42.6	44.6	53.7	61.3	65.1	70.1	69.3	63.1	56.8	50.2	46.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.7	5.9	7.7	10.7	10.8	9.6	9.9	8.7	7.6	6.3	6.0	(35)	
(36)			MCDBR	5.4	6.0	10.7	18.1	18.7	17.7	17.6	16.7	12.4	9.1	6.4	5.2	(36)
(37)			MCWBR	5.3	5.2	7.8	10.7	10.6	9.9	8.5	8.1	7.7	7.1	6.4	5.3	(37)
(38)		5% WB	MCDWB	5.2	5.6	9.6	16.2	16.3	15.2	15.3	14.5	10.9	8.4	6.2	5.2	(38)
(39)			MCWBR	5.5	5.1	7.5	10.5	10.3	9.6	8.5	8.0	7.7	7.1	6.4	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.343	0.366	0.399	0.390	0.387	0.401	0.402	0.382	0.361	0.337	0.314	(40)	
(41)		taud	2.259	2.305	2.294	2.254	2.342	2.373	2.350	2.355	2.394	2.382	2.310	2.257	(41)	
(42)		Ebn at Noon	185	230	253	260	271	272	266	257	246	221	180	161	(42)	
(43)		Edh at Noon	18	25	32	38	36	36	36	34	29	23	17	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	159	356	771	1289	1667	1750	1638	1316	920	482	197	116	(44)	
(45)		RadStd	25	50	70	148	164	139	179	96	97	57	28	11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-268	N/A	N/A

Nomenclature: See separate page