

ROEMOE JUVRE, Denmark

WMO: 060960

Lat: 55.1906N

Lon: 8.5600E

Elev: 9

StdP: 101.22

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -5.3	(d) -9.8	(e) 1.6	(f) -5.9	(g) -7.9	(h) 1.9	(i) -4.6	(j) 21.2	(k) 6.6	(l) 19.1	(m) 6.2	(n) 5.4	(o) 130	(p) 0.809

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.5	(c) 25.7	(d) 19.3	(e) 23.6	(f) 18.3	(g) 21.7	(h) 17.4	(i) 20.1	(j) 24.2	(k) 19.1	(l) 22.4	(m) 18.2	(n) 21.0	(o) 6.4	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.4	21.9	17.7	12.7	20.9	16.9	12.0	19.9	57.5	24.4	54.2	22.5	51.3	21.1	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
16.5	14.5	13.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-8.0	29.0	2.7	1.7	-10.0	30.2	-11.6	31.1	-13.1	32.1	-15.1	33.3
			-8.5	22.1	2.6	1.0	-10.4	22.8	-12.0	23.3	-13.5	23.9	-15.4	24.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	1.6	1.9	3.7	7.6	11.7	14.5	17.0	17.3	14.4	10.2	6.1	3.1		
	DBStd	6.36	3.57	3.38	2.85	2.96	2.98	2.63	2.62	2.28	2.19	2.79	3.17	3.89		
	HDD10.0	1147	261	228	195	84	14	0	0	0	1	32	119	213		
	HDD18.3	3400	519	461	453	321	208	119	61	48	120	252	366	472		
	CDD10.0	831	0	0	0	13	66	136	216	227	132	39	3	0		
	CDD18.3	42	0	0	0	0	1	4	18	17	2	0	0	0		
	CDH23.3	199	0	0	0	0	4	24	96	71	4	0	0	0		
	CDH26.7	29	0	0	0	0	0	2	16	11	0	0	0	0		
(14) Wind	WSAvg	7.0	7.7	7.5	7.4	6.9	6.9	7.0	6.4	6.4	6.7	6.9	7.1	7.3		
(15) Precipitation	PrecAvg	787	64	54	49	35	43	60	67	89	82	93	81	71		
	PrecMax	990	123	97	97	75	79	113	120	202	183	178	151	161		
	PrecMin	488	3	18	8	2	3	3	21	31	25	38	35	23		
	PrecStd	119	33	21	25	17	20	29	30	45	44	34	32	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	8.8	13.1	19.7	23.8	25.9	28.7	28.2	23.5	17.3	13.7	10.5		
		MCWB	8.1	6.9	9.2	13.0	17.4	19.0	20.3	20.0	18.6	15.0	12.5	9.6		
	2%	DB	8.0	7.4	9.7	16.9	21.4	23.5	26.1	25.4	20.6	15.7	12.2	9.4		
		MCWB	7.0	6.3	7.8	11.8	15.2	17.3	19.5	19.5	16.9	14.1	11.2	8.6		
	5%	DB	7.0	6.6	8.1	14.5	19.0	20.9	23.6	22.9	18.8	14.8	11.2	8.6		
		MCWB	6.2	5.8	6.7	10.6	14.0	16.7	18.6	18.6	16.1	13.3	10.2	7.9		
	10%	DB	6.2	5.9	7.1	12.2	16.7	18.8	21.5	21.0	17.6	13.9	10.3	7.8		
		MCWB	5.6	5.2	6.1	9.7	13.1	15.6	17.7	17.8	15.3	12.6	9.2	7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	7.5	9.6	14.3	18.5	20.2	21.6	21.5	19.1	15.6	12.7	9.8		
		MCDB	8.9	8.4	11.2	17.9	22.7	24.7	26.7	25.8	22.2	16.7	13.3	10.3		
	2%	WB	7.2	6.6	8.1	12.4	16.2	18.4	20.2	20.0	17.6	14.5	11.4	8.9		
		MCDB	7.7	7.2	9.7	15.9	19.6	21.8	24.4	24.0	19.8	15.5	12.1	9.3		
	5%	WB	6.4	6.0	7.0	11.1	14.7	17.0	19.1	19.0	16.6	13.6	10.3	8.0		
		MCDB	6.9	6.5	7.8	13.6	18.0	19.9	22.5	22.2	18.3	14.5	11.0	8.5		
	10%	WB	5.7	5.3	6.2	9.9	13.4	15.9	18.1	18.2	15.7	12.8	9.4	7.2		
		MCDB	6.2	5.9	7.0	12.0	16.3	18.4	21.2	20.7	17.3	13.8	10.1	7.8		
(35) Mean Daily Temperature Range	MDBR		3.2	3.3	4.3	6.0	6.0	5.4	5.5	5.5	4.8	4.2	3.5	3.3		
	5% DB	MCDBR	3.0	3.3	5.9	10.0	10.4	9.8	9.8	9.3	6.9	5.0	3.6	2.9		
		MCWBR	3.0	2.9	4.3	5.9	5.9	5.5	4.7	4.5	4.3	3.9	3.5	3.0		
	5% WB	MCDBR	2.9	3.1	5.3	9.0	9.1	8.5	8.5	8.1	6.1	4.6	3.5	2.9		
		MCWBR	3.0	2.8	4.1	5.8	5.7	5.3	4.7	4.4	4.3	4.0	3.5	3.0		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.343	0.366	0.399	0.390	0.387	0.401	0.402	0.382	0.361	0.337	0.314		
	taud		2.259	2.305	2.294	2.254	2.342	2.373	2.350	2.355	2.394	2.382	2.310	2.257		
	Ebn at Noon		584	724	797	821	853	859	837	811	776	696	568	509		
	Edh at Noon		58	79	100	119	115	113	114	107	90	73	55	47		
(44) All-Sky Solar Radiation	RadAvg		0.50	1.12	2.43	4.06	5.26	5.52	5.16	4.15	2.90	1.52	0.62	0.36		
	RadStd		0.08	0.16	0.22	0.47	0.52	0.44	0.56	0.30	0.30	0.18	0.09	0.04		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-149	N/A	N/A

Nomenclature: See separate page