

KEGNAES FYR, Denmark

WMO: 061190

Lat: 54.8528N

Lon: 9.9881E

Elev: 62

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.3	25.3	17.7	13.5	25.1	20.4	15.3	26.8	45.3	39.5	41.5	38.7	16.5	40	0.757

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	74.3	67.2	72.2	66.0	70.1	64.8	68.7	72.5	67.1	70.7	65.7	69.1	10.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	100.4	71.2	65.7	94.9	69.5	64.2	90.0	68.1	33.0	72.6	31.7	71.0	30.5	69.2	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
38.8	33.6	30.2	DB	21.1	79.3	3.0	4.1	19.0	82.2	17.3	84.6	15.6	86.9	13.5	89.9	
			WB	20.2	71.2	2.6	3.6	18.4	73.8	16.9	75.9	15.5	77.9	13.6	80.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.0	35.7	35.8	39.0	45.0	53.1	58.7	63.4	63.8	58.6	51.7	44.0	38.4
	DBStd	11.25	5.57	5.35	5.72	4.46	4.61	4.23	4.45	3.78	3.73	4.50	4.96	5.72
	HDD50	1952	444	399	348	160	21	0	0	0	0	34	187	359
	HDD65	5917	909	819	808	600	371	194	86	69	195	413	630	823
	CDD50	1587	0	0	6	10	116	261	416	428	258	86	6	0
	CDD65	78	0	0	1	0	0	5	37	32	3	0	0	0
	CDH74	86	0	0	11	0	0	8	45	22	0	0	0	0
	CDH80	9	0	0	6	0	0	1	1	1	0	0	0	0
Wind	WSAvg	15.3	18.8	17.4	16.2	13.9	12.8	12.1	11.7	13.0	14.5	16.7	17.7	18.9
Precipitation	PrecAvg	29.3	2.7	2.0	1.8	1.4	2.0	2.6	3.0	3.1	2.8	2.8	2.4	2.7
	PrecMax	37.2	5.7	4.6	4.0	4.3	3.7	5.6	6.1	7.8	5.6	5.9	6.1	5.9
	PrecMin	19.1	0.0	0.4	0.2	0.0	0.6	0.0	0.9	1.1	0.7	0.7	0.4	1.0
	PrecStd	4.4	1.4	0.9	0.9	0.9	0.9	1.2	1.5	1.5	1.4	1.0	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.6	48.2	63.6	60.5	68.7	74.4	78.1	77.0	70.2	62.8	56.4	51.0
		MCWB	47.0	45.8	58.9	53.1	61.1	66.0	68.8	68.0	63.9	59.6	54.3	49.5
	2%	DB	46.3	45.7	51.3	56.4	64.8	69.7	74.9	73.7	67.8	60.3	54.1	48.9
		MCWB	45.0	44.3	47.1	51.9	59.3	63.3	67.7	66.8	63.1	57.6	52.4	47.6
	5%	DB	44.7	44.1	47.1	53.6	62.3	67.2	72.8	71.8	65.9	59.0	52.1	47.4
		MCWB	43.5	43.0	44.3	50.1	57.4	61.8	66.7	65.9	61.5	56.7	50.3	46.2
	10%	DB	43.0	42.7	45.0	51.3	59.9	65.3	70.8	69.9	64.3	57.6	50.3	45.8
		MCWB	42.0	41.6	43.0	48.2	55.9	60.7	65.3	64.9	60.2	55.6	48.7	44.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	46.7	59.1	55.4	62.6	67.3	71.1	70.2	66.1	60.3	54.8	50.1
		MCDB	48.2	47.4	61.8	59.1	66.5	71.9	75.2	73.6	68.6	61.8	55.9	50.7
	2%	WB	45.3	44.7	47.3	52.6	60.3	64.8	69.4	68.3	64.1	58.5	52.7	48.0
		MCDB	46.0	45.4	49.9	55.4	63.7	68.3	73.5	71.8	66.8	59.7	53.9	48.6
	5%	WB	43.7	43.2	44.9	50.5	58.3	63.0	67.8	67.0	62.5	57.2	50.5	46.4
		MCDB	44.5	43.9	46.4	53.0	61.2	66.2	71.5	70.4	65.1	58.6	51.7	47.3
	10%	WB	42.1	41.8	43.3	48.6	56.4	61.6	66.1	65.7	61.0	55.9	49.0	44.8
		MCDB	42.9	42.6	44.7	50.9	59.4	64.5	69.7	69.0	63.6	57.4	50.2	45.6
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.0	6.6	8.0	9.0	9.5	9.0	8.1	6.8	5.5	4.9	4.8
		MCDBR	5.7	6.3	9.8	10.7	11.8	12.5	11.7	10.1	8.4	6.2	5.5	5.3
		MCWBR	5.6	5.3	6.9	7.2	7.7	7.8	6.8	5.9	5.4	4.9	4.9	5.2
	5% WB	MCDBR	5.7	6.1	8.9	10.0	10.6	10.4	9.6	8.2	6.9	5.7	5.4	5.3
		MCWBR	5.7	5.5	6.9	7.2	7.6	7.6	6.4	5.8	5.2	4.9	5.1	5.2
Clear-Sky Solar Irradiance	taub	0.321	0.341	0.368	0.402	0.394	0.390	0.408	0.407	0.383	0.360	0.338	0.309	
	taud	2.276	2.300	2.262	2.218	2.321	2.361	2.329	2.342	2.390	2.404	2.341	2.269	
	Ebn at Noon	191	232	252	259	270	272	264	256	246	223	184	167	
	Edh at Noon	18	25	33	39	37	36	37	34	29	23	17	15	
All-Sky Solar Radiation	RadAvg	155	353	774	1303	1667	1757	1643	1322	941	491	198	113	
	RadStd	23	54	71	152	170	132	185	95	97	60	26	9	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-286	N/A	N/A

Nomenclature: See separate page