

KEGNAES FYR, Denmark

WMO: 061190

Lat: 54.8528N

Lon: 9.9881E

Elev: 19

StdP: 101.10

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.9	-3.7	-7.9	1.9	-3.8	-6.5	2.2	-2.9	20.2	4.2	18.6	3.7	7.4	40	0.757

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	23.5	19.5	22.3	18.9	21.2	18.2	20.4	22.5	19.5	21.5	18.7	20.6	4.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.3	21.8	18.7	13.6	20.8	17.9	12.9	20.1	58.8	22.6	55.8	21.6	53.1	20.7	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	15.0	13.5	DB	-6.0	26.3	1.6	2.3	-7.2	27.9	-8.2	29.2	-9.1	30.5	-10.3	32.2	(4)
(5)			WB	-6.5	21.8	1.4	2.0	-7.6	23.2	-8.4	24.4	-9.2	25.5	-10.2	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	2.0	2.1	3.9	7.2	11.7	14.8	17.5	17.7	14.8	10.9	6.7	3.6	(6)
(7)		DBStd	6.25	3.09	2.97	3.18	2.48	2.56	2.35	2.47	2.10	2.07	2.50	2.76	3.18	(7)
(8)		HDD10.0	1084	247	222	193	89	12	0	0	0	0	19	104	199	(8)
(9)		HDD18.3	3287	505	455	449	333	206	108	48	38	108	229	350	457	(9)
(10)		CDD10.0	882	0	0	3	6	64	145	231	238	143	48	3	0	(10)
(11)		CDD18.3	43	0	0	1	0	0	3	21	18	2	0	0	0	(11)
(12)		CDH23.3	48	0	0	6	0	0	4	25	12	0	0	0	0	(12)
(13)		CDH26.7	5	0	0	3	0	0	1	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	6.8	8.4	7.8	7.2	6.2	5.7	5.4	5.2	5.8	6.5	7.5	7.9	8.4	(14)
(15)	Precipitation	PrecAvg	743	68	51	45	35	51	66	75	80	72	70	62	69	(15)
(16)		PrecMax	946	146	117	102	108	93	143	154	197	142	151	155	150	(16)
(17)		PrecMin	486	1	9	6	1	16	0	23	28	19	19	10	26	(17)
(18)		PrecStd	113	36	23	23	22	23	31	38	37	36	25	36	34	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	9.0	17.6	15.8	20.4	23.6	25.6	25.0	21.2	17.1	13.6	10.6	(19)
(20)			MCWB	8.3	7.7	14.9	11.7	16.2	18.9	20.4	20.0	17.7	15.3	12.4	9.7	(20)
(21)		2%	DB	7.9	7.6	10.7	13.6	18.2	21.0	23.9	23.2	19.9	15.7	12.3	9.4	(21)
(22)			MCWB	7.2	6.8	8.4	11.0	15.2	17.4	19.8	19.3	17.3	14.2	11.3	8.7	(22)
(23)		5%	DB	7.0	6.7	8.4	12.0	16.8	19.6	22.7	22.1	18.8	15.0	11.1	8.6	(23)
(24)			MCWB	6.4	6.1	6.8	10.0	14.1	16.6	19.3	18.8	16.4	13.7	10.2	7.9	(24)
(25)		10%	DB	6.1	6.0	7.2	10.7	15.5	18.5	21.6	21.1	17.9	14.2	10.2	7.7	(25)
(26)			MCWB	5.5	5.3	6.1	9.0	13.3	15.9	18.5	18.3	15.7	13.1	9.3	7.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	8.2	15.0	13.0	17.0	19.6	21.7	21.2	18.9	15.7	12.7	10.1	(27)
(28)			MCD B	9.0	8.6	16.6	15.1	19.1	22.2	24.0	23.1	20.3	16.6	13.3	10.4	(28)
(29)		2%	WB	7.4	7.1	8.5	11.4	15.7	18.2	20.8	20.2	17.8	14.7	11.5	8.9	(29)
(30)			MCD B	7.8	7.5	9.9	13.0	17.6	20.2	23.1	22.1	19.3	15.4	12.1	9.2	(30)
(31)		5%	WB	6.5	6.2	7.1	10.3	14.6	17.2	19.9	19.5	16.9	14.0	10.3	8.0	(31)
(32)			MCD B	6.9	6.6	8.0	11.7	16.2	19.0	22.0	21.3	18.4	14.8	10.9	8.5	(32)
(33)		10%	WB	5.6	5.4	6.3	9.2	13.6	16.4	18.9	18.7	16.1	13.3	9.4	7.1	(33)
(34)			MCD B	6.0	5.9	7.1	10.5	15.2	18.1	21.0	20.5	17.5	14.1	10.1	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.6	2.8	3.7	4.4	5.0	5.3	5.0	4.5	3.8	3.1	2.7	2.6	(35)
(36)			MCDBR	3.2	3.5	5.5	5.9	6.6	6.9	6.5	5.6	4.7	3.4	3.1	2.9	(36)
(37)			MCWBR	3.1	3.0	3.8	4.0	4.3	4.4	3.8	3.3	3.0	2.7	2.7	2.9	(37)
(38)		5% WB	MCDBR	3.2	3.4	4.9	5.5	5.9	5.8	5.3	4.6	3.8	3.1	3.0	2.9	(38)
(39)			MCWBR	3.2	3.1	3.8	4.0	4.2	4.2	3.6	3.2	2.9	2.7	2.8	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.341	0.368	0.402	0.394	0.390	0.408	0.407	0.383	0.360	0.338	0.309	(40)	
(41)		taud	2.276	2.300	2.262	2.218	2.321	2.361	2.329	2.342	2.390	2.404	2.341	2.269	(41)	
(42)		Ebn at Noon	602	731	795	818	850	857	832	808	777	704	580	528	(42)	
(43)		Edh at Noon	58	80	103	123	118	115	116	108	91	72	55	47	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.49	1.11	2.44	4.11	5.25	5.54	5.18	4.17	2.97	1.55	0.62	0.35	(44)	
(45)		RadStd	0.07	0.17	0.23	0.48	0.54	0.41	0.58	0.30	0.30	0.19	0.08	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-159	N/A	N/A

Nomenclature: See separate page