

SYDFYNS TASINGE ISL, Denmark

WMO: 061240

Lat: 55.0144N

Lon: 10.5694E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.0	-4.9	-9.8	1.6	-5.4	-7.8	1.9	-4.0	12.4	4.9	11.2	4.5	3.3	40	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	26.1	19.1	24.4	18.6	22.7	17.6	20.2	24.3	19.2	22.8	18.4	21.7	4.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	13.6	22.0	17.9	12.8	20.9	17.0	12.1	20.1	58.1	24.5	54.8	22.9	52.0	21.9	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.5	8.6	-9.7	28.8	3.4	1.5	-12.1	29.9	-14.1	30.8	-16.0	31.6	-18.5	32.7		
(5)			-10.0	22.0	3.3	1.1	-12.5	22.7	-14.4	23.4	-16.3	24.0	-18.7	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.4	1.4	3.8	7.8	12.0	15.1	17.6	17.6	14.5	10.2	6.2	3.4	(6)
(7)		DBStd	6.53	3.52	3.37	3.18	2.97	2.85	2.44	2.61	2.24	2.38	2.95	2.92	3.48	(7)
(8)		HDD10.0	1149	267	242	193	79	12	1	0	0	1	33	117	205	(8)
(9)		HDD18.3	3352	525	475	452	317	197	102	47	42	116	251	364	463	(9)
(10)		CDD10.0	888	0	0	0	12	74	152	235	236	136	41	3	0	(10)
(11)		CDD18.3	48	0	0	0	0	1	3	24	18	2	0	0	0	(11)
(12)		CDH23.3	256	0	0	0	0	3	21	149	78	4	0	0	0	(12)
(13)		CDH26.7	27	0	0	0	0	0	1	18	8	0	0	0	0	(13)
(14)	Wind	WSAvg	4.2	4.6	4.3	4.5	4.2	4.0	4.1	3.9	3.8	3.9	3.9	4.2	4.6	(14)
(15)	Precipitation	PrecAvg	672	60	45	40	35	44	65	62	69	63	64	62	59	(15)
(16)		PrecMax	831	127	99	95	94	86	132	121	150	152	157	135	126	(16)
(17)		PrecMin	471	0	5	9	4	16	2	17	19	16	22	10	20	(17)
(18)		PrecStd	100	33	20	21	20	20	34	34	37	37	28	32	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	9.1	13.2	19.5	23.3	25.8	28.7	27.7	24.0	18.2	13.6	10.6	(19)
(20)			MCWB	8.7	7.3	9.5	13.2	16.9	18.8	20.5	19.5	17.9	15.2	12.6	9.8	(20)
(21)		2%	DB	8.0	7.8	10.7	16.4	20.8	23.5	26.7	25.6	21.6	16.2	12.1	9.6	(21)
(22)			MCWB	7.2	6.5	7.8	11.5	15.4	18.0	19.5	19.0	17.1	14.2	11.3	8.8	(22)
(23)		5%	DB	7.1	6.7	8.9	14.5	19.2	21.6	25.1	23.6	19.9	15.1	11.0	8.6	(23)
(24)			MCWB	6.3	5.6	6.9	10.4	14.3	16.8	18.9	18.1	16.3	13.5	10.2	7.9	(24)
(25)		10%	DB	6.1	5.7	7.7	12.7	17.5	19.9	23.2	21.9	18.5	14.1	10.1	7.6	(25)
(26)			MCWB	5.4	4.8	6.3	9.5	13.4	15.9	18.1	17.5	15.4	12.7	9.3	6.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	7.8	10.1	13.7	18.0	20.6	21.8	20.9	19.1	16.0	12.9	10.1	(27)
(28)			MCDWB	9.5	8.6	12.3	17.9	21.9	24.3	25.9	24.9	21.7	17.4	13.3	10.5	(28)
(29)		2%	WB	7.4	6.7	8.3	12.1	16.4	18.7	20.6	19.6	17.7	14.7	11.4	8.9	(29)
(30)			MCDWB	7.9	7.5	9.9	15.6	19.7	22.0	24.8	23.5	20.3	15.8	11.9	9.3	(30)
(31)		5%	WB	6.4	5.8	7.3	10.9	15.1	17.6	19.6	18.9	16.9	13.8	10.3	8.0	(31)
(32)			MCDWB	6.9	6.6	8.5	13.6	18.1	20.7	23.6	22.3	19.4	14.8	10.9	8.4	(32)
(33)		10%	WB	5.4	4.9	6.5	9.9	13.8	16.4	18.6	18.2	16.0	12.9	9.4	7.0	(33)
(34)			MCDWB	6.0	5.6	7.6	12.3	16.8	19.3	22.2	21.2	18.2	13.9	10.0	7.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.4	3.6	5.2	7.0	8.0	7.8	7.9	7.1	6.3	4.8	3.6	3.3	(35)
(36)			MCDBR	3.5	4.5	7.1	9.8	11.1	10.6	11.2	9.9	8.4	5.7	3.6	3.3	(36)
(37)			MCWBR	3.4	3.5	5.0	5.9	6.5	6.3	5.3	4.6	4.9	4.2	3.3	3.3	(37)
(38)		5% WB	MCDWR	3.5	4.3	6.3	8.8	9.6	9.5	10.0	8.5	7.7	5.4	3.5	3.2	(38)
(39)			MCWBR	3.5	3.5	4.7	5.7	6.2	6.2	5.4	4.6	4.8	4.2	3.3	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.341	0.368	0.403	0.395	0.390	0.409	0.409	0.383	0.360	0.339	0.309	(40)	
(41)		taud	2.288	2.310	2.275	2.228	2.336	2.381	2.343	2.353	2.404	2.412	2.342	2.272	(41)	
(42)		Ebn at Noon	600	729	795	817	849	857	830	805	777	702	576	523	(42)	
(43)		Edh at Noon	57	79	102	122	116	112	115	107	90	71	55	47	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.47	1.08	2.46	4.15	5.30	5.66	5.27	4.22	3.03	1.54	0.61	0.34	(44)	
(45)		RadStd	0.07	0.17	0.23	0.50	0.54	0.39	0.58	0.29	0.29	0.20	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-159	N/A	N/A

Nomenclature: See separate page