

TYSTOFTE, Denmark

WMO: 061360

Lat: 55.2464N

Lon: 11.3283E

Elev: 39

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.0	22.6	12.4	10.4	25.7	15.7	12.2	30.2	43.2	40.2	38.2	40.2	8.8	20	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	79.2	65.1	76.2	64.0	73.2	62.8	67.9	75.1	66.1	72.8	64.5	70.8	11.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.3	71.2	63.5	87.8	69.5	61.9	82.9	67.7	32.2	75.6	30.9	72.9	29.6	71.1	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.1	29.8	24.7	DB	14.0	83.0	5.8	3.6	9.8	85.6	6.4	87.7	3.1	89.8	-1.1	92.4	(4)
(5)			WB	14.0	70.4	5.6	1.8	10.0	71.6	6.7	72.7	3.6	73.7	-0.5	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	34.6	34.4	38.8	46.4	53.7	59.8	64.4	63.4	58.3	50.7	43.5	38.3
	DBStd	11.88	6.25	5.97	6.10	5.52	5.65	4.30	4.58	3.86	4.13	4.91	5.88	6.41
	HDD50	2041	477	436	347	136	25	0	0	0	1	51	204	364
	HDD65	5954	942	856	811	559	354	164	69	77	203	444	646	829
	CDD50	1656	0	0	1	27	138	295	447	417	251	73	7	0
	CDD65	94	0	0	0	0	2	9	51	29	3	0	0	0
	CDH74	508	0	0	0	0	12	56	328	108	4	0	0	0
	CDH80	53	0	0	0	0	0	1	40	12	0	0	0	0
Wind	WSAvg	11.1	13.5	12.2	11.7	9.9	10.3	9.3	9.5	9.7	10.5	11.3	12.5	12.9
Precipitation	PrecAvg	23.5	1.9	1.4	1.4	1.3	1.6	2.2	2.3	2.5	2.3	2.1	2.2	2.0
	PrecMax	29.4	3.8	2.8	3.1	3.0	3.2	4.9	5.3	5.9	5.8	4.0	4.8	3.8
	PrecMin	15.8	0.0	0.1	0.3	0.3	0.3	0.0	0.4	0.7	0.4	0.9	0.5	0.8
	PrecStd	3.3	0.9	0.5	0.7	0.6	0.7	1.1	1.1	1.4	1.3	0.8	1.1	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	47.4	56.9	67.8	75.5	78.7	83.7	81.8	73.8	64.6	56.4	50.4
		MCWB	47.2	44.4	49.1	55.9	63.3	64.9	67.3	66.1	62.9	59.2	54.3	48.8
	2%	DB	46.3	45.4	51.9	62.9	71.3	75.5	80.7	76.9	70.2	61.1	54.2	48.6
		MCWB	44.5	43.0	46.2	52.7	59.4	64.3	65.3	64.5	61.5	57.3	52.4	47.0
	5%	DB	44.8	43.7	48.5	59.2	67.9	72.1	77.9	73.5	67.1	59.1	52.5	47.4
		MCWB	43.0	41.8	44.3	50.5	57.8	62.7	64.6	63.2	60.1	56.2	50.7	45.9
	10%	DB	43.1	42.1	46.2	55.6	64.3	68.6	74.6	70.6	64.7	57.4	50.8	45.9
		MCWB	41.6	40.4	43.3	48.8	55.7	60.3	63.0	61.7	58.7	54.7	49.0	44.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	45.3	50.1	56.6	65.2	68.2	70.4	68.9	65.3	60.6	54.9	49.4
		MCDB	49.1	46.5	54.8	64.8	73.4	74.7	79.5	75.7	70.4	63.9	55.9	50.2
	2%	WB	44.9	43.3	46.9	53.8	61.8	65.7	68.6	66.7	62.9	58.2	52.8	47.5
		MCDB	46.0	44.6	50.7	61.7	68.7	72.5	77.1	72.7	67.8	60.3	53.9	48.3
	5%	WB	43.2	42.0	45.0	51.6	59.3	63.7	66.9	65.2	61.6	56.6	50.9	46.0
		MCDB	44.3	43.4	47.5	57.7	64.8	70.3	74.4	71.1	66.1	58.6	52.3	47.1
	10%	WB	41.5	40.4	43.6	49.5	56.8	61.7	65.1	63.7	60.2	55.1	49.2	44.6
		MCDB	42.8	42.0	45.9	54.5	62.8	67.3	71.8	69.1	64.1	57.1	50.6	45.8
Mean Daily Temperature Range	5% DB	MDBR	5.9	6.3	9.1	13.2	14.1	13.6	13.9	12.0	10.7	8.4	6.1	5.8
		MCDBR	6.2	7.4	12.4	19.2	20.0	19.4	19.8	16.6	13.8	9.9	6.1	5.8
		MCWBR	6.2	5.9	8.3	11.1	11.3	11.0	9.0	7.9	8.0	7.2	5.4	5.7
	5% WB	MCDBR	6.1	7.3	11.3	17.1	17.4	17.2	17.6	14.4	12.6	9.1	6.1	5.8
		MCWBR	6.3	6.1	8.1	10.6	11.2	10.7	9.1	8.0	7.8	7.2	5.6	5.9
Clear-Sky Solar Irradiance	taub	0.317	0.339	0.365	0.400	0.393	0.386	0.407	0.407	0.379	0.358	0.339	0.307	
	taud	2.288	2.311	2.287	2.241	2.334	2.379	2.341	2.349	2.409	2.410	2.341	2.265	
	Ebn at Noon	190	231	253	260	270	273	264	256	247	222	181	164	
	Edh at Noon	18	25	32	38	37	36	36	34	28	23	17	15	
All-Sky Solar Radiation	RadAvg	147	340	787	1317	1685	1806	1677	1343	958	483	189	105	
	RadStd	24	54	74	157	167	128	182	91	93	61	28	9	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (69 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-293	N/A	N/A

Nomenclature: See separate page