

TYSTOFTE, Denmark

WMO: 061360

Lat: 55.2464N

Lon: 11.3283E

Elev: 12

StdP: 101.18

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.2	-5.2	-10.9	1.5	-3.5	-9.1	1.7	-1.0	19.3	4.6	17.1	4.5	3.9	20	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	26.2	18.4	24.6	17.8	22.9	17.1	19.9	23.9	19.0	22.7	18.1	21.6	5.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.3	21.8	17.5	12.5	20.8	16.6	11.8	19.8	57.0	24.2	53.9	22.7	51.1	21.7	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	13.3	11.1	DB	-10.0	28.3	3.2	2.0	-12.3	29.8	-14.2	31.0	-16.0	32.1	-18.4	33.6
			WB	-10.0	21.3	3.1	1.0	-12.2	22.0	-14.0	22.6	-15.8	23.2	-18.0	23.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	1.4	1.4	3.8	8.0	12.0	15.5	18.0	17.5	14.6	10.4	6.4	3.5
	DBStd	6.60	3.47	3.31	3.39	3.07	3.14	2.39	2.54	2.15	2.29	2.73	3.27	3.56
	HDD10.0	1134	265	242	193	76	14	0	0	0	1	28	113	202
	HDD18.3	3308	523	476	451	311	197	91	38	43	113	247	359	461
	CDD10.0	920	0	0	1	15	77	164	248	232	139	41	4	0
	CDD18.3	52	0	0	0	0	1	5	28	16	2	0	0	0
	CDH23.3	282	0	0	0	0	7	31	182	60	2	0	0	0
	CDH26.7	29	0	0	0	0	0	1	22	7	0	0	0	0
Wind	WSAvg	5.0	6.0	5.4	5.2	4.4	4.6	4.1	4.3	4.3	4.7	5.0	5.6	5.7
Precipitation	PrecAvg	596	49	36	36	33	40	56	58	64	58	53	57	52
	PrecMax	747	97	72	80	75	81	125	134	149	147	102	121	96
	PrecMin	402	1	2	7	7	7	1	9	19	9	22	13	20
	PrecStd	85	23	13	18	15	19	29	29	36	34	21	27	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	8.5	13.8	19.9	24.2	25.9	28.7	27.7	23.2	18.1	13.6	10.2
		MCWB	8.5	6.9	9.5	13.3	17.4	18.3	19.6	18.9	17.2	15.1	12.4	9.3
	2%	DB	8.0	7.4	11.0	17.2	21.9	24.2	27.0	24.9	21.2	16.2	12.3	9.2
		MCWB	6.9	6.1	7.9	11.5	15.2	18.0	18.5	18.0	16.4	14.1	11.3	8.3
	5%	DB	7.1	6.5	9.1	15.1	20.0	22.3	25.5	23.1	19.5	15.1	11.4	8.6
		MCWB	6.1	5.4	6.9	10.3	14.3	17.1	18.1	17.3	15.6	13.4	10.4	7.7
	10%	DB	6.2	5.6	7.9	13.1	17.9	20.4	23.7	21.4	18.2	14.1	10.4	7.7
		MCWB	5.3	4.7	6.3	9.4	13.2	15.7	17.2	16.5	14.8	12.6	9.4	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	7.4	10.1	13.7	18.4	20.1	21.3	20.5	18.5	15.9	12.7	9.7
		MCDB	9.5	8.0	12.7	18.2	23.0	23.7	26.4	24.3	21.3	17.7	13.3	10.1
	2%	WB	7.1	6.3	8.3	12.1	16.6	18.7	20.3	19.3	17.2	14.6	11.5	8.6
		MCDB	7.8	7.0	10.4	16.5	20.4	22.5	25.0	22.6	19.9	15.7	12.2	9.1
	5%	WB	6.2	5.6	7.2	10.9	15.2	17.6	19.4	18.4	16.4	13.7	10.5	7.8
		MCDB	6.8	6.4	8.6	14.3	18.2	21.3	23.5	21.7	19.0	14.8	11.3	8.4
	10%	WB	5.3	4.7	6.5	9.7	13.8	16.5	18.4	17.6	15.7	12.8	9.6	7.0
		MCDB	6.0	5.5	7.7	12.5	17.1	19.6	22.1	20.6	17.8	13.9	10.3	7.7
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.5	5.1	7.3	7.8	7.6	7.7	6.7	5.9	4.7	3.4	3.2
		MCDBR	3.5	4.1	6.9	10.7	11.1	10.8	11.0	9.2	7.7	5.5	3.4	3.2
		MCWBR	3.4	3.3	4.6	6.2	6.3	6.1	5.0	4.4	4.5	4.0	3.0	3.1
	5% WB	MCDBR	3.4	4.0	6.3	9.5	9.7	9.5	9.8	8.0	7.0	5.1	3.4	3.2
		MCWBR	3.5	3.4	4.5	5.9	6.2	6.0	5.1	4.4	4.4	4.0	3.1	3.3
Clear-Sky Solar Irradiance	taub	0.317	0.339	0.365	0.400	0.393	0.386	0.407	0.407	0.379	0.358	0.339	0.307	
	taud	2.288	2.311	2.287	2.241	2.334	2.379	2.341	2.349	2.409	2.410	2.341	2.265	
	Ebn at Noon	599	729	797	819	850	860	832	806	779	701	570	518	
	Edh at Noon	56	78	100	120	116	112	115	107	89	71	54	46	
All-Sky Solar Radiation	RadAvg	0.46	1.07	2.48	4.15	5.31	5.69	5.29	4.23	3.02	1.52	0.60	0.33	
	RadStd	0.08	0.17	0.23	0.50	0.53	0.40	0.57	0.29	0.29	0.19	0.09	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-163	N/A	N/A

Nomenclature: See separate page