

VINDEBAEK KYST, Denmark

WMO: 061470

Lat: 54.8789N

Lon: 12.1842E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.4	25.1	16.7	12.8	24.7	19.9	14.9	27.2	34.3	40.2	32.1	37.6	11.8	40	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	75.0	67.1	72.4	65.6	70.3	64.2	68.6	73.2	66.8	70.9	65.4	69.1	10.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	98.5	71.6	65.1	92.7	69.4	63.7	88.3	68.0	32.8	73.2	31.4	71.3	30.3	69.1	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.5	28.2	25.5	19.1	81.3	5.1	3.7	15.4	84.0	12.5	86.2	9.6	88.3	5.9	91.0
			18.5	71.3	4.5	2.4	15.3	73.0	12.6	74.4	10.1	75.7	6.8	77.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.0	35.4	35.3	38.6	45.1	52.6	59.0	64.0	63.9	58.7	51.2	44.2	38.8	(6)
(7)		DBStd	11.35	5.56	5.36	5.39	4.57	4.57	3.73	3.94	3.56	3.83	4.54	5.03	5.80	(7)
(8)		HDD50	1961	452	412	353	155	25	0	0	0	39	179	346	(8)	
(9)		HDD65	5909	917	832	817	596	383	184	68	61	190	427	623	811	(9)
(10)		CDD50	1598	0	0	0	10	107	270	433	432	263	77	6	0	(10)
(11)		CDD65	70	0	0	0	0	0	4	36	28	2	0	0	0	(11)
(12)		CDH74	123	0	0	0	0	0	11	70	42	0	0	0	0	(12)
(13)		CDH80	8	0	0	0	0	0	1	4	3	0	0	0	0	(13)
(14)	Wind	WSAvg	13.1	15.9	14.0	13.5	12.1	11.4	11.1	10.8	11.5	12.7	13.7	14.7	15.3	(14)
(15)	Precipitation	PrecAvg	24.1	2.1	1.4	1.4	1.3	1.8	2.2	2.2	2.6	2.3	2.1	2.3	2.2	(15)
(16)		PrecMax	31.6	3.5	2.4	3.8	2.8	4.1	5.2	6.1	8.3	6.5	4.1	5.3	4.6	(16)
(17)		PrecMin	16.9	0.1	0.1	0.3	0.5	0.3	0.0	0.2	0.4	0.7	1.2	0.2	0.7	(17)
(18)		PrecStd	3.4	1.0	0.5	0.8	0.5	0.9	1.1	1.3	1.7	1.4	0.7	1.2	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.9	47.5	54.8	62.2	68.8	74.9	79.2	78.8	70.4	63.0	56.6	50.5	(19)
MCWB			47.1	44.7	48.7	53.1	60.5	66.8	69.3	69.8	64.8	59.3	54.7	48.8	(20)	
2%		DB	46.1	45.2	49.4	56.6	64.6	70.0	75.8	74.1	67.7	60.6	54.0	48.9	(21)	
		MCWB	44.2	43.0	45.1	50.8	58.1	62.8	67.6	66.7	63.0	57.7	52.2	47.1	(22)	
5%		DB	44.6	43.6	46.9	53.6	62.0	67.8	73.3	71.6	65.8	58.9	52.0	47.4	(23)	
		MCWB	43.0	41.6	43.6	49.1	56.8	60.8	66.4	65.3	61.3	56.3	50.4	45.7	(24)	
10%		DB	43.0	41.7	45.1	51.4	59.7	65.9	71.2	69.6	64.4	57.4	50.5	45.8	(25)	
		MCWB	41.5	40.0	42.5	47.3	55.2	60.2	65.0	63.9	60.2	54.9	48.9	44.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	45.5	48.7	53.8	62.1	67.7	71.9	70.6	66.0	60.3	55.3	49.4	(27)
MCD B			48.9	47.2	54.2	59.1	67.1	72.7	76.7	76.2	68.9	62.0	56.3	50.3	(28)	
2%		WB	44.7	43.5	45.8	51.4	59.5	64.7	69.6	68.1	64.1	58.2	52.5	47.6	(29)	
		MCD B	45.8	45.0	48.6	55.3	63.2	68.7	73.9	72.3	66.9	60.0	53.5	48.7	(30)	
5%		WB	43.2	41.8	44.1	49.5	57.5	62.6	67.5	66.5	62.4	56.7	50.6	46.0	(31)	
		MCD B	44.3	43.3	46.4	52.9	60.7	66.2	72.0	70.3	65.1	58.6	51.8	47.1	(32)	
10%		WB	41.6	40.2	42.7	47.8	55.8	61.0	66.0	65.1	61.1	55.3	49.1	44.3	(33)	
		MCD B	42.8	41.6	44.8	50.9	59.1	64.8	70.1	68.5	63.6	57.0	50.3	45.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.3	7.3	8.9	10.1	11.2	11.0	10.0	8.4	6.6	5.2	5.2	(35)
MCDBR			6.1	7.1	10.4	12.2	13.1	14.3	14.2	12.3	9.6	7.8	5.2	5.7	(36)	
MCWBR			5.8	5.5	7.3	8.0	8.6	8.9	8.4	7.3	6.4	5.9	5.1	5.6	(37)	
5% WB		MCD BR	6.0	6.9	10.1	11.8	12.0	12.6	12.5	11.2	8.6	7.5	5.1	5.5	(38)	
		MCWBR	6.0	5.7	7.3	8.3	8.7	8.8	8.3	7.6	6.3	6.0	5.1	5.5	(39)	
		Clear-Sky Solar Irradiance	taub	0.320	0.341	0.368	0.399	0.392	0.388	0.408	0.409	0.379	0.361	0.341	0.311	(40)
taud	2.314		2.326	2.289	2.269	2.356	2.394	2.354	2.361	2.426	2.414	2.355	2.294	(41)		
Ebn at Noon	193		233	253	261	271	273	264	256	249	223	183	168	(42)		
Edh at Noon	18		25	32	37	36	35	36	34	28	23	17	15	(43)		
(44)	All-Sky Solar Radiation	RadAvg	149	343	766	1321	1691	1809	1677	1352	966	490	194	104	(44)	
RadStd		23	59	73	154	176	130	193	95	89	68	28	10	(45)		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (69 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-290	N/A	N/A	

Nomenclature: See separate page