

OMOE FYR, Denmark

WMO: 061510

Lat: 55.1592N

Lon: 11.1347E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.2	-3.8	-8.7	1.8	-4.1	-7.2	2.1	-3.3	27.5	4.8	24.1	5.6	7.1	50	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	24.4	19.7	22.9	19.0	21.7	18.3	20.4	23.3	19.5	22.3	18.7	21.2	4.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	22.3	18.3	13.2	21.2	17.6	12.6	20.3	58.5	23.4	55.6	22.4	53.0	21.3	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	15.9	14.0	-6.6	27.0	2.1	2.6	-8.2	28.8	-9.4	30.3	-10.6	31.8	-12.1	33.7		
(5)			-7.4	21.7	2.1	1.2	-8.9	22.5	-10.1	23.2	-11.2	23.9	-12.7	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	1.8	1.6	3.5	7.6	12.2	15.6	18.3	18.2	15.3	10.9	7.0	3.9
	DBStd	6.51	3.13	2.73	2.72	2.40	2.53	2.13	2.41	1.99	2.07	2.55	2.61	2.97
	HDD10.0	1081	254	235	200	78	8	0	0	0	0	21	94	190
	HDD18.3	3209	513	468	458	322	191	85	32	27	94	230	342	448
	CDD10.0	972	0	0	0	7	76	168	257	254	158	49	3	0
	CDD18.3	58	0	0	0	0	0	3	31	23	2	0	0	0
	CDH23.3	98	0	0	0	0	0	3	68	27	0	0	0	0
	CDH26.7	5	0	0	0	0	0	0	3	2	0	0	0	0
Wind	WSAvg	7.4	8.8	8.0	7.3	6.5	6.3	6.9	6.0	6.2	7.1	8.0	8.7	8.9
Precipitation	PrecAvg	613	51	37	36	33	41	60	59	67	61	58	56	54
	PrecMax	769	101	66	76	70	78	131	124	148	165	118	117	99
	PrecMin	399	5	4	7	8	12	0	6	22	12	24	11	21
	PrecStd	92	24	13	18	15	18	32	29	37	36	23	25	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	7.6	10.4	16.0	21.0	24.0	27.1	25.9	22.1	17.2	13.1	9.8
		MCWB	7.6	6.2	8.0	12.2	16.8	19.2	20.9	20.5	18.5	15.2	12.2	8.8
	2%	DB	7.5	6.6	8.6	13.7	18.9	21.7	25.2	23.8	20.4	15.8	11.9	8.7
		MCWB	6.4	5.5	6.7	10.4	15.1	17.7	20.0	19.5	17.4	14.1	11.0	7.8
	5%	DB	6.7	5.8	7.4	12.2	17.5	20.4	23.6	22.5	19.1	14.8	11.0	8.1
		MCWB	5.8	4.9	6.0	9.5	14.3	16.8	19.3	18.9	16.6	13.5	10.1	7.3
	10%	DB	5.8	5.1	6.6	10.9	16.1	19.1	22.2	21.3	18.1	14.1	10.3	7.3
		MCWB	5.1	4.3	5.5	8.8	13.4	16.0	18.8	18.2	15.9	12.8	9.4	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	6.7	8.2	12.4	17.6	19.9	21.9	21.2	19.1	15.7	12.5	9.1
		MCDB	8.7	7.3	10.0	15.4	20.5	23.3	26.0	24.1	21.2	17.0	12.9	9.6
	2%	WB	6.7	5.7	6.9	10.9	15.7	18.2	20.7	20.1	17.8	14.5	11.2	8.1
		MCDB	7.3	6.3	8.0	13.1	18.0	20.7	23.8	23.0	19.6	15.4	11.7	8.5
	5%	WB	6.0	5.1	6.2	9.9	14.7	17.3	19.8	19.3	17.0	13.7	10.3	7.4
		MCDB	6.6	5.7	7.1	11.7	16.9	19.6	22.7	21.9	18.7	14.6	10.9	7.9
	10%	WB	5.2	4.4	5.6	9.0	13.6	16.4	19.0	18.6	16.3	13.0	9.5	6.7
		MCDB	5.8	5.0	6.4	10.7	15.6	18.6	21.8	20.8	17.8	13.9	10.1	7.2
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.5	3.3	4.6	5.1	5.3	5.4	4.6	4.1	3.1	2.5	2.4
		MCDBR	2.6	2.9	4.3	6.4	7.1	7.4	7.5	6.5	5.4	3.7	2.4	2.3
		MCWBR	2.4	2.3	3.1	4.2	4.6	4.7	4.2	3.8	3.5	3.0	2.5	2.2
	5% WB	MCDBR	2.5	2.8	4.1	5.8	6.5	6.6	7.0	5.8	5.1	3.6	2.4	2.2
		MCWBR	2.5	2.3	3.1	4.0	4.5	4.7	4.2	3.8	3.5	3.0	2.5	2.3
Clear-Sky Solar Irradiance	taub	0.319	0.340	0.367	0.402	0.394	0.388	0.408	0.408	0.381	0.359	0.339	0.309	
	taud	2.288	2.311	2.282	2.236	2.333	2.378	2.340	2.348	2.406	2.411	2.341	2.269	
	Ebn at Noon	600	729	796	818	849	858	830	805	778	702	571	519	
	Edh at Noon	57	78	101	121	116	113	115	108	89	71	54	46	
All-Sky Solar Radiation	RadAvg	0.47	1.08	2.47	4.15	5.31	5.68	5.28	4.23	3.02	1.53	0.60	0.33	
	RadStd	0.08	0.17	0.23	0.50	0.53	0.40	0.58	0.29	0.29	0.20	0.09	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-163	N/A	N/A

Nomenclature: See separate page