

VAERLOSE, Denmark

WMO: 061600

Lat: 55.767N

Lon: 12.343E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.4	-12.2	1.3	-7.0	-10.2	1.6	-5.4	14.5	4.6	12.4	4.6	1.4	20	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	26.8	18.5	25.1	18.0	23.2	17.4	20.1	23.5	19.1	22.9	18.3	22.1	3.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	21.5	18.0	12.9	20.4	17.0	12.1	19.5	57.6	23.3	54.3	22.5	51.6	21.8	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.1	8.9	-15.5	28.9	3.2	1.9	-17.8	30.3	-19.7	31.4	-21.5	32.5	-23.8	33.8		
			-15.7	21.9	3.2	1.3	-18.0	22.9	-19.9	23.7	-21.7	24.4	-24.1	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	0.3	0.8	2.2	6.9	10.8	14.1	16.9	17.2	13.2	8.8	4.5	1.1
	DBStd	6.91	3.93	3.76	3.46	3.67	2.72	2.60	2.82	2.88	2.74	3.44	3.29	4.03
	HDD10.0	1437	300	257	241	106	24	1	0	0	4	63	167	274
	HDD18.3	3773	558	490	499	342	234	130	63	58	154	297	416	533
	CDD10.0	752	0	0	1	14	48	124	215	223	101	24	2	0
	CDD18.3	46	0	0	0	0	0	3	19	23	1	0	0	0
	CDH23.3	369	0	0	0	2	1	27	177	159	2	0	0	0
	CDH26.7	52	0	0	0	0	0	3	34	15	0	0	0	0
Wind	WSAvg	4.1	4.4	4.9	4.7	4.1	3.9	4.1	3.4	3.5	3.7	4.1	4.0	4.0
Precipitation	PrecAvg	671	52	41	38	37	47	69	66	75	66	66	58	56
	PrecMax	872	96	88	76	79	86	157	188	201	158	126	116	108
	PrecMin	441	2	5	10	8	12	2	3	20	16	37	17	23
	PrecStd	103	27	18	20	19	22	39	44	44	41	27	21	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	9.9	13.1	22.2	22.1	26.2	29.9	28.2	23.2	17.7	13.1	10.9
		MCWB	8.1	8.3	8.4	14.9	14.8	18.4	19.3	19.1	17.3	14.4	12.0	9.8
	2%	DB	7.4	8.8	10.5	17.8	20.2	23.2	27.2	26.8	21.3	15.8	11.5	8.7
		MCWB	6.8	7.9	7.5	12.1	14.2	16.8	18.5	18.6	16.4	13.8	10.4	8.1
	5%	DB	6.2	7.7	9.0	15.1	18.8	21.4	25.2	25.1	19.7	14.2	10.3	7.5
		MCWB	5.6	6.9	7.0	10.7	12.9	16.0	18.1	18.1	15.3	12.8	9.2	6.9
	10%	DB	5.1	6.2	7.5	13.1	16.9	19.8	23.3	23.3	18.0	13.4	9.1	6.7
		MCWB	4.6	5.3	6.0	9.4	12.2	15.0	17.4	17.7	14.6	12.1	8.3	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.9	10.0	15.7	16.9	20.5	21.6	21.8	19.1	15.6	12.2	10.0
		MCDB	9.0	9.2	11.0	20.6	20.6	24.6	25.9	25.1	22.1	16.7	13.1	10.6
	2%	WB	6.9	8.0	8.2	13.1	15.0	18.1	20.3	20.0	17.3	14.1	10.7	8.1
		MCDB	7.3	8.5	9.5	16.7	19.0	21.5	24.1	23.0	19.8	15.2	11.4	8.5
	5%	WB	5.7	6.8	7.2	11.4	13.7	16.9	19.2	19.2	16.1	13.3	9.5	7.0
		MCDB	6.1	7.3	8.5	14.3	16.9	20.3	23.2	22.9	18.5	14.3	10.1	7.3
	10%	WB	4.7	5.5	6.0	10.0	12.7	15.7	18.3	18.4	15.2	12.4	8.4	6.0
		MCDB	5.0	6.1	7.3	12.2	15.6	18.9	22.3	22.2	17.3	13.4	9.0	6.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	6.6	8.4	9.0	8.4	9.2	9.2	7.7	6.3	4.8	4.5
		MCDBR	4.2	4.9	8.7	11.2	12.8	11.6	13.0	12.1	10.0	6.5	4.7	4.2
		MCWBR	4.1	4.2	6.3	6.7	7.4	6.7	6.1	5.4	5.7	4.9	4.2	4.2
	5% WB	MCDBR	4.2	4.7	7.7	10.0	10.3	10.2	10.7	10.4	8.9	6.1	4.7	4.2
		MCWBR	4.1	4.3	6.1	6.3	6.6	6.4	5.8	5.4	5.6	5.0	4.5	4.3
Clear-Sky Solar Irradiance	taub	0.314	0.336	0.359	0.393	0.389	0.383	0.405	0.405	0.375	0.356	0.336	0.304	
	taud	2.285	2.309	2.308	2.271	2.342	2.386	2.343	2.350	2.416	2.402	2.325	2.258	
	Ebn at Noon	591	725	801	824	852	862	832	805	781	697	557	504	
	Edh at Noon	55	77	97	116	115	111	114	107	87	70	53	44	
All-Sky Solar Radiation	RadAvg	0.44	1.04	2.43	4.14	5.34	5.68	5.27	4.24	2.99	1.47	0.56	0.30	
	RadStd	0.08	0.17	0.26	0.51	0.52	0.44	0.63	0.32	0.30	0.21	0.10	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (63 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-159	N/A	N/A

Nomenclature: See separate page