

NAKKEHOVED FYR, Denmark

WMO: 061680

Lat: 56.1193N

Lon: 12.3429E

Elev: 141

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	22.2	14.1	11.3	22.9	16.8	12.9	24.1	38.9	37.9	33.4	37.1	10.5	50	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	78.1	66.2	75.0	65.2	72.2	63.9	68.4	74.8	66.7	72.5	65.1	70.5	7.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	96.5	71.6	64.4	91.2	69.8	62.8	85.9	68.4	32.7	75.4	31.4	72.6	30.1	70.5	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.3	26.0	21.8	DB	16.3	84.2	4.2	3.3	13.3	86.6	10.8	88.5	8.5	90.4	5.4	92.9	(4)
(5)			WB	15.1	71.0	3.9	1.5	12.3	72.1	10.1	73.0	7.9	73.8	5.0	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	33.7	34.2	37.4	45.8	53.4	59.3	63.8	63.5	57.3	49.3	42.0	36.3	(6)
(7)		DBStd	12.08	6.05	5.96	5.45	5.64	5.40	4.62	4.75	4.44	4.20	4.89	5.15	6.28	(7)
(8)		HDD50	2252	506	441	390	151	25	0	0	0	1	71	243	424	(8)
(9)		HDD65	6268	971	861	854	576	360	180	81	86	234	486	690	889	(9)
(10)		CDD50	1552	0	0	0	25	131	279	428	417	219	50	3	0	(10)
(11)		CDD65	96	0	0	0	0	2	9	45	38	2	0	0	0	(11)
(12)		CDH74	371	0	0	0	3	11	51	185	117	4	0	0	0	(12)
(13)		CDH80	45	0	0	0	0	0	7	27	11	0	0	0	0	(13)
(14)	Wind	WSAvg	9.9	11.2	11.3	10.8	9.5	8.7	8.9	8.0	8.3	9.4	10.2	11.3	11.4	(14)
(15)	Precipitation	PrecAvg	26.3	2.1	1.7	1.4	1.5	1.9	2.8	2.6	3.1	2.6	2.5	2.1	2.2	(15)
(16)		PrecMax	34.6	3.8	3.5	3.2	2.7	3.9	5.8	5.5	7.7	5.4	4.6	4.2	4.1	(16)
(17)		PrecMin	19.1	0.2	0.1	0.3	0.4	0.6	0.3	0.2	1.0	0.5	1.4	0.6	0.8	(17)
(18)		PrecStd	3.7	1.1	0.8	0.8	0.7	0.9	1.4	1.6	1.8	1.4	0.9	0.8	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	49.0	55.8	70.3	75.4	79.6	83.4	81.6	74.1	63.0	55.2	50.8	(19)
(20)			MCWB	46.8	45.7	48.1	57.4	61.6	66.0	66.6	66.7	63.4	58.3	53.4	49.3	(20)
(21)		2%	DB	45.7	46.3	50.6	62.6	70.0	74.4	78.6	77.3	69.6	59.7	52.7	48.4	(21)
(22)			MCWB	44.2	44.3	45.6	52.5	58.4	63.0	67.1	66.1	61.5	56.6	51.1	47.3	(22)
(23)		5%	DB	43.8	44.1	47.1	58.4	66.0	70.8	75.4	73.9	66.1	57.5	50.6	46.1	(23)
(24)			MCWB	42.4	42.2	43.9	50.0	56.8	61.9	66.3	65.5	60.4	55.0	48.9	44.8	(24)
(25)		10%	DB	42.0	42.3	44.8	54.7	62.7	67.5	72.3	71.0	63.5	55.8	48.8	44.5	(25)
(26)			MCWB	40.6	40.6	42.2	48.2	55.2	60.0	64.9	64.3	58.8	53.5	47.2	43.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.2	47.0	49.2	57.6	63.5	67.7	70.7	70.3	65.1	59.6	54.2	49.8	(27)
(28)			MCDWB	48.2	48.0	53.6	67.6	72.0	76.6	77.8	76.6	71.3	61.2	54.8	50.4	(28)
(29)		2%	WB	44.6	44.5	46.3	53.5	60.4	64.8	68.8	68.3	62.6	57.2	51.4	47.3	(29)
(30)			MCDWB	45.5	45.9	49.3	60.2	67.3	71.7	75.4	74.0	68.0	59.2	52.5	48.1	(30)
(31)		5%	WB	42.5	42.6	44.3	51.2	58.2	62.8	67.2	66.6	60.9	55.5	49.3	45.1	(31)
(32)			MCDWB	43.6	43.9	46.7	56.8	64.1	69.0	73.3	71.8	64.8	57.1	50.3	46.0	(32)
(33)		10%	WB	40.7	40.8	42.4	48.9	56.1	61.0	65.5	65.1	59.4	53.9	47.5	43.4	(33)
(34)			MCDWB	41.8	42.2	44.5	53.6	61.6	66.4	71.0	69.9	62.8	55.5	48.5	44.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	6.6	9.2	12.4	13.4	12.5	12.2	11.5	9.6	7.5	6.1	5.8	(35)
(36)			MCDBR	6.8	8.2	13.0	18.8	19.1	18.5	17.6	16.0	13.9	9.3	7.3	6.6	(36)
(37)			MCWBR	6.4	7.0	9.2	10.8	11.3	10.5	9.3	8.1	8.0	7.0	6.6	6.6	(37)
(38)		5% WB	MCDBR	6.6	7.9	12.1	17.0	16.4	16.4	14.9	13.5	12.7	8.9	6.9	6.8	(38)
(39)			MCWBR	6.6	7.1	9.1	10.4	10.5	10.2	8.9	8.1	8.0	7.3	6.6	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.333	0.355	0.389	0.385	0.378	0.400	0.401	0.370	0.353	0.332	0.300	(40)	
(41)		taud	2.283	2.313	2.326	2.289	2.363	2.409	2.364	2.369	2.433	2.407	2.323	2.253	(41)	
(42)		Ebn at Noon	186	230	255	263	271	275	265	257	249	221	175	157	(42)	
(43)		Edh at Noon	17	24	30	36	36	34	35	33	27	22	16	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	135	323	759	1286	1671	1770	1642	1318	928	451	171	92	(44)	
(45)		RadStd	26	52	79	164	161	144	193	105	99	65	30	10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-302	+106	N/A

Nomenclature: See separate page