

NAKKEHOVED FYR, Denmark

WMO: 061680

Lat: 56.1193N

Lon: 12.3429E

Elev: 43

StdP: 100.81

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -5.5	(d) -10.0	(e) 1.6	(f) -5.0	(g) -8.4	(h) 1.8	(i) -4.4	(j) 17.4	(k) 3.3	(l) 14.9	(m) 2.8	(n) 4.7	(o) 50	(p) 0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	25.6	19.0	23.9	18.5	22.3	17.7	20.2	23.8	19.3	22.5	18.4	21.4	3.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.8	22.0	18.0	13.0	21.0	17.1	12.3	20.2	58.2	24.1	55.1	22.6	52.1	21.4	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.0	(b) 11.6	(c) 9.7	(e) -8.7	(f) 29.0	(g) 2.3	(h) 1.9	(i) -10.4	(j) 30.3	(k) -11.8	(l) 31.4	(m) -13.1	(n) 32.5	(o) -14.8	(p) 33.8		
(a) 14.0	(b) 11.6	(c) 9.7	(e) -9.4	(f) 21.6	(g) 2.2	(h) 0.9	(i) -10.9	(j) 22.3	(k) -12.2	(l) 22.8	(m) -13.4	(n) 23.2	(o) -15.0	(p) 23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	0.9	1.2	3.0	7.7	11.9	15.2	17.7	17.5	14.0	9.6	5.5	2.4
	DBStd	6.71	3.36	3.31	3.03	3.14	3.00	2.57	2.64	2.47	2.33	2.72	2.86	3.49
	HDD10.0	1251	281	245	217	84	14	0	0	0	1	39	135	236
	HDD18.3	3482	539	478	474	320	200	100	45	48	130	270	383	494
	CDD10.0	862	0	0	0	14	73	155	238	232	122	28	2	0
	CDD18.3	53	0	0	0	0	1	5	25	21	1	0	0	0
	CDH23.3	206	0	0	0	2	6	28	103	65	2	0	0	0
	CDH26.7	25	0	0	0	0	0	4	15	6	0	0	0	0
Wind	WSAvg	4.4	5.0	5.1	4.8	4.2	3.9	4.0	3.6	3.7	4.2	4.6	5.0	5.1
Precipitation	PrecAvg	669	53	43	35	39	47	70	66	80	66	63	54	55
	PrecMax	879	96	89	81	68	98	148	140	195	136	116	106	103
	PrecMin	486	5	3	8	9	16	8	6	25	13	36	16	20
	PrecStd	95	27	20	20	18	24	36	40	45	36	23	21	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	9.4	13.2	21.3	24.1	26.4	28.6	27.6	23.4	17.2	12.9	10.5
		MCWB	8.2	7.6	9.0	14.1	16.5	18.9	19.2	19.3	17.4	14.6	11.9	9.6
	2%	DB	7.6	7.9	10.3	17.0	21.1	23.6	25.9	25.1	20.9	15.4	11.5	9.1
		MCWB	6.8	6.8	7.6	11.4	14.7	17.2	19.5	19.0	16.4	13.7	10.6	8.5
	5%	DB	6.6	6.7	8.4	14.7	18.9	21.6	24.1	23.3	19.0	14.2	10.3	7.8
		MCWB	5.8	5.7	6.6	10.0	13.8	16.6	19.1	18.6	15.8	12.8	9.4	7.1
	10%	DB	5.6	5.7	7.1	12.6	17.1	19.7	22.4	21.7	17.5	13.2	9.3	6.9
		MCWB	4.8	4.8	5.7	9.0	12.9	15.5	18.3	17.9	14.9	12.0	8.5	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.3	9.6	14.2	17.5	19.8	21.5	21.3	18.4	15.3	12.3	9.9
		MCDB	9.0	8.9	12.0	19.8	22.2	24.8	25.4	24.8	21.8	16.2	12.6	10.2
	2%	WB	7.0	7.0	8.0	12.0	15.8	18.2	20.5	20.2	17.0	14.0	10.8	8.5
		MCDB	7.5	7.7	9.6	15.6	19.6	22.1	24.1	23.3	20.0	15.1	11.4	9.0
	5%	WB	5.9	5.9	6.8	10.7	14.6	17.1	19.6	19.2	16.1	13.1	9.6	7.3
		MCDB	6.4	6.6	8.2	13.8	17.8	20.5	23.0	22.1	18.2	13.9	10.2	7.8
	10%	WB	4.8	4.9	5.8	9.4	13.4	16.1	18.6	18.4	15.2	12.1	8.6	6.3
		MCDB	5.5	5.7	6.9	12.0	16.4	19.1	21.7	21.0	17.1	13.1	9.2	6.8
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.7	5.1	6.9	7.4	6.9	6.8	6.4	5.3	4.2	3.4	3.2
		MCDBR	3.8	4.6	7.2	10.5	10.6	10.3	9.8	8.9	7.7	5.2	4.0	3.7
		MCWBR	3.6	3.9	5.1	6.0	6.3	5.8	5.1	4.5	4.4	3.9	3.7	3.7
	5% WB	MCDBR	3.7	4.4	6.7	9.4	9.1	9.1	8.3	7.5	7.1	4.9	3.8	3.8
		MCWBR	3.7	4.0	5.1	5.8	5.8	5.7	4.9	4.5	4.4	4.0	3.7	3.8
Clear-Sky Solar Irradiance	taub	0.310	0.333	0.355	0.389	0.385	0.378	0.400	0.401	0.370	0.353	0.332	0.300	
	taud	2.283	2.313	2.326	2.289	2.363	2.409	2.364	2.369	2.433	2.407	2.323	2.253	
	Ebn at Noon	586	724	804	828	855	866	835	809	784	696	553	496	
	Edh at Noon	53	76	95	114	112	108	111	104	86	69	52	43	
All-Sky Solar Radiation	RadAvg	0.42	1.02	2.39	4.05	5.27	5.58	5.18	4.15	2.93	1.42	0.54	0.29	
	RadStd	0.08	0.16	0.25	0.52	0.51	0.46	0.61	0.33	0.31	0.21	0.10	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	-168	+59	N/A

Nomenclature: See separate page