

TESSEBOELLE, Denmark

WMO: 061740

Lat: 55.3956N

Lon: 12.1492E

Elev: 72

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	21.5	12.8	10.6	20.3	16.4	12.6	24.2	25.6	39.8	24.0	39.1	5.2	0	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	79.3	65.3	76.1	64.5	73.2	63.1	68.1	75.5	66.2	72.8	64.6	70.6	8.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	94.1	70.7	63.7	88.7	68.8	62.1	83.7	67.4	32.4	75.4	30.9	72.9	29.7	70.3	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	18.9	17.0	13.1	84.1	7.5	3.4	7.7	86.6	3.3	88.6	-0.9	90.6	-6.4	93.1
			12.5	71.5	7.4	1.8	7.2	72.8	2.9	73.9	-1.3	74.9	-6.6	76.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	33.9	34.1	38.3	45.5	52.6	58.4	63.5	62.5	57.1	49.6	42.5	37.6
	DBStd	11.79	6.63	6.48	6.48	5.55	5.73	4.54	4.62	4.08	4.27	5.28	5.78	6.72
	HDD50	2197	500	446	365	157	37	1	0	0	3	73	231	384
	HDD65	6264	965	866	829	586	384	204	88	100	239	478	676	849
	CDD50	1477	0	0	1	21	118	253	417	387	215	60	5	0
	CDD65	71	0	0	0	0	1	6	40	23	1	0	0	0
	CDH74	510	0	0	0	1	4	54	330	116	5	0	0	0
	CDH80	60	0	0	0	0	0	5	40	15	0	0	0	0
Wind	WSAvg	8.2	9.8	9.4	9.1	8.1	7.5	7.1	6.7	7.1	7.6	8.1	8.7	9.5
Precipitation	PrecAvg	24.9	2.0	1.5	1.5	1.4	1.7	2.2	2.3	2.6	2.6	2.4	2.4	2.2
	PrecMax	32.2	3.5	3.5	3.4	3.3	3.3	5.2	5.2	7.0	7.1	5.0	5.0	4.3
	PrecMin	15.9	0.1	0.2	0.3	0.4	0.3	0.0	0.1	0.5	0.4	1.2	0.6	1.0
	PrecStd	3.8	0.9	0.6	0.7	0.6	0.8	1.2	1.3	1.7	1.7	1.1	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	50.1	57.9	68.3	74.1	79.1	83.9	82.1	74.5	65.2	56.9	52.1
		MCWB	48.1	45.6	49.6	56.0	62.3	65.4	67.5	67.2	63.4	59.8	55.3	50.2
	2%	DB	46.6	46.5	53.0	63.0	70.8	75.0	80.7	77.1	70.1	61.0	54.1	49.9
		MCWB	45.0	43.9	47.2	53.1	60.5	64.0	65.5	64.6	62.0	57.2	52.4	48.5
	5%	DB	44.9	44.5	49.4	58.9	67.3	71.4	78.0	73.8	66.9	59.0	51.9	48.0
		MCWB	43.2	42.2	44.8	50.2	58.0	61.9	65.2	63.2	60.4	56.2	50.4	46.5
	10%	DB	43.1	42.5	46.9	55.4	64.1	68.5	74.6	71.2	64.6	56.9	50.1	45.9
		MCWB	41.7	40.7	43.6	48.5	56.0	60.0	64.2	62.1	58.8	54.5	48.6	44.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	46.8	51.1	57.5	65.1	69.3	70.5	69.4	65.0	60.9	55.7	51.2
		MCDB	49.7	48.8	55.8	66.4	71.5	75.9	78.7	77.7	70.7	63.8	56.4	52.1
	2%	WB	45.5	44.4	47.8	53.9	61.9	65.6	68.6	67.1	63.0	58.2	52.7	48.7
		MCDB	46.4	45.9	51.8	61.0	68.3	72.1	76.8	72.7	68.2	60.0	53.6	49.5
	5%	WB	43.6	42.6	45.7	51.6	59.4	63.3	67.0	65.2	61.5	56.5	50.5	46.6
		MCDB	44.6	44.2	48.6	57.6	65.2	69.3	74.6	70.6	65.8	58.5	51.6	47.9
	10%	WB	41.7	40.7	43.8	49.4	56.9	61.1	65.2	63.7	60.0	54.8	48.8	44.6
		MCDB	43.0	42.5	46.5	54.5	62.3	67.1	72.0	68.8	63.5	56.6	49.8	45.9
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.1	10.4	14.7	16.1	16.3	17.0	15.3	12.7	9.9	7.1	6.5
		MCDBR	7.3	9.2	14.8	20.4	21.1	21.5	22.9	19.1	16.0	11.6	7.5	7.0
		MCWBR	7.2	7.0	10.0	12.1	12.2	12.0	10.5	8.9	9.4	8.5	6.8	6.9
	5% WB	MCDBR	7.1	9.0	13.6	19.0	18.3	18.9	20.1	16.6	14.8	10.9	7.5	7.0
		MCWBR	7.1	7.2	9.8	12.0	11.7	11.8	10.5	9.2	9.3	8.7	7.0	7.0
Clear-Sky Solar Irradiance	taub	0.316	0.338	0.362	0.396	0.390	0.385	0.406	0.407	0.376	0.357	0.338	0.307	
	taud	2.293	2.310	2.296	2.260	2.337	2.378	2.338	2.345	2.411	2.402	2.335	2.268	
	Ebn at Noon	190	231	254	261	270	273	264	255	248	222	180	163	
	Edh at Noon	18	25	31	37	37	36	36	34	28	23	17	15	
All-Sky Solar Radiation	RadAvg	145	338	779	1328	1703	1821	1690	1358	964	479	185	99	
	RadStd	26	54	81	159	169	136	196	96	92	66	30	10	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
Regional (67 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	-293	N/A	N/A

Nomenclature: See separate page