

MOEN FYR, Denmark

WMO: 061790

Lat: 54.9467N

Lon: 12.5397E

Elev: 56

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.2	24.7	14.9	11.7	25.2	18.3	13.9	26.9	44.2	31.2	40.2	33.9	11.0	0	0.716

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	75.8	67.6	73.0	66.7	70.8	65.3	69.3	73.8	67.4	72.1	65.9	70.1	8.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	101.7	72.5	65.5	94.3	70.5	63.9	89.2	69.3	33.4	74.2	31.8	72.2	30.7	70.2	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.5	30.9	27.7	DB	18.5	80.5	4.2	2.7	15.5	82.4	13.1	84.0	10.7	85.6	7.7	87.6	(4)
(5)			WB	17.1	70.6	3.3	2.1	14.7	72.1	12.8	73.3	11.0	74.5	8.6	76.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	34.5	34.5	36.9	43.7	51.8	58.0	63.0	64.3	58.1	50.7	42.9	36.7	(6)	
	DBStd	11.68	5.09	5.24	4.72	4.08	4.08	3.86	4.46	5.01	3.96	5.13	4.90	5.05	(7)	
	HDD50	2224	481	433	407	194	26	0	0	0	0	53	217	413	(8)	
	HDD65	6301	946	853	872	639	411	213	94	78	210	443	664	878	(9)	
	CDD50	1494	0	0	0	6	81	240	402	443	244	75	3	0	(10)	
	CDD65	94	0	0	0	0	0	3	31	56	4	0	0	0	(11)	
	CDH74	159	0	0	0	0	0	7	52	99	1	0	0	0	(12)	
	CDH80	8	0	0	0	0	0	1	2	5	0	0	0	0	(13)	
(14) Wind	WSAvg	13.7	16.1	15.3	14.8	12.5	11.2	11.7	10.6	11.7	13.1	15.4	16.0	16.1	(14)	
(15) Precipitation	PrecAvg	25.4	2.0	1.6	1.6	1.4	2.0	2.6	2.6	2.8	2.3	2.0	2.1	2.2	(15)	
	PrecMax	33.4	3.5	3.0	3.9	2.9	4.0	6.2	11.1	6.1	5.6	3.7	5.2	4.5	(16)	
	PrecMin	19.2	0.0	0.3	0.3	0.2	0.6	0.0	0.1	1.1	0.7	1.0	0.3	0.7	(17)	
	PrecStd	3.8	0.9	0.6	0.8	0.6	0.9	1.3	2.0	1.4	1.2	0.6	1.0	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.8	46.7	49.8	58.9	67.8	73.3	78.6	80.3	72.2	63.3	53.9	48.5	(19)	
		MCWB	43.9	44.6	44.4	52.5	59.3	64.3	68.8	69.3	65.5	59.1	52.3	46.8	(20)	
	2%	DB	43.8	45.0	46.8	54.7	63.8	68.8	75.2	77.0	68.7	59.9	52.6	46.8	(21)	
		MCWB	42.1	43.3	43.6	50.1	57.0	62.1	66.9	68.5	63.1	56.7	50.7	45.4	(22)	
	5%	DB	42.2	43.2	44.9	52.0	60.9	66.5	72.7	74.0	66.5	58.1	50.9	45.4	(23)	
		MCWB	40.8	41.6	42.3	48.2	55.0	60.3	66.1	67.3	61.3	55.7	48.9	44.1	(24)	
	10%	DB	41.0	41.5	43.0	49.4	58.7	64.6	70.4	71.7	63.9	56.9	49.4	43.5	(25)	
		MCWB	39.7	40.1	40.6	45.8	53.4	59.2	64.5	66.7	59.5	54.9	47.6	42.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	45.6	46.4	53.4	60.0	65.5	71.8	72.0	66.7	59.7	53.1	47.4	(27)	
		MCDB	45.4	46.3	47.6	57.0	66.0	71.6	76.0	77.0	70.9	62.4	53.3	47.9	(28)	
	2%	WB	42.4	43.8	44.2	50.7	57.5	63.0	68.8	70.2	64.3	57.5	51.1	45.7	(29)	
		MCDB	43.4	44.6	46.2	53.9	62.4	67.6	73.7	74.6	68.2	59.0	52.1	46.6	(30)	
	5%	WB	41.0	41.8	42.6	48.6	55.8	61.4	66.6	68.4	62.0	56.4	49.3	44.2	(31)	
		MCDB	41.9	42.9	44.6	51.8	60.2	65.5	71.4	72.8	65.2	57.8	50.6	45.3	(32)	
	10%	WB	39.9	40.2	41.1	46.3	54.1	59.8	65.1	66.8	60.3	55.1	47.7	42.6	(33)	
		MCDB	40.8	41.3	42.6	48.8	58.2	63.6	69.5	71.0	63.0	56.8	49.1	43.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.6	7.1	8.1	9.4	9.8	9.6	9.1	7.6	6.3	5.3	5.3	(35)	
		MCDBR	5.3	6.1	9.5	11.3	12.9	12.5	12.8	12.1	11.3	7.2	5.7	5.8	(36)	
	5% WB	MCWBR	4.9	4.7	7.5	7.5	8.9	7.9	8.0	6.9	6.9	5.5	4.9	5.6	(37)	
		MCWBR	5.0	5.8	9.0	10.5	11.7	11.7	11.0	9.9	9.1	6.5	5.2	5.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.320	0.342	0.367	0.394	0.389	0.384	0.404	0.406	0.375	0.362	0.342	0.312	(40)	
		taud	2.319	2.332	2.296	2.301	2.383	2.421	2.379	2.385	2.448	2.416	2.356	2.296	(41)	
	Edn at Noon		193	232	253	263	272	274	265	257	250	223	183	167	(42)	
		Edh at Noon	18	24	32	36	35	34	35	33	27	23	17	15	(43)	
(44) All-Sky Solar Radiation	RadAvg		148	342	763	1325	1699	1819	1683	1360	969	487	193	102	(44)	
	RadStd		23	59	75	154	176	134	197	97	88	69	28	10	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-297	+113	N/A

Nomenclature: See separate page