

MOEN FYR, Denmark

WMO: 061790

Lat: 54.9467N

Lon: 12.5397E

Elev: 17

StdP: 101.12

Time Zone: 1.00 (EUC)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.4	-4.0	-9.5	1.7	-3.8	-7.6	2.0	-2.9	19.8	-0.5	18.0	1.1	4.9	0	0.716

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	24.3	19.8	22.8	19.3	21.6	18.5	20.7	23.2	19.7	22.3	18.8	21.2	3.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	22.5	18.6	13.5	21.4	17.7	12.7	20.7	59.8	23.4	56.2	22.3	53.4	21.2	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.8	12.4	DB	-7.5	26.9	2.3	1.5	-9.2	28.0	-10.5	28.9	-11.8	29.8	-13.5	30.9	(4)
(5)			WB	-8.3	21.5	1.8	1.2	-9.6	22.3	-10.7	23.0	-11.7	23.6	-13.0	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	1.4	1.4	2.7	6.5	11.0	14.4	17.2	17.9	14.5	10.4	6.0	2.6		
	DBStd	6.49	2.83	2.91	2.62	2.27	2.26	2.14	2.48	2.78	2.20	2.85	2.72	2.80		
	HDD10.0	1236	267	241	226	108	14	0	0	0	0	29	121	229		
	HDD18.3	3501	526	474	484	355	228	118	52	43	117	246	369	488		
	CDD10.0	830	0	0	0	3	45	133	223	246	136	42	2	0		
	CDD18.3	52	0	0	0	0	0	2	17	31	2	0	0	0		
	CDH23.3	88	0	0	0	0	0	4	29	55	1	0	0	0		
	CDH26.7	4	0	0	0	0	0	1	1	3	0	0	0	0		
(14) Wind	WSAvg	6.1	7.2	6.8	6.6	5.6	5.0	5.2	4.7	5.2	5.8	6.9	7.2	7.2		
(15) Precipitation	PrecAvg	644	51	41	40	35	52	67	67	71	59	52	53	57		
	PrecMax	848	88	77	98	74	101	158	282	156	142	93	132	114		
	PrecMin	487	1	7	8	4	15	1	3	29	17	26	7	18		
	PrecStd	97	24	15	20	16	23	33	50	35	30	16	26	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	8.2	9.9	14.9	19.9	23.0	25.9	26.8	22.3	17.4	12.2	9.1		
		MCWB	6.6	7.0	6.9	11.4	15.2	17.9	20.4	20.7	18.6	15.0	11.3	8.2		
	2%	DB	6.6	7.2	8.2	12.6	17.7	20.4	24.0	25.0	20.4	15.5	11.4	8.2		
		MCWB	5.6	6.3	6.5	10.1	13.9	16.7	19.4	20.3	17.3	13.7	10.4	7.5		
	5%	DB	5.7	6.2	7.1	11.1	16.1	19.2	22.6	23.3	19.2	14.5	10.5	7.4		
		MCWB	4.9	5.3	5.7	9.0	12.8	15.7	19.0	19.6	16.3	13.2	9.4	6.7		
	10%	DB	5.0	5.3	6.1	9.7	14.8	18.1	21.3	22.0	17.7	13.9	9.7	6.4		
		MCWB	4.3	4.5	4.8	7.7	11.9	15.1	18.1	19.3	15.3	12.7	8.7	5.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	7.5	8.0	11.9	15.6	18.6	22.1	22.2	19.3	15.4	11.7	8.5		
		MCDB	7.5	7.9	8.7	13.9	18.9	22.0	24.5	25.0	21.6	16.9	11.9	8.8		
	2%	WB	5.8	6.5	6.8	10.4	14.2	17.2	20.4	21.2	17.9	14.2	10.6	7.6		
		MCDB	6.4	7.0	7.9	12.2	16.9	19.8	23.2	23.7	20.1	15.0	11.2	8.1		
	5%	WB	5.0	5.4	5.9	9.2	13.2	16.3	19.2	20.2	16.7	13.6	9.6	6.8		
		MCDB	5.5	6.1	7.0	11.0	15.7	18.6	21.9	22.7	18.4	14.3	10.3	7.4		
	10%	WB	4.4	4.5	5.0	8.0	12.3	15.4	18.4	19.3	15.7	12.8	8.7	5.9		
		MCDB	4.9	5.2	5.9	9.3	14.5	17.6	20.8	21.6	17.2	13.8	9.5	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	3.1	3.9	4.5	5.2	5.4	5.3	5.1	4.2	3.5	3.0	2.9		
		MCDBR	2.9	3.4	5.3	6.3	7.2	6.9	7.1	6.7	6.3	4.0	3.2	3.2		
	5% WB	MCWBR	2.7	2.6	4.2	4.2	5.0	4.4	4.4	3.8	3.8	3.1	2.7	3.1		
		MCWBR	2.8	3.2	5.0	5.9	6.5	6.1	6.1	5.5	5.0	3.6	2.9	3.2		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.342	0.367	0.394	0.389	0.384	0.404	0.406	0.375	0.362	0.342	0.312		
		taud	2.319	2.332	2.296	2.301	2.383	2.421	2.379	2.385	2.448	2.416	2.356	2.296		
	Ebn at Noon		609	732	798	828	856	863	835	810	788	702	576	528		
		Edh at Noon	56	77	100	114	111	108	111	104	86	71	54	46		
(44) All-Sky Solar Radiation	RadAvg		0.47	1.08	2.40	4.18	5.36	5.73	5.31	4.29	3.05	1.54	0.61	0.32		
	RadStd		0.07	0.19	0.24	0.48	0.56	0.42	0.62	0.30	0.28	0.22	0.09	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (62 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-165	+63	N/A

Nomenclature: See separate page