

KOEbenhavns AP, Denmark

WMO: 061800

Lat: 55.614N

Lon: 12.645E

Elev: 5

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.9	-5.2	-10.9	1.5	-4.4	-9.0	1.7	-3.5	15.1	5.2	13.9	4.2	4.5	50	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	25.8	18.5	24.2	18.0	22.8	17.3	19.9	23.5	18.9	22.5	18.2	21.6	4.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.4	21.7	17.7	12.7	20.6	16.8	12.0	19.9	56.9	23.4	53.8	22.3	51.3	21.6	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.0	10.0	DB	-10.1	28.4	2.8	1.5	-12.1	29.5	-13.7	30.4	-15.3	31.3	-17.3	32.4	(4)
(5)			WB	-10.5	21.4	2.7	1.1	-12.4	22.2	-14.0	22.9	-15.5	23.5	-17.4	24.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	1.1	1.2	3.2	7.4	11.7	15.2	17.9	17.8	14.3	9.8	5.7	2.6		
	DBStd	6.76	3.36	3.31	3.16	3.10	3.01	2.60	2.73	2.49	2.38	2.89	3.00	3.56		
	HDD10.0	1238	277	246	211	89	16	0	0	0	1	39	131	229		
	HDD18.3	3453	535	479	469	328	205	100	42	42	122	264	379	487		
	CDD10.0	887	0	0	0	11	69	156	246	241	129	32	2	0		
	CDD18.3	60	0	0	0	0	1	6	29	24	1	0	0	0		
	CDH23.3	228	0	0	0	0	3	22	128	74	1	0	0	0		
	CDH26.7	19	0	0	0	0	0	2	13	3	0	0	0	0		
(14) Wind	WSAvg	5.3	6.0	6.0	5.6	4.9	4.7	4.8	4.4	4.6	5.1	5.6	5.7	5.9		
(15) Precipitation	PrecAvg	623	47	33	32	31	48	63	61	78	59	65	53	53		
	PrecMax	835	86	77	63	74	83	136	175	184	154	130	144	96		
	PrecMin	414	1	4	8	8	10	3	3	18	13	25	6	20		
	PrecStd	98	24	14	17	16	19	29	41	49	37	29	27	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	9.8	13.3	19.1	23.2	25.6	28.2	27.0	22.9	17.0	13.2	10.4		
		MCWB	7.8	7.6	9.0	13.1	16.2	18.3	19.4	18.7	17.7	14.4	12.0	9.5		
	2%	DB	7.6	8.1	10.7	16.3	20.9	23.4	26.3	25.2	20.8	15.6	11.8	9.2		
		MCWB	6.6	6.9	7.2	11.0	14.8	17.0	18.7	18.5	16.5	13.7	10.9	8.3		
	5%	DB	6.6	6.9	8.9	14.2	19.0	21.5	24.7	23.9	19.2	14.6	10.8	8.2		
		MCWB	5.6	5.7	6.5	9.8	13.6	16.0	18.3	18.0	15.5	12.9	9.8	7.3		
	10%	DB	5.6	5.8	7.7	12.5	17.1	19.9	23.1	22.2	18.1	13.7	9.8	7.2		
		MCWB	4.8	4.7	5.8	8.9	12.7	15.1	17.6	17.4	14.9	12.2	8.8	6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	8.3	9.7	14.1	17.4	19.7	21.2	21.0	18.6	15.3	12.4	9.8		
		MCDB	8.8	9.0	12.5	18.0	22.1	23.7	25.6	24.5	21.5	16.2	13.0	10.1		
	2%	WB	6.8	7.0	7.9	11.8	15.7	18.0	20.1	19.8	17.2	14.1	10.9	8.6		
		MCDB	7.4	7.7	9.5	15.3	19.3	21.8	24.0	23.0	19.6	15.3	11.6	9.1		
	5%	WB	5.8	5.8	6.9	10.5	14.4	16.9	19.2	18.8	16.3	13.2	9.9	7.4		
		MCDB	6.4	6.5	8.4	13.4	17.8	20.4	23.0	22.0	18.4	14.3	10.6	8.0		
	10%	WB	4.8	4.7	5.9	9.3	13.2	15.8	18.4	18.1	15.5	12.5	8.9	6.5		
		MCDB	5.4	5.5	7.4	11.8	16.2	19.0	22.1	21.2	17.5	13.5	9.6	7.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	4.1	5.7	7.4	7.8	7.5	7.6	7.2	6.1	4.8	3.7	3.6		
		MCDBR	4.0	4.9	7.7	9.9	10.4	9.4	9.7	8.8	7.2	5.2	3.8	3.9		
	5% WB	MCWBR	3.8	3.9	5.2	5.8	5.6	4.9	4.2	3.9	4.1	3.9	3.5	3.9		
		MCWBR	4.0	4.8	7.2	8.8	9.0	8.6	8.5	7.7	6.5	4.8	3.7	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.337	0.360	0.393	0.389	0.383	0.405	0.405	0.374	0.357	0.339	0.306		
		taud	2.287	2.306	2.300	2.275	2.343	2.384	2.343	2.351	2.419	2.398	2.331	2.260		
	Ebn at Noon		593	725	800	826	853	862	832	806	782	696	559	507		
		Edh at Noon	55	77	98	116	115	112	114	107	87	71	53	45		
(44) All-Sky Solar Radiation	RadAvg		0.45	1.05	2.43	4.18	5.38	5.72	5.31	4.28	3.03	1.49	0.57	0.30		
	RadStd		0.09	0.17	0.27	0.51	0.54	0.44	0.65	0.32	0.30	0.22	0.10	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	-164	-241	+87	N/A
(47) Regional (62 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-169	+62	N/A

Nomenclature: See separate page