

JAEGBERSBORG, Denmark

WMO: 061810

Lat: 55.7664N

Lon: 12.5264E

Elev: 138

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.1	22.2	12.3	10.3	23.7	15.8	12.3	25.6	36.6	39.6	32.0	40.7	5.8	30	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	79.2	65.1	76.5	64.0	73.6	62.8	67.8	74.8	66.0	72.7	64.5	70.8	7.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	93.6	70.9	63.5	88.1	68.9	61.9	83.1	67.5	32.2	75.3	30.7	72.7	29.6	70.9	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	19.5	16.6	14.8	84.1	4.8	2.9	11.4	86.2	8.6	87.8	5.9	89.4	2.4	91.5		
			13.8	70.8	4.7	2.1	10.4	72.3	7.7	73.5	5.0	74.7	1.6	76.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.6	34.0	34.2	38.3	46.4	54.4	59.7	64.6	63.7	57.6	49.7	42.8	37.4
	DBStd	12.17	6.39	6.21	6.39	5.75	5.62	4.75	4.76	4.30	4.37	5.44	5.33	6.42
	HDD50	2147	495	443	365	138	20	1	0	0	2	72	221	390
	HDD65	6080	960	863	828	558	332	170	69	77	226	475	667	855
	CDD50	1651	0	0	1	29	156	292	451	426	229	63	4	0
	CDD65	109	0	0	0	0	2	12	55	37	3	0	0	0
	CDH74	539	0	0	0	2	17	83	305	127	5	0	0	0
	CDH80	62	0	0	0	0	1	11	41	9	0	0	0	0
Wind	WSAvg	7.6	8.9	9.0	8.7	7.7	7.4	7.6	6.5	6.1	6.3	7.1	7.9	8.3
Precipitation	PrecAvg	24.5	1.9	1.3	1.5	1.5	1.7	2.1	2.6	2.5	2.6	2.2	2.3	2.2
	PrecMax	33.7	4.0	2.9	4.2	3.8	3.7	5.9	5.9	6.1	7.4	4.1	4.5	5.6
	PrecMin	15.2	0.0	0.1	0.2	0.0	0.2	0.0	0.1	0.4	0.3	0.4	0.4	0.4
	PrecStd	4.0	1.0	0.6	0.9	0.9	0.9	1.2	1.3	1.3	1.6	1.1	1.0	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	50.7	58.2	69.2	76.4	80.6	84.4	81.1	74.6	64.3	55.7	51.6
		MCWB	47.5	46.6	48.5	56.3	62.1	63.3	68.1	66.5	63.6	58.4	53.5	49.7
	2%	DB	46.6	47.1	53.6	64.0	72.3	76.2	80.3	77.8	70.5	61.0	53.4	49.5
		MCWB	44.8	44.3	46.5	52.5	58.9	62.5	65.0	65.4	61.7	56.6	51.5	47.7
	5%	DB	44.7	44.9	49.6	59.9	68.8	72.4	77.5	74.5	67.2	58.8	51.5	47.4
		MCWB	42.9	42.5	44.4	50.1	57.3	60.7	64.6	64.1	59.8	55.5	49.5	45.7
	10%	DB	43.0	42.8	46.9	56.3	65.2	69.0	74.4	71.5	64.8	56.9	49.7	45.6
		MCWB	41.2	40.7	43.2	48.3	55.4	58.9	63.5	62.7	58.6	54.1	47.8	44.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	47.8	50.3	58.7	64.4	68.4	71.2	69.6	65.2	59.8	54.4	50.2
		MCDB	49.3	49.4	55.6	68.2	73.1	76.6	80.2	76.9	71.9	62.3	55.3	50.9
	2%	WB	45.2	44.9	47.4	53.5	61.5	64.3	68.3	67.3	62.7	57.5	51.7	48.1
		MCDB	46.4	46.6	51.5	61.4	69.4	71.7	75.9	73.6	68.4	59.8	52.9	49.3
	5%	WB	43.2	42.9	45.5	51.3	58.9	62.2	66.5	65.6	61.0	56.0	49.8	45.9
		MCDB	44.5	44.6	48.7	58.3	65.5	69.9	73.8	71.5	65.7	58.2	51.2	47.0
	10%	WB	41.3	40.7	43.5	49.1	56.5	60.3	64.8	64.3	59.4	54.5	48.1	44.2
		MCDB	42.7	42.5	46.5	55.1	63.4	67.4	71.8	69.7	63.7	56.6	49.4	45.5
Mean Daily Temperature Range	5% DB	MDBR	6.3	7.0	10.5	14.0	15.3	14.2	14.2	13.1	11.7	9.0	6.5	6.1
		MCDBR	6.9	9.3	15.0	19.7	21.0	19.3	19.2	16.2	14.7	10.6	7.3	6.9
		MCWBR	6.6	7.1	9.5	10.9	10.9	9.0	7.9	7.4	7.6	7.3	6.4	6.8
	5% WB	MCDBR	7.0	8.7	13.5	17.8	18.0	17.0	16.4	14.0	13.8	10.0	6.9	6.9
		MCWBR	7.0	7.2	9.6	10.4	10.6	9.1	8.1	7.5	8.0	7.5	6.6	7.0
Clear-Sky Solar Irradiance	taub	0.312	0.334	0.357	0.390	0.387	0.381	0.402	0.403	0.372	0.354	0.335	0.302	
	taud	2.287	2.312	2.312	2.279	2.347	2.388	2.346	2.354	2.421	2.404	2.329	2.258	
	Ebn at Noon	188	231	255	262	271	274	265	256	249	221	178	161	
	Edh at Noon	17	24	31	36	36	35	36	34	28	22	17	14	
All-Sky Solar Radiation	RadAvg	140	331	767	1313	1695	1798	1669	1343	950	464	177	94	
	RadStd	27	52	84	163	168	142	202	102	96	68	31	10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-293	+108	N/A

Nomenclature: See separate page