

JAEGBERSBORG, Denmark

WMO: 061810

Lat: 55.7664N

Lon: 12.5264E

Elev: 42

StdP: 100.82

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.2	-5.4	-11.0	1.5	-4.6	-9.0	1.8	-3.6	16.4	4.2	14.3	4.8	2.6	30	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	26.2	18.4	24.7	17.8	23.1	17.1	19.9	23.8	18.9	22.6	18.0	21.6	3.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.4	21.6	17.5	12.6	20.5	16.6	11.9	19.7	57.0	24.0	53.6	22.6	51.0	21.6	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	8.7	7.4	DB	-9.5	28.9	2.7	1.6	-11.4	30.1	-13.0	31.0	-14.5	31.9	-16.4	33.1	(4)
(5)			WB	-10.1	21.6	2.6	1.1	-12.0	22.4	-13.5	23.1	-15.0	23.7	-16.9	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	1.1	1.2	3.5	8.0	12.4	15.4	18.1	17.6	14.2	9.8	6.0	3.0		
	DBStd	6.76	3.55	3.45	3.55	3.20	3.12	2.64	2.64	2.39	2.43	3.02	2.96	3.57		
	HDD10.0	1193	275	246	203	77	11	1	0	0	1	40	123	217		
	HDD18.3	3378	533	479	460	310	184	94	38	43	126	264	371	475		
	CDD10.0	917	0	0	1	16	87	162	251	237	127	35	2	0		
	CDD18.3	61	0	0	0	0	1	7	31	21	2	0	0	0		
	CDH23.3	299	0	0	0	1	9	46	169	71	3	0	0	0		
	CDH26.7	34	0	0	0	0	1	6	23	5	0	0	0	0		
(14) Wind	WSAvg	3.4	4.0	4.0	3.9	3.4	3.3	3.4	2.9	2.7	2.8	3.2	3.5	3.7		
(15) Precipitation	PrecAvg	622	49	32	38	39	43	54	65	63	66	56	59	55		
	PrecMax	856	102	73	106	97	93	150	150	154	188	105	115	143		
	PrecMin	387	1	3	4	0	6	1	2	9	8	10	11	10		
	PrecStd	102	25	16	22	22	24	31	33	34	40	27	25	30		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	10.4	14.5	20.7	24.7	27.0	29.1	27.3	23.7	17.9	13.1	10.9		
		MCWB	8.6	8.1	9.2	13.5	16.7	17.4	20.0	19.2	17.5	14.7	11.9	9.8		
	2%	DB	8.1	8.4	12.0	17.8	22.4	24.5	26.8	25.4	21.4	16.1	11.9	9.7		
		MCWB	7.1	6.9	8.0	11.4	15.0	17.0	18.3	18.5	16.5	13.7	10.8	8.7		
	5%	DB	7.1	7.2	9.8	15.5	20.4	22.4	25.3	23.6	19.6	14.9	10.8	8.5		
		MCWB	6.1	5.8	6.9	10.1	14.1	16.0	18.1	17.9	15.4	13.1	9.7	7.6		
	10%	DB	6.1	6.0	8.3	13.5	18.5	20.6	23.6	22.0	18.2	13.8	9.8	7.6		
		MCWB	5.1	4.8	6.2	9.1	13.0	14.9	17.5	17.0	14.8	12.3	8.8	6.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	8.8	10.2	14.9	18.0	20.2	21.8	20.9	18.4	15.4	12.5	10.1		
		MCDB	9.6	9.6	13.1	20.1	22.8	24.8	26.8	25.0	22.2	16.8	13.0	10.5		
	2%	WB	7.3	7.2	8.5	12.0	16.4	18.0	20.2	19.6	17.0	14.2	10.9	8.9		
		MCDB	8.0	8.1	10.8	16.3	20.8	22.0	24.4	23.1	20.2	15.4	11.6	9.6		
	5%	WB	6.2	6.0	7.5	10.7	14.9	16.8	19.2	18.7	16.1	13.3	9.9	7.7		
		MCDB	6.9	7.0	9.3	14.6	18.6	21.1	23.2	21.9	18.7	14.6	10.6	8.3		
	10%	WB	5.1	4.8	6.4	9.5	13.6	15.7	18.2	17.9	15.2	12.5	9.0	6.8		
		MCDB	5.9	5.8	8.0	12.8	17.5	19.7	22.1	20.9	17.6	13.7	9.7	7.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.9	5.8	7.8	8.5	7.9	7.9	7.3	6.5	5.0	3.6	3.4		
		MCDBR	3.8	5.2	8.3	11.0	11.7	10.7	10.7	9.0	8.1	5.9	4.1	3.8		
	5% WB	MCWBR	3.7	3.9	5.3	6.1	6.0	5.0	4.4	4.1	4.2	4.1	3.6	3.8		
		MCWBR	3.9	4.8	7.5	9.9	10.0	9.4	9.1	7.8	7.7	5.6	3.8	3.9		
(40) Clear-Sky Solar Irradiance	taub		0.312	0.334	0.357	0.390	0.387	0.381	0.402	0.403	0.372	0.354	0.335	0.302		
	taud		2.287	2.312	2.312	2.279	2.347	2.388	2.346	2.354	2.421	2.404	2.329	2.258		
	Ebn at Noon		593	728	804	827	855	864	834	808	784	698	560	506		
	Edh at Noon		54	77	97	115	114	111	114	106	87	70	53	44		
(44) All-Sky Solar Radiation	RadAvg		0.44	1.04	2.42	4.14	5.34	5.67	5.26	4.23	2.99	1.46	0.56	0.30		
	RadStd		0.08	0.17	0.27	0.51	0.53	0.45	0.64	0.32	0.30	0.21	0.10	0.03		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (62 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-163	+60	N/A

Nomenclature: See separate page