

DROGDEN FYR, Denmark

WMO: 061830

Lat: 55.5365N

Lon: 12.7115E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.2	-3.9	-9.3	1.7	-3.7	-7.8	1.9	-2.7	19.2	3.5	18.0	2.3	9.5	40	0.833

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	22.8	18.7	21.7	18.1	20.6	17.4	19.6	21.8	18.8	20.8	18.0	19.9	6.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.5	20.9	17.9	12.8	20.1	17.2	12.3	19.3	55.9	21.8	53.3	20.9	50.8	20.0	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	15.2	13.9	-5.5	25.2	1.8	1.5	-6.7	26.3	-7.8	27.2	-8.8	28.1	-10.1	29.2		
(5)			-6.7	20.3	1.5	1.0	-7.8	21.0	-8.7	21.6	-9.5	22.2	-10.6	22.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.6	1.5	3.1	7.1	11.5	15.1	17.6	17.8	14.8	10.6	6.8	4.1	(6)
(7)		DBStd	6.37	3.06	2.79	2.83	2.44	2.73	2.26	2.25	1.91	1.95	2.52	2.60	2.99	(7)
(8)		HDD10.0	1126	261	238	213	93	14	0	0	0	0	24	98	184	(8)
(9)		HDD18.3	3323	519	472	472	337	212	100	43	32	107	241	346	443	(9)
(10)		CDD10.0	885	0	0	0	6	61	153	234	243	144	42	2	0	(10)
(11)		CDD18.3	41	0	0	0	0	1	3	19	17	1	0	0	0	(11)
(12)		CDH23.3	19	0	0	0	0	0	1	12	7	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.6	9.0	8.2	7.5	6.4	6.1	6.7	6.3	6.7	7.7	8.5	8.9	9.2	(14)
(15)	Precipitation	PrecAvg	623	47	33	32	31	48	63	61	78	59	65	53	53	(15)
(16)		PrecMax	835	86	77	63	74	83	136	175	184	154	130	144	96	(16)
(17)		PrecMin	414	1	4	8	8	10	3	3	18	13	25	6	20	(17)
(18)		PrecStd	98	24	14	17	16	19	29	41	49	37	29	27	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	8.0	10.5	15.2	20.6	22.4	24.7	24.2	20.8	16.3	12.7	10.0	(19)
(20)			MCWB	7.7	6.4	8.0	10.6	15.4	17.3	19.3	19.4	17.6	14.3	11.8	9.0	(20)
(21)		2%	DB	7.5	6.7	8.6	13.3	18.2	20.7	23.0	22.8	19.1	15.2	11.6	9.1	(21)
(22)			MCWB	6.4	5.6	6.5	9.3	13.8	16.6	19.0	18.6	16.5	13.4	10.5	8.2	(22)
(23)		5%	DB	6.6	5.9	7.3	11.7	16.6	19.2	21.9	21.6	18.2	14.5	10.8	8.4	(23)
(24)			MCWB	5.7	5.0	5.8	8.6	13.3	15.8	18.6	18.1	15.9	12.9	9.8	7.6	(24)
(25)		10%	DB	5.8	5.1	6.4	10.4	15.2	18.2	20.9	20.5	17.5	13.7	10.0	7.7	(25)
(26)			MCWB	5.0	4.4	5.3	7.9	12.4	15.2	17.8	17.4	15.3	12.3	9.0	6.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	6.7	8.5	11.2	16.5	19.0	20.9	20.6	18.4	14.7	12.2	9.4	(27)
(28)			MCDWB	8.9	7.0	9.9	13.2	19.5	20.4	23.4	23.2	19.9	15.8	12.6	9.7	(28)
(29)		2%	WB	6.8	5.8	7.0	9.9	15.0	17.4	19.9	19.3	17.2	13.7	10.9	8.4	(29)
(30)			MCDWB	7.4	6.3	8.0	11.9	17.0	19.9	22.2	21.5	18.5	14.7	11.4	8.9	(30)
(31)		5%	WB	6.0	5.0	6.2	9.0	14.0	16.5	19.1	18.4	16.4	13.1	10.0	7.6	(31)
(32)			MCDWB	6.6	5.5	7.1	10.9	15.9	18.7	21.4	20.3	17.8	14.2	10.7	8.1	(32)
(33)		10%	WB	5.2	4.2	5.5	8.1	13.0	15.7	18.4	17.8	15.7	12.5	9.2	6.8	(33)
(34)			MCDWB	5.9	4.9	6.4	9.8	14.9	17.7	20.5	19.5	17.2	13.6	9.9	7.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.4	2.3	3.0	3.8	4.0	3.6	3.5	3.2	2.8	2.4	2.2	2.3	(35)
(36)			MCDBR	2.7	3.0	4.1	5.5	5.9	5.0	5.0	4.4	3.4	2.7	2.2	2.4	(36)
(37)			MCWBR	2.8	2.3	2.8	3.3	3.5	3.0	2.9	2.7	2.5	2.4	2.4	2.6	(37)
(38)		5% WB	MCDBR	2.7	2.8	3.8	5.1	5.6	4.3	4.1	3.7	3.1	2.5	2.3	2.4	(38)
(39)			MCWBR	2.8	2.4	2.9	3.5	3.7	3.2	2.8	2.8	2.7	2.4	2.5	2.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.338	0.361	0.392	0.388	0.383	0.404	0.405	0.374	0.358	0.339	0.307	(40)	
(41)		taud	2.289	2.307	2.298	2.277	2.346	2.387	2.346	2.354	2.422	2.399	2.333	2.263	(41)	
(42)		Ebn at Noon	595	726	800	826	854	862	833	807	784	697	561	509	(42)	
(43)		Edh at Noon	55	78	98	116	114	111	114	107	87	71	54	45	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.45	1.06	2.44	4.20	5.40	5.75	5.34	4.30	3.04	1.50	0.57	0.30	(44)	
(45)		RadStd	0.09	0.17	0.27	0.51	0.54	0.44	0.65	0.31	0.29	0.22	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (63 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-169	+62		

Nomenclature: See separate page