

BORNHOLM AP, DenmarkWMO: **061900**Lat: **55.0678N**Lon: **14.7494E**Elev: **52**StdP: **14.67**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.0	23.9	13.9	11.2	24.5	17.0	13.0	26.0	36.5	37.0	33.1	38.3	10.1	100	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	77.4	66.6	75.1	65.9	72.0	64.6	69.4	74.2	67.5	72.2	65.9	70.6	11.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	102.5	71.5	66.0	96.0	70.2	64.3	90.3	68.5	33.5	74.9	32.0	72.6	30.7	70.6	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.5	27.9	25.2	DB	15.3	83.5	4.8	3.5	11.9	86.0	9.0	88.1	6.3	90.0	2.9	92.5	(4)
(5)			WB	14.5	71.8	4.5	2.1	11.3	73.3	8.7	74.6	6.1	75.7	2.9	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	34.6	34.1	36.8	43.9	51.8	58.6	63.8	64.4	58.4	50.4	43.4	37.9
	DBStd	11.93	5.56	5.27	4.87	5.68	5.81	4.55	4.62	4.31	4.33	5.14	5.13	5.71
	HDD50	2210	478	444	409	200	43	1	0	0	1	58	202	374
	HDD65	6208	943	864	874	633	411	201	79	63	202	451	648	839
	CDD50	1578	0	0	0	18	100	257	428	448	252	71	4	0
	CDD65	101	0	0	0	0	2	8	42	46	3	0	0	0
	CDH74	344	0	0	0	0	11	32	172	127	2	0	0	0
	CDH80	33	0	0	0	0	0	3	21	9	0	0	0	0
Wind	WSAvg	12.5	14.8	14.0	12.6	11.4	10.8	10.7	10.3	11.0	12.3	13.5	14.3	15.0
Precipitation	PrecAvg	21.3	1.7	1.1	1.1	1.1	1.3	1.8	1.9	2.2	2.4	2.0	2.1	1.7
	PrecMax	29.4	4.6	2.3	2.1	2.0	6.5	4.7	5.5	8.2	5.9	4.4	6.9	3.8
	PrecMin	12.6	0.1	0.0	0.2	0.3	0.3	0.0	0.0	0.0	0.6	0.0	0.7	0.7
	PrecStd	4.7	1.1	0.6	0.7	0.6	1.3	1.2	1.3	1.9	1.4	1.2	1.4	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.6	44.6	53.6	68.1	75.0	78.4	83.0	80.7	72.7	62.6	54.1	48.7
		MCWB	45.7	43.0	46.7	55.7	62.6	65.6	67.9	67.7	64.5	58.8	52.2	47.5
	2%	DB	44.6	42.9	47.3	61.0	68.8	73.2	78.6	77.2	69.6	60.4	52.5	47.9
		MCWB	44.0	41.9	43.2	51.5	58.8	63.3	67.2	66.6	63.6	57.6	50.9	46.8
	5%	DB	43.0	41.4	44.5	56.8	64.6	69.6	75.3	74.9	66.6	58.8	51.5	46.4
		MCWB	42.3	40.5	41.9	48.9	56.2	61.7	66.2	66.4	61.8	56.5	50.0	45.6
	10%	DB	41.4	40.8	42.7	52.5	60.9	66.3	72.6	71.9	64.6	57.2	50.0	44.9
		MCWB	40.7	39.9	41.0	46.5	54.6	60.3	65.2	65.3	60.5	55.0	48.9	44.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	43.5	47.3	57.0	63.9	68.1	71.9	71.7	67.4	59.9	53.5	48.2
		MCDB	46.3	43.8	52.2	65.9	72.2	74.0	77.6	76.4	70.3	61.2	54.5	48.4
	2%	WB	43.8	42.2	43.9	52.5	60.4	65.1	69.8	69.5	64.6	58.3	51.8	46.7
		MCDB	44.1	42.4	45.6	59.4	66.8	70.6	75.0	73.8	67.8	59.6	52.7	47.0
	5%	WB	42.5	40.9	42.3	49.8	57.8	63.1	67.8	67.8	62.9	57.0	50.3	45.5
		MCDB	42.8	41.3	43.4	54.9	62.8	67.6	73.0	72.0	65.8	58.5	51.0	45.9
	10%	WB	40.9	39.6	41.1	47.5	55.6	61.2	66.0	66.3	61.4	55.5	48.9	44.1
		MCDB	41.3	40.2	42.0	51.5	59.9	65.2	71.1	70.4	64.0	56.9	49.5	44.7
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.7	7.8	11.3	12.1	11.2	11.1	10.8	9.1	7.4	5.9	5.6
		MCDBR	4.4	5.6	10.9	17.9	18.3	17.7	16.8	15.5	11.5	8.2	5.0	4.9
		MCWBR	4.8	5.0	7.9	10.4	10.7	9.6	8.9	8.2	7.3	7.0	5.0	5.3
	5% WB	MCDBR	4.4	5.1	8.9	15.2	15.9	14.4	14.7	13.0	10.6	7.5	5.0	4.9
		MCWBR	4.8	4.9	7.2	9.8	10.5	9.2	8.8	8.3	7.6	7.0	5.3	5.4
Clear-Sky Solar Irradiance	taub	0.321	0.344	0.367	0.401	0.398	0.391	0.414	0.415	0.381	0.365	0.346	0.315	
	taud	2.305	2.323	2.302	2.278	2.356	2.407	2.358	2.357	2.425	2.391	2.329	2.296	
	Ebn at Noon	191	230	253	260	268	272	262	253	247	220	179	165	
	Edh at Noon	18	25	31	37	36	35	36	34	28	23	17	15	
All-Sky Solar Radiation	RadAvg	134	333	772	1368	1793	1921	1748	1412	1000	482	187	95	
	RadStd	23	59	68	138	180	120	192	106	98	76	30	12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-274	+106	N/A

Nomenclature: See separate page