

BORNHOLM AP, Denmark

WMO: 061900

Lat: 55.0678N

Lon: 14.7494E

Elev: 16

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-4.5	-10.1	1.6	-4.2	-8.3	1.9	-3.3	16.3	2.8	14.8	3.5	4.5	100	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	25.2	19.2	23.9	18.8	22.2	18.1	20.8	23.5	19.7	22.3	18.8	21.4	4.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.6	22.0	18.9	13.7	21.2	17.9	12.9	20.3	60.1	23.8	56.5	22.6	53.6	21.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.5	11.3	-9.3	28.6	2.7	1.9	-11.2	30.0	-12.8	31.1	-14.3	32.2	-16.2	33.6		
(5)			-9.7	22.1	2.5	1.2	-11.5	23.0	-13.0	23.6	-14.4	24.3	-16.2	25.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	1.4	1.2	2.7	6.6	11.0	14.8	17.7	18.0	14.6	10.2	6.3	3.3		
	DBStd	6.63	3.09	2.93	2.71	3.16	3.23	2.53	2.57	2.40	2.40	2.85	2.85	3.17		
	HDD10.0	1228	266	247	227	111	24	1	0	0	1	32	112	208		
	HDD18.3	3449	524	480	486	352	228	112	44	35	112	251	360	466		
	CDD10.0	877	0	0	0	10	56	143	238	249	140	39	2	0		
	CDD18.3	56	0	0	0	0	1	4	23	26	2	0	0	0		
	CDH23.3	191	0	0	0	0	6	18	96	71	1	0	0	0		
	CDH26.7	18	0	0	0	0	0	2	12	5	0	0	0	0		
(14) Wind	WSAvg	5.6	6.6	6.3	5.6	5.1	4.8	4.8	4.6	4.9	5.5	6.0	6.4	6.7		
(15) Precipitation	PrecAvg	542	44	28	29	29	34	46	49	56	62	50	53	43		
	PrecMax	748	118	59	54	51	164	120	140	209	150	112	176	96		
	PrecMin	319	3	0	4	7	8	0	0	0	15	0	19	17		
	PrecStd	120	29	15	17	14	34	31	34	47	35	31	36	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.0	12.0	20.0	23.9	25.8	28.3	27.1	22.6	17.0	12.3	9.3		
		MCWB	7.6	6.1	8.2	13.2	17.0	18.7	19.9	19.8	18.1	14.9	11.2	8.6		
	2%	DB	7.0	6.0	8.5	16.1	20.5	22.9	25.9	25.1	20.9	15.8	11.4	8.8		
		MCWB	6.6	5.5	6.2	10.8	14.9	17.4	19.6	19.2	17.5	14.2	10.5	8.2		
	5%	DB	6.1	5.2	6.9	13.8	18.1	20.9	24.1	23.8	19.2	14.9	10.8	8.0		
		MCWB	5.7	4.7	5.5	9.4	13.5	16.5	19.0	19.1	16.5	13.6	10.0	7.5		
	10%	DB	5.2	4.9	6.0	11.4	16.1	19.0	22.5	22.2	18.1	14.0	10.0	7.2		
		MCWB	4.8	4.4	5.0	8.1	12.5	15.7	18.5	18.5	15.8	12.8	9.4	6.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	6.4	8.5	13.9	17.7	20.0	22.2	22.0	19.6	15.5	12.0	9.0		
		MCDB	8.0	6.5	11.2	18.8	22.3	23.3	25.3	24.6	21.3	16.2	12.5	9.1		
	2%	WB	6.6	5.6	6.6	11.4	15.8	18.4	21.0	20.9	18.1	14.6	11.0	8.1		
		MCDB	6.7	5.8	7.6	15.2	19.3	21.5	23.9	23.2	19.9	15.3	11.5	8.3		
	5%	WB	5.8	5.0	5.7	9.9	14.3	17.3	19.9	19.9	17.2	13.9	10.1	7.5		
		MCDB	6.0	5.2	6.3	12.7	17.1	19.8	22.8	22.2	18.8	14.7	10.5	7.7		
	10%	WB	4.9	4.2	5.0	8.6	13.1	16.2	18.9	19.0	16.3	13.1	9.4	6.7		
		MCDB	5.1	4.6	5.6	10.8	15.5	18.4	21.7	21.3	17.8	13.8	9.7	7.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.1	3.2	4.4	6.3	6.7	6.2	6.2	6.0	5.1	4.1	3.3	3.1		
		MCDBR	2.5	3.1	6.1	9.9	10.1	9.8	9.3	8.6	6.4	4.6	2.8	2.7		
	5% WB	MCWBR	2.6	2.8	4.4	5.8	5.9	5.3	4.9	4.6	4.1	3.9	2.8	2.9		
		MCWBR	2.4	2.9	5.0	8.5	8.8	8.0	8.2	7.2	5.9	4.2	2.8	2.7		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.344	0.367	0.401	0.398	0.391	0.414	0.415	0.381	0.365	0.346	0.315		
		taud	2.305	2.323	2.302	2.278	2.356	2.407	2.358	2.357	2.425	2.391	2.329	2.296		
	Ebn at Noon		602	726	797	820	846	857	826	799	779	694	563	519		
		Edh at Noon	56	78	99	116	114	109	113	107	88	73	55	46		
(44) All-Sky Solar Radiation	RadAvg		0.42	1.05	2.43	4.31	5.65	6.05	5.51	4.45	3.15	1.52	0.59	0.30		
	RadStd		0.07	0.18	0.21	0.43	0.57	0.38	0.60	0.34	0.31	0.24	0.10	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-152	+59	N/A

Nomenclature: See separate page