

CHRISTIANSO FYR, Denmark

WMO: 061910

Lat: 55.3206N

Lon: 15.1869E

Elev: 15

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.8	-4.0	-8.2	1.9	-5.2	-6.5	2.2	-3.1	23.7	5.0	22.2	4.5	8.6	130	0.861

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	23.1	20.6	21.9	19.8	20.6	18.8	21.0	22.8	20.1	21.6	19.0	20.4	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.0	22.3	19.4	14.2	21.3	18.4	13.3	20.0	60.8	22.8	57.5	21.6	53.9	20.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	19.3	17.3	DB	-4.8	25.2	3.2	2.1	-7.2	26.7	-9.0	27.9	-10.8	29.0	-13.2	30.5	(4)
(5)			WB	-5.3	22.1	2.9	1.3	-7.4	23.0	-9.1	23.8	-10.8	24.5	-12.9	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	2.1	1.7	2.9	5.0	9.5	13.9	16.9	17.7	14.0	10.2	6.2	3.6	(6)	
	DBStd	6.14	2.94	3.13	2.78	2.21	2.37	2.42	2.41	2.36	2.10	2.57	2.31	2.36	(7)	
	HDD10.0	1229	245	231	219	152	39	1	0	0	1	29	114	198	(8)	
	HDD18.3	3558	503	464	478	402	276	133	58	41	132	252	363	456	(9)	
	CDD10.0	750	0	0	0	0	22	119	214	238	119	36	1	0	(10)	
	CDD18.3	37	0	0	0	0	0	1	14	21	1	0	0	0	(11)	
	CDH23.3	24	0	0	0	0	0	2	12	11	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.4	10.4	10.4	8.9	7.3	6.3	6.2	6.8	6.8	8.6	8.7	9.8	10.5	(14)	
(15) Precipitation	PrecAvg	593	44	39	38	28	39	44	48	65	65	64	63	55	(15)	
	PrecMax	772	94	79	80	56	106	107	133	212	153	159	164	130	(16)	
	PrecMin	445	3	9	6	2	7	0	1	12	21	16	27	23	(17)	
	PrecStd	88	23	15	20	15	24	27	29	47	32	36	32	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	9.5	9.9	11.9	17.8	21.7	24.6	24.9	22.0	16.1	12.6	9.3	(19)	
		MCWB	7.3	8.4	8.1	9.9	14.8	18.9	21.7	21.5	20.8	15.5	11.9	9.0	(20)	
	2%	DB	6.9	7.4	7.7	10.0	15.4	19.5	23.1	23.4	18.8	15.0	10.6	8.2	(21)	
		MCWB	6.3	6.5	6.9	8.6	13.7	17.4	20.3	20.8	17.1	14.4	9.8	7.7	(22)	
	5%	DB	6.1	6.2	6.7	8.8	14.1	18.3	21.6	22.4	17.4	14.2	9.8	7.4	(23)	
		MCWB	5.6	5.7	6.0	7.9	12.7	16.5	19.5	20.2	16.1	13.6	9.3	6.9	(24)	
	10%	DB	5.5	5.5	5.9	7.9	13.0	17.1	20.2	21.2	16.6	13.6	8.9	6.7	(25)	
		MCWB	5.1	5.0	5.3	7.1	11.7	15.6	18.4	19.4	15.3	12.9	8.4	6.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	8.6	8.4	10.2	15.2	19.3	22.2	22.1	20.9	15.7	12.0	9.0	(27)	
		MCDB	7.8	9.5	9.3	11.4	17.3	20.9	24.3	23.7	22.0	15.9	12.5	9.1	(28)	
	2%	WB	6.4	6.6	7.1	9.0	13.9	17.7	20.8	21.3	17.4	14.5	10.1	7.9	(29)	
		MCDB	6.7	7.2	7.5	9.7	15.3	19.0	22.5	23.0	18.2	14.8	10.4	8.2	(30)	
	5%	WB	5.7	5.7	6.2	8.0	12.9	16.7	19.7	20.5	16.4	13.8	9.3	7.0	(31)	
		MCDB	6.0	6.2	6.6	8.7	13.9	18.0	21.1	22.1	17.1	14.1	9.6	7.3	(32)	
	10%	WB	5.1	5.1	5.3	7.2	11.9	15.8	18.7	19.6	15.6	13.0	8.5	6.2	(33)	
		MCDB	5.4	5.4	5.8	7.8	12.8	16.9	19.9	21.0	16.4	13.5	8.8	6.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.2	2.2	2.5	2.8	3.3	3.3	3.1	3.0	2.4	2.3	2.2	2.3	(35)	
		MCDBR	2.3	2.8	3.3	3.9	5.2	4.8	4.7	4.0	3.3	3.0	3.0	2.8	(36)	
	5% WB	MCWBR	2.3	2.5	2.8	3.0	3.9	3.5	3.2	2.8	2.6	2.7	3.0	2.8	(37)	
		MCWBR	2.2	2.7	3.3	3.8	5.0	4.4	4.3	3.8	3.1	2.5	2.8	2.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.342	0.364	0.396	0.393	0.386	0.409	0.411	0.378	0.363	0.344	0.313	(40)	
		taud	2.309	2.330	2.320	2.294	2.375	2.426	2.378	2.373	2.437	2.394	2.325	2.291	(41)	
	Edn at Noon		600	726	800	824	850	861	830	802	781	694	559	513	(42)	
		Edh at Noon	55	77	97	114	112	107	111	105	87	72	55	45	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.41	1.04	2.45	4.34	5.69	6.12	5.57	4.48	3.16	1.50	0.58	0.29	(44)	
	RadStd		0.08	0.19	0.23	0.42	0.55	0.37	0.60	0.33	0.31	0.24	0.10	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-154	+60	N/A

Nomenclature: See separate page