

NEXO VEST, Denmark

WMO: 061970

Lat: 55.0558N

Lon: 15.0953E

Elev: 25

StdP: 101.03

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	-4.2	-10.0	1.6	-4.3	-8.3	1.9	-3.3	16.5	4.1	15.4	4.1	5.1	120	0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	24.5	19.2	22.8	18.3	21.5	17.6	20.4	23.2	19.2	21.6	18.3	20.5	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.1	21.8	18.2	13.2	20.6	17.3	12.4	19.5	58.8	23.3	54.7	21.6	51.8	20.5	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.0	11.5	10.4	-7.4	28.0	2.3	1.9	-9.0	29.3	-10.4	30.4	-11.7	31.5	-13.4	32.9		
			-8.1	21.7	2.3	1.5	-9.7	22.7	-11.1	23.6	-12.4	24.4	-14.1	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	1.1	1.2	3.1	6.4	10.7	14.2	17.4	14.3	9.8	6.3	3.6		
		DBStd	6.35	3.00	2.83	2.84	2.81	2.93	2.41	2.40	2.25	2.30	2.59	2.63		
		HDD10.0	1220	276	246	213	112	28	1	0	1	34	112	197		
		HDD18.3	3499	534	479	472	357	238	126	48	122	263	360	455		
		CDD10.0	801	0	0	0	5	48	127	228	231	131	29	2		
		CDD18.3	38	0	0	0	0	0	2	19	16	1	0	0		
		CDH23.3	108	0	0	0	0	0	10	59	39	1	0	0		
		CDH26.7	8	0	0	0	0	0	1	3	4	0	0	0		
(14)	Wind	WSAvg	5.1	6.1	5.8	5.5	4.7	4.3	4.1	3.9	4.3	5.0	5.4	5.6	6.1	
(15)	Precipitation	PrecAvg	563	41	30	36	41	40	36	53	56	61	54	67	56	
(16)		PrecMax	707	83	61	78	111	80	90	97	150	102	146	120	114	
(17)		PrecMin	450	10	11	8	12	10	13	8	7	21	18	16	15	
(18)		PrecStd	77	21	14	19	24	21	21	31	40	23	36	33	30	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	7.6	8.6	12.3	16.9	20.5	24.8	27.0	26.8	22.3	16.7	12.7	9.3		
(20)		0.4% MCWB	6.9	6.8	9.0	11.3	15.4	19.5	20.1	19.9	17.9	14.3	11.5	8.5		
(21)		2% DB	6.7	6.7	9.4	14.3	18.5	21.4	24.9	24.1	20.1	15.2	11.6	8.5		
(22)		2% MCWB	6.0	5.4	6.8	10.2	14.7	17.0	19.2	19.2	16.7	13.7	10.6	7.7		
(23)		5% DB	5.8	5.8	7.9	12.2	17.0	20.0	23.4	22.4	18.7	14.3	10.6	7.8		
(24)		5% MCWB	5.0	4.8	6.0	8.9	13.6	16.1	18.5	18.2	15.7	12.9	9.8	7.1		
(25)		10% DB	5.1	5.0	6.7	10.6	15.6	18.8	21.9	21.3	17.8	13.5	9.8	7.1		
(26)		10% MCWB	4.4	4.2	5.3	8.1	12.7	15.3	17.9	17.4	15.3	12.1	8.8	6.3		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	7.1	6.9	9.1	12.4	16.7	20.2	22.0	21.7	19.0	15.1	12.1	8.9		
(28)		0.4% MCDB	7.4	7.7	11.0	15.2	19.3	24.0	24.7	24.8	20.7	16.1	12.6	9.1		
(29)		2% WB	6.1	5.7	7.4	10.7	15.4	18.2	20.7	20.2	17.3	14.1	10.9	8.1		
(30)		2% MCDB	6.5	6.5	8.7	13.3	17.7	20.3	23.5	22.5	18.8	14.9	11.3	8.3		
(31)		5% WB	5.2	5.0	6.3	9.4	14.2	16.9	19.6	19.0	16.6	13.1	9.9	7.3		
(32)		5% MCDB	5.6	5.8	7.4	11.7	16.4	19.0	22.2	21.4	18.1	14.1	10.6	7.7		
(33)		10% WB	4.5	4.2	5.5	8.3	13.0	15.9	18.5	18.1	15.9	12.4	9.0	6.4		
(34)		10% MCDB	5.1	4.9	6.5	10.3	15.0	18.0	20.9	20.5	17.4	13.3	9.7	6.9		
(35)	Mean Daily Temperature Range	MDBR	2.9	3.0	4.1	5.6	6.6	7.0	6.9	6.2	4.7	3.8	3.1	2.9		
(36)		5% DB MCDBR	3.0	4.0	6.1	8.3	8.6	8.6	8.7	7.6	5.6	4.4	3.1	3.0		
(37)		5% WB MCWBR	3.2	3.2	4.4	5.5	5.6	5.1	4.5	4.0	3.5	3.4	3.0	3.2		
(38)		5% WB MCDBR	3.0	3.9	5.6	7.3	7.8	7.9	7.6	7.2	4.9	4.1	3.2	3.1		
(39)	Clear-Sky Solar Irradiance	taub	0.319	0.343	0.365	0.398	0.396	0.388	0.412	0.413	0.379	0.363	0.344	0.314		
(40)		taud	2.310	2.331	2.313	2.286	2.366	2.416	2.366	2.365	2.433	2.395	2.330	2.298		
(41)		Ebn at Noon	605	729	800	823	849	859	828	802	782	697	566	522		
(42)		Edh at Noon	56	77	98	115	113	109	112	106	87	72	55	46		
(44)	All-Sky Solar Radiation	RadAvg	0.42	1.05	2.43	4.31	5.65	6.05	5.51	4.45	3.15	1.52	0.59	0.30		
(45)		RadStd	0.07	0.18	0.21	0.43	0.57	0.38	0.60	0.34	0.31	0.24	0.09	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (49 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-152	+59	N/A

Nomenclature: See separate page