

D15-FA-1, Netherlands

WMO: 062010

Lat: 54.326N

Lon: 2.936E

Elev: 118

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.6	34.4	21.3	16.1	34.2	23.6	17.9	35.6	46.7	45.1	42.4	43.4	23.7	100	0.871

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	67.2	64.1	65.6	62.4	64.7	61.5	64.6	66.6	63.3	65.2	62.2	64.1	16.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.7	65.9	62.4	84.7	64.8	61.2	81.0	63.9	29.8	66.8	28.9	65.3	28.0	64.2	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.2	37.0	33.4	31.9	68.4	3.4	2.8	29.5	70.4	27.6	72.0	25.7	73.6	23.2	75.6		
(5)			28.7	65.0	3.6	2.2	26.1	66.5	24.0	67.8	21.9	69.0	19.3	70.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	42.4	41.2	42.4	45.5	50.2	55.4	59.7	61.9	59.2	54.9	49.5	45.3		
	DBStd	7.81	3.43	3.61	3.44	3.00	3.29	2.85	4.06	2.20	2.54	3.08	3.79	3.65		
	HDD50	1103	237	245	234	138	39	1	5	0	0	5	52	147		
	HDD65	5229	702	665	699	586	459	289	169	99	174	313	465	609		
	CDD50	1354	0	0	0	2	45	161	305	368	277	157	37	2		
	CDD65	8	0	0	0	0	0	0	4	3	1	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.0	21.1	19.9	18.4	16.5	16.3	14.3	14.9	15.6	17.0	20.4	20.7	21.3		
	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3		
(15) Precipitation	PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2		
	PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0		
	PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	48.9	49.5	53.9	58.4	63.6	70.8	68.3	67.8	62.9	58.4	53.2		
		MCWB	48.3	46.0	46.7	49.7	54.6	60.3	66.1	65.0	64.8	59.9	55.8	50.5		
	2%	DB	48.5	47.6	48.2	51.4	56.7	61.6	67.6	66.8	65.3	61.1	56.8	52.1		
		MCWB	46.4	45.1	45.9	48.1	53.9	59.1	64.8	63.5	62.5	58.6	54.5	49.9		
	5%	DB	47.6	46.5	46.9	50.2	55.6	60.2	65.6	65.7	63.9	60.0	55.7	51.0		
		MCWB	45.5	44.3	44.7	47.6	53.2	57.8	62.5	62.3	61.2	57.3	53.2	48.9		
	10%	DB	46.8	45.7	46.1	49.2	54.5	59.0	64.4	64.8	62.9	58.8	54.4	49.8		
		MCWB	44.7	43.6	44.0	46.9	52.3	56.5	61.3	61.6	60.2	56.0	51.7	47.8		
	0.4%	WB	49.0	47.1	47.5	49.8	56.2	61.0	67.2	65.7	65.0	60.3	56.6	51.3		
		MCDB	49.7	48.0	48.6	51.6	57.6	62.8	69.3	67.7	66.4	62.1	57.9	52.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.1	45.7	46.2	49.0	54.8	59.5	65.0	64.3	63.7	59.2	55.1	50.4		
		MCDB	48.0	46.9	47.6	50.7	56.0	61.1	67.3	66.3	64.9	61.0	56.7	51.6		
	5%	WB	46.0	44.8	45.1	48.2	53.8	58.3	63.4	63.1	62.1	57.9	53.7	49.2		
		MCDB	47.1	46.1	46.4	49.9	55.0	60.0	65.4	65.0	63.4	59.6	55.3	50.7		
	10%	WB	45.1	44.0	44.4	47.3	52.6	56.9	61.9	62.3	60.7	56.7	52.1	48.1		
		MCDB	46.5	45.4	45.8	49.0	54.3	58.6	63.9	64.3	62.5	58.5	54.1	49.7		
	5% DB	MDBR	3.5	3.3	3.3	3.2	3.2	3.1	3.6	3.3	3.2	3.5	3.7	3.7		
		MCDBR	4.0	3.8	3.8	4.0	4.4	4.2	3.9	3.8	3.4	4.0	4.5	4.1		
		MCWBR	4.8	3.9	3.6	2.9	3.6	3.8	3.3	4.4	4.1	4.7	5.6	4.8		
		MCWBR	3.7	3.7	3.7	4.0	4.5	4.1	4.1	3.8	3.1	4.0	4.5	4.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.6	4.0	3.7	3.1	3.9	4.0	3.6	4.6	4.0	4.9	5.7	5.1		
	Clear-Sky Solar Irradiance	taub	0.332	0.347	0.373	0.401	0.390	0.397	0.401	0.393	0.382	0.357	0.335	0.318		
		taud	2.287	2.346	2.314	2.270	2.387	2.382	2.380	2.412	2.428	2.421	2.341	2.275		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	191	233	253	261	272	271	267	262	249	227	189	169		
		Edh at Noon	19	25	31	37	35	36	35	32	28	23	18	16		
(44) All-Sky Solar Radiation	RadStd		184	410	832	1379	1767	1795	1754	1468	986	528	226	137		
			21	60	65	129	121	124	173	98	96	35	20	14		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-187	N/A	N/A

Nomenclature: See separate page