

D15-FA-1, Netherlands

WMO: 062010

Lat: 54.326N

Lon: 2.936E

Elev: 36

StdP: 100.89

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.3	1.3	-5.9	2.3	1.2	-4.7	2.6	2.0	20.9	7.3	19.0	6.3	10.6	100	0.871

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	19.6	17.8	18.7	16.9	18.1	16.4	18.1	19.2	17.4	18.4	16.8	17.8	7.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.7	18.8	16.9	12.1	18.2	16.2	11.6	17.7	51.4	19.3	49.2	18.5	47.3	17.9	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.6	14.9	DB	0.0	20.2	1.9	1.6	-1.4	21.3	-2.5	22.2	-3.5	23.1	-4.9	24.2	(4)
(5)			WB	-1.8	18.3	2.0	1.2	-3.3	19.2	-4.5	19.9	-5.6	20.6	-7.1	21.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	5.8	5.1	5.8	7.5	10.1	13.0	15.4	16.6	15.1	12.7	9.7	7.4		
	DBStd	4.34	1.90	2.00	1.91	1.67	1.83	1.58	2.25	1.22	1.41	1.71	2.11	2.03		
	HDD10.0	613	132	136	130	77	22	1	3	0	0	3	29	82		
	HDD18.3	2905	390	369	388	326	255	161	94	55	97	174	258	338		
	CDD10.0	752	0	0	0	1	25	89	169	204	154	87	21	1		
	CDD18.3	4	0	0	0	0	0	0	2	2	1	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.1	9.4	8.9	8.2	7.4	7.3	6.4	6.6	7.0	7.6	9.1	9.2	9.5		
(15) Precipitation	PrecAvg	975	94	72	66	46	52	63	74	93	95	104	108	108		
	PrecMax	1262	165	146	139	99	88	135	172	209	192	191	192	182		
	PrecMin	724	12	23	10	3	24	19	13	20	19	37	18	50		
	PrecStd	132	39	31	31	24	19	30	36	46	43	43	39	35		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	9.4	9.7	12.2	14.7	17.6	21.6	20.2	19.9	17.2	14.7	11.8		
		MCWB	9.1	7.8	8.2	9.8	12.6	15.7	18.9	18.3	18.2	15.5	13.2	10.3		
	2%	DB	9.2	8.7	9.0	10.8	13.7	16.4	19.8	19.3	18.5	16.2	13.8	11.1		
		MCWB	8.0	7.3	7.7	9.0	12.2	15.1	18.2	17.5	16.9	14.8	12.5	9.9		
	5%	DB	8.7	8.1	8.3	10.1	13.1	15.6	18.7	18.7	17.7	15.5	13.2	10.5		
		MCWB	7.5	6.8	7.1	8.7	11.8	14.3	16.9	16.9	16.2	14.1	11.8	9.4		
	10%	DB	8.2	7.6	7.8	9.5	12.5	15.0	18.0	18.2	17.2	14.9	12.4	9.9		
		MCWB	7.0	6.4	6.6	8.3	11.3	13.6	16.3	16.4	15.7	13.3	10.9	8.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	8.4	8.6	9.9	13.4	16.1	19.6	18.7	18.3	15.7	13.7	10.7		
		MCDB	9.8	8.9	9.2	10.9	14.2	17.1	20.7	19.8	19.1	16.7	14.4	11.2		
	2%	WB	8.4	7.6	7.9	9.4	12.7	15.3	18.3	17.9	17.6	15.1	12.8	10.2		
		MCDB	8.9	8.3	8.7	10.4	13.3	16.2	19.6	19.0	18.3	16.1	13.7	10.9		
	5%	WB	7.8	7.1	7.3	9.0	12.1	14.6	17.4	17.3	16.7	14.4	12.0	9.6		
		MCDB	8.4	7.8	8.0	9.9	12.8	15.6	18.6	18.4	17.5	15.4	13.0	10.4		
	10%	WB	7.3	6.6	6.9	8.5	11.5	13.8	16.6	16.8	15.9	13.7	11.2	8.9		
		MCDB	8.0	7.4	7.6	9.4	12.4	14.8	17.7	18.0	17.0	14.7	12.3	9.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	1.9	1.8	1.8	1.8	1.8	1.7	2.0	1.8	1.8	2.0	2.0	2.0		
		MCDBR	2.2	2.1	2.1	2.2	2.4	2.3	2.2	2.1	1.9	2.2	2.5	2.3		
	5% WB	MCWBR	2.7	2.2	2.0	1.6	2.0	2.1	1.8	2.5	2.3	2.6	3.1	2.7		
		MCWBR	2.1	2.1	2.1	2.2	2.5	2.3	2.3	2.1	1.7	2.2	2.5	2.3		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.347	0.373	0.401	0.390	0.397	0.401	0.393	0.382	0.357	0.335	0.318		
		taud	2.287	2.346	2.314	2.270	2.387	2.382	2.380	2.412	2.428	2.421	2.341	2.275		
	Ebn at Noon		601	735	797	823	857	853	841	825	784	715	597	533		
		Edh at Noon	60	78	99	118	111	113	111	102	89	72	56	49		
(44) All-Sky Solar Radiation	RadAvg		0.58	1.29	2.62	4.35	5.57	5.66	5.53	4.63	3.11	1.67	0.71	0.43		
	RadStd		0.07	0.19	0.21	0.41	0.38	0.39	0.55	0.31	0.30	0.11	0.06	0.04		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (18 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-104	N/A	N/A		

Nomenclature: See separate page