

L9-FF-1, Netherlands

WMO: 062070

Lat: 53.614N

Lon: 4.960E

Elev: 98

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.5	31.5	19.8	14.9	32.3	22.7	17.1	33.5	50.6	45.6	47.2	46.1	20.8	120	0.867

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	71.8	65.7	69.4	64.4	67.7	63.4	66.8	70.7	65.2	68.5	63.8	67.0	15.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.2	69.3	63.6	88.3	67.9	62.4	84.4	66.6	31.4	71.4	30.2	68.5	29.2	67.1	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.2	39.3	35.2	DB	27.8	79.1	3.6	2.8	25.2	81.1	23.1	82.7	21.0	84.3	18.4	86.3	(4)
(5)			WB	25.9	69.2	3.8	1.4	23.2	70.2	21.0	71.0	18.9	71.8	16.1	72.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	41.2	40.9	42.6	47.2	52.7	57.8	62.8	64.0	61.0	55.7	49.1	44.9	(6)	
	DBStd	9.13	4.75	4.44	4.19	4.28	4.53	3.65	3.83	3.35	3.19	3.65	4.23	4.65	(7)	
	HDD50	1120	274	256	231	105	23	0	0	0	0	4	63	164	(8)	
	HDD65	4909	739	676	695	534	383	219	92	57	127	287	476	624	(9)	
	CDD50	1746	0	0	1	21	105	234	396	435	330	182	37	5	(10)	
	CDD65	60	0	0	0	0	0	3	23	27	7	0	0	0	(11)	
	CDH74	31	0	0	0	0	1	2	15	11	2	0	0	0	(12)	
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)	
(14) Wind	WSAvg	18.7	21.7	21.2	19.4	17.2	17.3	15.5	15.3	15.8	17.2	20.2	20.4	23.0	(14)	
(15) Precipitation	PrecAvg	32.4	2.7	2.1	1.7	1.5	1.9	2.2	2.8	3.3	3.4	3.8	3.7	3.2	(15)	
	PrecMax	40.2	5.0	4.8	3.6	3.2	3.3	3.7	6.3	7.5	6.9	9.1	6.9	6.0	(16)	
	PrecMin	22.6	0.4	0.7	0.2	0.0	0.7	0.8	0.8	0.7	0.4	1.2	0.5	1.3	(17)	
	PrecStd	4.8	1.3	0.9	0.9	0.8	0.7	0.9	1.4	1.9	1.7	1.9	1.4	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	51.4	53.2	62.9	66.1	71.8	75.6	75.5	72.7	65.4	59.3	54.4	(19)	
		MCWB	48.7	46.0	48.6	54.3	58.5	65.4	67.8	68.1	66.7	60.6	56.6	51.5	(20)	
	2%	DB	49.6	48.4	49.8	57.5	62.0	66.3	71.6	71.5	68.7	63.3	57.6	53.2	(21)	
		MCWB	47.4	45.1	46.6	51.8	57.0	62.1	65.4	65.6	63.8	59.5	54.9	50.5	(22)	
	5%	DB	48.3	47.2	48.1	54.1	59.5	63.5	68.9	69.5	66.5	61.6	56.3	51.9	(23)	
		MCWB	46.1	44.4	46.0	49.8	55.5	59.7	64.6	64.4	62.5	58.3	53.5	49.7	(24)	
	10%	DB	47.0	46.1	46.8	51.9	58.0	61.7	67.2	67.8	65.0	60.4	54.9	50.4	(25)	
		MCWB	44.8	43.6	44.5	48.5	54.6	58.4	63.4	63.2	61.1	57.2	51.9	48.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	47.9	49.2	54.7	60.8	66.1	68.6	68.7	67.2	61.5	57.6	52.4	(27)	
		MCDB	50.3	49.7	52.4	61.4	64.4	70.1	74.3	73.1	71.6	64.2	58.7	53.8	(28)	
	2%	WB	47.7	46.0	47.4	52.0	58.0	62.8	66.6	66.8	64.8	60.2	55.6	51.2	(29)	
		MCDB	48.9	47.4	49.2	56.6	60.8	65.5	70.4	70.7	68.1	62.7	57.3	52.5	(30)	
	5%	WB	46.5	44.9	46.2	50.3	56.2	60.4	65.2	65.1	63.1	59.1	53.9	50.1	(31)	
		MCDB	47.7	46.5	47.8	53.8	58.9	62.8	68.4	68.4	65.9	61.3	56.0	51.8	(32)	
	10%	WB	45.3	44.0	44.9	48.8	54.8	58.8	63.7	63.8	61.8	57.9	52.1	48.4	(33)	
		MCDB	46.7	45.8	46.3	51.5	57.5	61.1	66.8	67.0	64.7	60.2	54.4	50.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.5	4.3	5.4	5.0	4.7	4.7	4.7	4.2	4.7	4.7	4.8	(35)	
		MCDBR	5.0	5.5	6.2	10.0	8.8	8.4	8.6	8.2	5.8	5.6	5.1	4.9	(36)	
	5% WB	MCWBR	5.3	4.8	5.0	6.5	6.1	6.2	5.9	5.9	5.3	5.4	5.6	5.6	(37)	
		MCWBR	4.9	5.1	5.8	9.2	8.6	7.9	8.1	6.7	5.5	5.2	5.0	4.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.333	0.349	0.376	0.403	0.398	0.399	0.407	0.400	0.386	0.363	0.342	0.322	(40)	
		taud	2.306	2.349	2.308	2.280	2.366	2.379	2.365	2.394	2.424	2.413	2.342	2.299	(41)	
	Edn at Noon	Edn at Noon	196	235	253	262	270	270	266	260	249	227	191	175	(42)	
		Edh at Noon	19	25	32	37	36	36	36	33	29	23	19	16	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	182	384	825	1364	1711	1770	1702	1421	966	523	218	137	(44)	
	RadStd	RadStd	17	62	72	130	106	116	167	103	83	48	20	16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page