

L9-FF-1, Netherlands

WMO: 062070

Lat: 53.614N

Lon: 4.960E

Elev: 30

StdP: 100.97

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.4	-0.3	-6.8	2.1	0.2	-5.2	2.4	0.8	22.6	7.5	21.1	7.8	9.3	120	0.867

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	22.1	18.7	20.8	18.0	19.8	17.4	19.3	21.5	18.4	20.3	17.7	19.4	7.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	20.7	17.6	12.6	19.9	16.9	12.1	19.2	55.1	21.9	52.3	20.3	50.0	19.5	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	17.6	15.7	-2.3	26.2	2.0	1.5	-3.8	27.3	-5.0	28.2	-6.1	29.0	-7.6	30.2		
(5)			-3.4	20.7	2.1	0.8	-4.9	21.2	-6.1	21.7	-7.3	22.1	-8.8	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	5.1	4.9	5.9	8.5	11.5	14.3	17.1	17.8	16.1	13.2	9.5	7.2	(6)
(7)		DBStd	5.07	2.64	2.46	2.33	2.38	2.51	2.03	2.13	1.86	1.77	2.03	2.35	2.59	(7)
(8)		HDD10.0	622	152	142	128	58	13	0	0	0	0	2	35	91	(8)
(9)		HDD18.3	2727	411	376	386	297	213	122	51	32	71	159	264	347	(9)
(10)		CDD10.0	970	0	0	1	12	58	130	220	242	183	101	21	3	(10)
(11)		CDD18.3	33	0	0	0	0	0	2	13	15	4	0	0	0	(11)
(12)		CDH23.3	17	0	0	0	0	1	1	8	6	1	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.3	9.7	9.5	8.7	7.7	7.7	6.9	6.9	7.0	7.7	9.0	9.1	10.3	(14)
(15)	Precipitation	PrecAvg	822	69	54	44	39	47	56	70	85	87	97	94	81	(15)
(16)		PrecMax	1020	127	122	91	82	83	95	159	190	174	230	175	152	(16)
(17)		PrecMin	575	9	19	4	1	18	21	21	17	11	30	12	34	(17)
(18)		PrecStd	122	32	24	24	20	18	22	35	48	44	47	35	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	10.8	11.8	17.1	19.0	22.1	24.2	22.6	18.5	15.1	12.5	(19)	
(20)			MCWB	9.3	7.8	9.2	12.4	14.7	18.5	19.9	20.1	19.3	15.9	13.7	10.8	(20)
(21)		2%	DB	9.8	9.1	9.9	14.2	16.7	19.1	22.0	22.0	20.4	17.4	14.2	11.8	(21)
(22)			MCWB	8.6	7.3	8.1	11.0	13.9	16.7	18.5	18.7	17.7	15.3	12.7	10.3	(22)
(23)		5%	DB	9.0	8.4	9.0	12.3	15.3	17.5	20.5	20.9	19.2	16.5	13.5	11.0	(23)
(24)			MCWB	7.8	6.9	7.8	9.9	13.1	15.4	18.1	18.0	16.9	14.6	12.0	9.8	(24)
(25)		10%	DB	8.4	7.8	8.2	11.1	14.4	16.5	19.6	19.9	18.3	15.8	12.7	10.2	(25)
(26)			MCWB	7.1	6.5	6.9	9.2	12.6	14.6	17.5	17.3	16.2	14.0	11.1	8.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.8	9.6	12.6	16.0	18.9	20.3	20.4	19.5	16.4	14.2	11.4	(27)
(28)			MCD B	10.1	9.8	11.3	16.3	18.0	21.2	23.5	22.8	22.0	17.9	14.8	12.1	(28)
(29)		2%	WB	8.7	7.8	8.5	11.1	14.4	17.1	19.2	19.3	18.2	15.6	13.1	10.7	(29)
(30)			MCD B	9.4	8.6	9.5	13.7	16.0	18.6	21.3	21.5	20.1	17.1	14.1	11.4	(30)
(31)		5%	WB	8.1	7.2	7.9	10.1	13.4	15.8	18.4	18.4	17.3	15.1	12.2	10.0	(31)
(32)			MCD B	8.7	8.1	8.8	12.1	14.9	17.1	20.2	20.2	18.9	16.3	13.3	11.0	(32)
(33)		10%	WB	7.4	6.7	7.2	9.4	12.6	14.9	17.6	17.7	16.6	14.4	11.2	9.1	(33)
(34)			MCD B	8.2	7.7	8.0	10.8	14.2	16.2	19.3	19.4	18.1	15.6	12.4	10.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.7	2.5	2.4	3.0	2.8	2.6	2.6	2.4	2.6	2.6	2.7	(35)	
(36)			MCDBR	2.8	3.1	3.4	5.6	4.9	4.7	4.8	4.6	3.2	3.1	2.8	2.7	(36)
(37)			MCWBR	3.0	2.7	2.8	3.6	3.4	3.4	3.3	3.3	2.9	3.0	3.1	3.1	(37)
(38)		5% WB	MCDBR	2.7	2.9	3.2	5.1	4.8	4.4	4.5	3.7	3.0	2.9	2.8	2.6	(38)
(39)			MCWBR	3.1	2.7	2.9	3.5	3.5	3.5	3.2	3.3	3.1	3.1	3.1	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.333	0.349	0.376	0.403	0.398	0.399	0.407	0.400	0.386	0.363	0.342	0.322	(40)	
(41)		taud	2.306	2.349	2.308	2.280	2.366	2.379	2.365	2.394	2.424	2.413	2.342	2.299	(41)	
(42)		Ebn at Noon	619	742	799	825	851	852	837	821	785	716	603	552	(42)	
(43)		Edh at Noon	61	79	101	118	114	114	113	104	90	74	59	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.57	1.21	2.60	4.30	5.39	5.58	5.37	4.48	3.05	1.65	0.69	0.43	(44)	
(45)		RadStd	0.06	0.20	0.23	0.41	0.33	0.36	0.53	0.33	0.26	0.15	0.06	0.05	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page