

J6-A, NetherlandsWMO: **062110**Lat: **53.824N**Lon: **2.945E**Elev: **112**StdP: **14.64**Time Zone: **1.00 (EUC)**Period: **09-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.3	34.3	21.4	16.1	34.2	23.8	18.1	35.8	43.2	45.5	40.8	45.4	23.7	120	0.853

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	68.2	64.2	66.4	62.9	65.2	61.9	64.7	67.1	63.6	65.7	62.4	64.6	17.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	88.5	66.4	62.5	84.9	65.3	61.3	81.5	64.3	29.8	67.2	29.0	65.8	28.2	64.7	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.8	36.5	33.0	DB	32.7	70.7	1.6	3.5	31.6	73.2	30.6	75.3	29.7	77.3	28.5	79.9	(4)
(5)			WB	29.4	66.0	3.7	2.4	26.7	67.7	24.6	69.1	22.5	70.5	19.8	72.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	42.4	41.2	42.6	45.8	50.6	55.6	60.6	62.0	59.8	55.8	50.0	45.6	(6)	
	DBStd	7.96	3.56	3.89	3.33	3.26	3.48	2.82	3.04	2.52	2.95	2.97	3.87	3.68	(7)	
	HDD50	1061	234	246	228	130	35	0	0	0	0	2	46	140	(8)	
	HDD65	5096	699	666	693	575	446	281	141	99	158	286	450	602	(9)	
	CDD50	1452	0	0	0	5	54	169	329	371	294	181	46	3	(10)	
	CDD65	13	0	0	0	0	0	0	5	5	3	0	0	0	(11)	
	CDH74	2	0	0	0	0	0	0	2	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	17.7	20.6	20.2	18.6	16.5	16.3	14.2	14.4	15.3	16.4	19.6	20.1	20.3	(14)	
(15) Precipitation	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3	(15)	
	PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2	(16)	
	PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0	(17)	
	PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	49.8	50.0	56.6	60.4	65.0	72.9	70.5	70.9	64.1	58.9	53.1	(19)	
		MCWB	48.0	46.6	46.9	50.4	55.1	61.4	66.9	66.1	67.2	60.5	56.2	50.6	(20)	
	2%	DB	49.0	48.0	48.4	53.4	58.2	62.2	68.2	67.9	66.6	62.6	57.7	52.2	(21)	
		MCWB	46.7	45.5	46.0	49.1	54.2	59.4	64.5	63.4	63.6	59.6	55.3	50.0	(22)	
	5%	DB	47.8	46.8	47.2	51.3	56.7	60.7	66.3	66.3	65.2	61.1	56.4	51.3	(23)	
		MCWB	45.6	44.6	44.9	48.3	53.7	58.2	63.0	62.5	62.1	58.2	54.0	49.3	(24)	
	10%	DB	46.9	45.9	46.3	49.9	55.3	59.2	64.5	65.3	63.9	59.8	55.2	50.2	(25)	
		MCWB	44.7	43.8	44.0	47.6	52.8	56.6	61.4	61.8	60.7	56.9	52.5	48.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	47.4	47.8	51.1	56.6	61.8	67.2	66.5	65.3	61.1	57.2	51.6	(27)	
		MCDB	49.7	48.8	49.2	54.3	58.4	64.3	71.3	70.0	66.5	63.3	58.4	52.3	(28)	
	2%	WB	47.3	46.1	46.5	49.8	55.2	60.1	65.0	64.5	63.8	60.0	55.8	50.7	(29)	
		MCDB	48.4	47.3	48.0	52.2	57.1	62.0	67.9	66.8	65.4	62.0	57.2	51.7	(30)	
	5%	WB	46.2	45.1	45.4	48.8	54.0	58.6	63.5	63.4	62.7	58.7	54.5	49.7	(31)	
		MCDB	47.4	46.4	46.8	51.0	55.9	60.4	65.8	65.6	64.5	60.6	56.2	51.1	(32)	
	10%	WB	45.2	44.2	44.5	47.8	53.0	57.1	61.8	62.5	61.3	57.6	52.9	48.4	(33)	
		MCDB	46.6	45.5	45.9	49.8	55.0	58.8	63.9	64.7	63.2	59.6	54.9	50.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.5	3.5	3.7	3.6	3.3	3.6	3.6	3.6	3.8	3.9	3.7	(35)	
		MCDBR	4.1	4.2	4.2	5.2	5.2	4.6	5.3	4.5	4.4	4.5	4.9	4.0	(36)	
	5% WB	MCWBR	4.9	3.8	3.6	3.7	3.9	4.2	3.6	4.2	4.3	4.9	5.7	5.0	(37)	
		MCWBR	4.0	4.1	4.1	5.0	4.8	4.6	4.8	4.3	4.1	4.2	4.8	4.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.332	0.347	0.375	0.401	0.394	0.400	0.404	0.394	0.382	0.360	0.335	0.319	(40)	
		taud	2.306	2.356	2.313	2.276	2.378	2.373	2.371	2.409	2.431	2.424	2.356	2.296	(41)	
	Ebn at Noon	Ebn at Noon	195	235	253	262	271	270	266	262	250	228	193	174	(42)	
		Edh at Noon	19	25	32	37	36	36	36	33	28	23	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	193	422	846	1396	1768	1822	1772	1486	1010	540	236	145	(44)	
	RadStd	RadStd	20	65	67	134	118	111	179	102	86	37	21	14	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-198	+94	N/A

Nomenclature: See separate page