

IJMUIDEN, Netherlands

WMO: 062250

Lat: 52.4622N

Lon: 4.5550E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.5	24.6	14.2	11.3	24.0	18.2	13.7	26.9	49.5	45.6	46.4	45.9	16.7	80	0.825

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	78.0	65.7	74.4	64.1	71.3	63.6	68.1	73.9	66.6	70.8	65.3	69.0	14.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.8	70.0	65.1	92.9	68.4	63.9	88.8	67.1	32.4	74.4	31.2	70.8	30.2	69.0	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.7	36.7	33.4	DB	20.2	84.8	7.9	3.8	14.5	87.6	9.8	89.8	5.4	92.0	-0.4	94.7	(4)
(5)			WB	19.1	72.0	7.8	2.0	13.5	73.4	9.0	74.5	4.6	75.6	-1.0	77.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	40.2	38.0	43.2	47.2	54.8	58.6	63.5	63.2	58.9	53.0	46.0	42.6	(6)	
	DBStd	10.26	6.60	7.35	5.80	5.50	6.63	5.24	4.48	3.88	3.51	4.87	6.15	5.33	(7)	
	HDD50	1401	305	338	219	119	19	1	0	0	0	29	140	231	(8)	
	HDD65	5257	770	757	674	533	327	205	86	81	186	373	571	694	(9)	
	CDD50	1711	0	1	10	36	167	259	418	410	268	121	19	2	(10)	
	CDD65	92	0	0	0	0	10	14	39	25	4	0	0	0	(11)	
	CDH74	337	0	0	0	2	50	53	145	73	14	0	0	0	(12)	
	CDH80	49	0	0	0	0	4	5	27	12	1	0	0	0	(13)	
	WSAvg	17.3	20.6	19.1	18.5	15.9	15.5	15.2	15.5	16.0	16.2	18.0	17.6	19.7	(14)	
	PrecAvg	36.1	3.0	2.4	2.0	1.7	2.1	2.6	3.2	4.1	3.6	3.9	3.9	3.5	(15)	
(16) Precipitation	PrecMax	48.1	5.6	4.8	5.0	3.7	4.1	6.2	6.7	9.3	7.7	6.9	7.4	6.3	(16)	
	PrecMin	27.1	0.3	0.8	0.4	0.0	0.7	0.9	0.6	0.9	0.4	0.7	0.4	0.9	(17)	
	PrecStd	5.0	1.4	1.1	1.2	0.9	0.9	1.4	1.7	2.2	1.9	1.7	1.7	1.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	54.5	63.8	71.2	79.5	79.2	84.3	81.8	75.4	69.0	58.4	54.0	(19)	
		MCWB	49.5	51.5	54.9	58.9	62.1	65.4	69.9	69.2	66.1	61.1	54.0	51.6	(20)	
	2%	DB	49.4	51.4	57.1	64.2	74.5	74.7	78.2	75.4	69.7	63.2	55.8	52.7	(21)	
		MCWB	47.9	49.4	51.3	56.3	60.0	63.8	67.1	66.1	63.8	59.5	53.4	50.6	(22)	
	5%	DB	48.0	48.3	52.7	58.9	70.2	70.3	73.8	71.6	66.4	60.7	54.5	50.6	(23)	
		MCWB	46.7	46.5	49.4	53.3	59.0	62.6	65.8	64.3	63.1	57.9	52.4	49.0	(24)	
	10%	DB	47.0	46.1	49.8	55.2	65.4	66.1	70.2	68.8	64.6	59.3	53.1	49.2	(25)	
		MCWB	45.7	44.6	47.8	50.7	57.7	61.2	64.7	64.1	61.5	56.5	51.2	47.9	(26)	
	0.4%	WB	50.3	53.0	54.8	60.9	65.0	68.6	71.3	71.0	67.1	62.4	55.5	52.1	(27)	
		MCDB	50.9	54.2	61.2	69.5	74.6	74.3	79.6	78.8	70.4	66.4	57.2	53.5	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	48.4	49.4	52.1	57.0	62.4	65.5	68.5	67.7	65.2	60.1	54.0	50.8	(29)	
		MCDB	49.1	50.8	56.0	61.7	70.3	71.4	74.7	73.1	68.2	62.0	55.3	52.0	(30)	
	5%	WB	47.3	46.9	49.9	53.8	60.0	63.4	66.9	66.4	63.7	58.9	52.9	49.5	(31)	
		MCDB	48.0	47.9	52.2	58.1	67.2	68.4	71.8	69.7	66.7	60.3	54.1	50.3	(32)	
	10%	WB	46.1	45.0	48.1	51.5	57.9	61.6	65.3	65.2	61.8	57.3	51.8	48.3	(33)	
		MCDB	46.8	45.9	49.5	54.1	64.6	65.6	69.0	68.2	64.5	59.1	53.0	48.9	(34)	
	5% DB	MDBR	6.1	6.6	7.1	8.1	8.9	7.0	7.2	7.3	7.5	7.7	6.5	6.0	(35)	
		MCDBR	7.3	9.4	12.7	14.9	17.6	15.4	14.6	13.8	13.3	9.7	6.5	7.0	(36)	
		MCWBR	6.9	7.9	7.9	8.5	7.5	7.5	7.3	7.2	9.5	7.2	5.9	6.5	(37)	
		MCWBR	6.7	8.4	10.9	13.5	16.0	13.1	12.6	9.9	11.8	8.8	6.2	7.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.361	0.392	0.413	0.417	0.413	0.422	0.414	0.394	0.376	0.353	0.335	(40)	
		taud	2.308	2.309	2.243	2.236	2.290	2.317	2.300	2.337	2.381	2.373	2.331	2.301	(41)	
	Edn at Noon		200	234	249	260	265	267	262	257	248	226	194	180	(42)	
		Edh at Noon	20	27	35	39	39	39	39	35	30	25	20	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		215	433	826	1337	1635	1734	1652	1374	984	558	248	159	(44)	
	RadStd		21	77	90	125	100	109	166	108	83	49	23	17	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (74 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page