

IJMUIDEN, Netherlands

WMO: 062250

Lat: 52.4622N

Lon: 4.5550E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.4	-4.1	-9.9	1.6	-4.4	-7.7	2.0	-2.8	22.1	7.6	20.8	7.7	7.5	80	0.825

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.0	25.6	18.7	23.6	17.8	21.8	17.6	20.0	23.3	19.2	21.5	18.5	20.6	6.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	21.1	18.4	13.3	20.2	17.7	12.7	19.5	57.4	23.6	54.6	21.5	52.4	20.6	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.4	15.0	DB	-6.6	29.3	4.4	2.1	-9.7	30.9	-12.3	32.1	-14.8	33.3	-18.0	34.9	(4)
(5)			WB	-7.2	22.2	4.3	1.1	-10.3	23.0	-12.8	23.6	-15.2	24.2	-18.3	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	4.5	3.3	6.2	8.5	12.6	14.8	17.5	17.3	15.0	11.7	7.8	5.9		
	DBStd	5.70	3.67	4.08	3.22	3.05	3.68	2.91	2.49	2.16	1.95	2.70	3.41	2.96		
	HDD10.0	778	169	188	122	66	11	1	0	0	0	16	78	128		
	HDD18.3	2921	428	421	374	296	182	114	48	45	103	207	317	386		
	CDD10.0	951	0	1	6	20	93	144	232	228	149	67	11	1		
	CDD18.3	51	0	0	0	0	6	8	22	14	2	0	0	0		
	CDH23.3	187	0	0	0	1	28	29	81	41	8	0	0	0		
	CDH26.7	27	0	0	0	0	2	3	15	7	1	0	0	0		
(14) Wind	WSAvg	7.7	9.2	8.5	8.3	7.1	6.9	6.8	6.9	7.2	7.2	8.0	7.9	8.8		
(15) Precipitation	PrecAvg	916	77	62	52	43	54	65	81	103	92	98	100	89		
	PrecMax	1222	142	123	128	95	105	157	169	237	196	174	187	159		
	PrecMin	688	8	20	10	0	18	22	16	23	9	18	10	22		
	PrecStd	128	36	29	30	24	24	36	42	57	48	42	43	36		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.5	17.7	21.8	26.4	26.2	29.1	27.7	24.1	20.5	14.7	12.2		
		MCWB	9.7	10.8	12.7	15.0	16.7	18.6	21.0	20.7	18.9	16.2	12.2	10.9		
	2%	DB	9.7	10.8	13.9	17.9	23.6	23.7	25.7	24.1	20.9	17.3	13.2	11.5		
		MCWB	8.8	9.6	10.7	13.5	15.6	17.7	19.5	19.0	17.7	15.3	11.9	10.3		
	5%	DB	8.9	9.1	11.5	14.9	21.2	21.3	23.2	22.0	19.1	16.0	12.5	10.3		
		MCWB	8.2	8.1	9.7	11.8	15.0	17.0	18.8	18.0	17.3	14.4	11.3	9.4		
	10%	DB	8.3	7.9	9.9	12.9	18.6	19.0	21.2	20.4	18.1	15.2	11.7	9.6		
		MCWB	7.6	7.0	8.8	10.4	14.3	16.2	18.1	17.9	16.4	13.6	10.7	8.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	11.7	12.7	16.1	18.3	20.3	21.8	21.6	19.5	16.9	13.1	11.2		
		MCDB	10.5	12.3	16.2	20.8	23.7	23.5	26.4	26.0	21.3	19.1	14.0	11.9		
	2%	WB	9.1	9.7	11.2	13.9	16.9	18.6	20.3	19.8	18.4	15.6	12.2	10.5		
		MCDB	9.5	10.5	13.3	16.5	21.3	21.9	23.7	22.8	20.1	16.6	13.0	11.1		
	5%	WB	8.5	8.3	9.9	12.1	15.6	17.5	19.4	19.1	17.6	14.9	11.6	9.7		
		MCDB	8.9	8.8	11.2	14.5	19.6	20.2	22.1	20.9	19.3	15.7	12.3	10.2		
	10%	WB	7.8	7.2	8.9	10.8	14.4	16.4	18.5	18.5	16.6	14.1	11.0	9.0		
		MCDB	8.2	7.7	9.7	12.3	18.1	18.7	20.6	20.1	18.1	15.1	11.6	9.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.4	3.7	3.9	4.5	4.9	3.9	4.0	4.1	4.2	4.3	3.6	3.3		
		MCDBR	4.0	5.2	7.1	8.3	9.8	8.6	8.1	7.6	7.4	5.4	3.6	3.9		
	5% WB	MCWBR	3.8	4.4	4.4	4.7	4.2	4.2	4.1	4.0	5.3	4.0	3.3	3.6		
		MCWBR	3.7	4.7	6.1	7.5	8.9	7.3	7.0	5.5	6.6	4.9	3.5	3.9		
(40) Clear-Sky Solar Irradiance	taub		0.341	0.361	0.392	0.413	0.417	0.413	0.422	0.414	0.394	0.376	0.353	0.335		
		taud	2.308	2.309	2.243	2.236	2.290	2.317	2.300	2.337	2.381	2.373	2.331	2.301		
	Ebn at Noon		632	737	786	819	836	842	825	811	781	712	611	566		
		Edh at Noon	64	85	110	124	124	122	122	111	95	79	63	55		
(44) All-Sky Solar Radiation	RadAvg		0.68	1.36	2.60	4.22	5.16	5.47	5.21	4.33	3.10	1.76	0.78	0.50		
	RadStd		0.07	0.24	0.28	0.40	0.31	0.34	0.52	0.34	0.26	0.15	0.07	0.06		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (74 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page