

DE KOOIJ AP, Netherlands

WMO: 062350

Lat: 52.9269N

Lon: 4.7811E

Elev: 3

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	25.9	16.4	12.6	24.7	20.3	15.2	26.9	37.8	47.1	34.6	46.7	12.6	90	0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	78.6	68.0	74.8	66.4	71.7	64.8	69.3	76.2	67.5	73.2	65.8	70.5	9.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	98.5	72.9	65.1	92.9	70.8	63.6	88.1	69.1	33.4	76.7	31.9	73.6	30.6	70.6	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.5	27.9	25.0	DB	18.6	87.1	5.7	3.0	14.5	89.3	11.1	91.1	7.9	92.8	3.8	94.9
			WB	17.8	73.3	5.6	1.9	13.7	74.7	10.4	75.9	7.3	76.9	3.2	78.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	38.8	39.0	42.5	48.2	54.3	59.2	63.5	64.0	59.7	53.2	46.2	40.8	(6)
	DBStd	10.51	6.60	6.03	4.98	5.50	5.46	4.68	4.77	4.30	4.08	4.98	5.33	6.70	(7)
	HDD50	1453	347	308	235	98	16	0	0	0	0	26	135	288	(8)
	HDD65	5267	812	728	697	504	334	186	87	70	167	367	565	750	(9)
	CDD50	1761	0	0	3	43	150	275	420	434	290	124	19	3	(10)
	CDD65	103	0	0	0	0	3	12	41	40	7	0	0	0	(11)
	CDH74	404	0	0	0	3	13	65	160	143	20	0	0	0	(12)
	CDH80	71	0	0	0	0	1	13	30	24	3	0	0	0	(13)
(14) Wind	WSAvg	12.1	14.4	13.7	13.2	11.4	11.5	11.0	10.5	10.3	11.0	12.4	12.3	13.8	(14)
(15) Precipitation	PrecAvg	30.2	2.5	1.7	1.9	1.6	1.7	2.0	2.4	2.8	3.4	3.5	3.6	3.0	(15)
	PrecMax	40.3	5.1	4.3	4.6	3.3	3.6	5.0	5.6	6.3	8.1	7.5	6.1	6.6	(16)
	PrecMin	20.1	0.2	0.1	0.4	0.2	0.4	0.4	0.2	0.4	0.2	0.9	1.5	0.8	(17)
	PrecStd	5.0	1.2	1.0	0.9	0.8	0.9	1.2	1.4	1.7	1.9	1.8	1.3	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	53.0	59.1	69.4	75.3	81.7	83.7	83.4	76.4	68.6	59.4	54.3	(19)
		MCWB	49.7	47.6	51.0	57.7	62.8	67.6	71.3	69.1	66.9	62.2	56.9	52.4	(20)
	2%	DB	49.5	49.8	54.1	63.7	70.0	74.3	78.1	78.1	70.8	63.9	57.1	52.5	(21)
		MCWB	47.7	47.4	49.6	55.8	61.2	65.4	68.5	67.8	64.4	60.0	55.1	50.8	(22)
	5%	DB	48.2	48.0	51.0	59.7	66.1	69.8	74.5	73.7	68.0	61.8	55.3	50.9	(23)
		MCWB	46.6	46.0	47.7	53.7	59.6	63.0	67.0	66.2	63.1	58.6	53.1	49.1	(24)
	10%	DB	46.8	46.5	48.9	56.3	62.9	66.5	71.2	70.7	65.9	60.1	53.5	49.1	(25)
		MCWB	45.2	44.8	46.4	51.7	57.3	60.7	65.1	64.8	61.5	57.2	51.0	47.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	49.1	53.1	59.4	65.7	69.7	72.6	71.5	68.1	62.8	57.5	52.9	(27)
		MCDB	51.4	50.7	57.2	66.9	71.9	77.8	79.8	79.4	73.8	66.7	58.5	53.7	(28)
	2%	WB	48.3	47.7	50.1	56.5	62.5	66.3	69.6	69.0	65.6	60.6	55.4	51.2	(29)
		MCDB	49.1	49.3	53.1	62.6	68.2	72.5	76.4	75.7	69.7	63.3	56.8	52.3	(30)
	5%	WB	46.9	46.4	48.2	54.2	60.0	63.7	67.7	67.2	63.8	59.2	53.4	49.4	(31)
		MCDB	47.9	47.8	50.4	58.9	65.3	69.2	73.6	72.5	67.1	61.4	55.0	50.6	(32)
	10%	WB	45.5	45.0	46.8	52.1	57.7	61.4	65.7	65.5	62.3	57.7	51.4	47.6	(33)
		MCDB	46.7	46.3	48.7	55.8	62.3	65.6	70.4	69.9	65.4	59.8	53.0	48.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	7.4	8.9	10.9	10.7	10.6	10.3	10.4	9.5	8.8	7.5	6.9	(35)
		MCDBR	6.1	8.7	12.6	16.4	15.8	16.7	15.7	15.1	12.5	10.2	7.8	6.3	(36)
	5% WB	MCWBR	6.4	7.3	9.2	10.0	9.4	9.7	8.5	7.8	7.9	8.0	7.4	6.5	(37)
		MCWBR	6.1	8.2	10.9	15.2	14.3	15.0	14.3	13.3	11.2	10.0	7.7	6.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.337	0.355	0.384	0.408	0.409	0.406	0.416	0.409	0.391	0.370	0.348	0.329	(40)
		taud	2.308	2.325	2.270	2.253	2.319	2.341	2.322	2.358	2.397	2.390	2.337	2.302	(41)
	Ebn at Noon		200	235	252	261	267	269	263	259	248	227	193	178	(42)
		Edh at Noon	20	26	34	39	38	37	38	35	30	24	19	17	(43)
(44) All-Sky Solar Radiation	RadAvg		201	412	826	1349	1665	1747	1672	1392	976	543	235	150	(44)
	RadStd		19	71	82	126	101	110	166	105	82	48	21	16	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page