

F3-FB-1, Netherlands

WMO: 062390

Lat: 54.854N

Lon: 4.696E

Elev: 79

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.8	32.6	19.8	14.9	32.7	22.3	16.8	34.5	47.6	44.0	44.3	44.0	22.3	90	0.850

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	69.0	65.6	67.5	64.2	65.9	62.8	66.1	68.5	64.6	66.9	63.2	65.5	12.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	92.4	67.8	63.4	87.6	66.4	62.1	83.5	65.2	30.8	68.6	29.7	67.1	28.8	65.6	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.4	38.7	34.7	30.0	69.4	2.5	2.6	28.2	71.2	26.8	72.8	25.4	74.2	23.6	76.1		
(5)			26.8	66.1	2.8	2.1	24.8	67.6	23.2	68.8	21.6	70.0	19.5	71.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	41.8	40.4	41.0	44.6	49.8	55.2	60.3	62.3	59.3	54.5	49.0	44.8		
	DBStd	8.41	4.07	4.12	3.69	3.32	3.61	3.15	3.61	3.30	2.92	3.64	3.96	4.22		
	HDD50	1253	254	269	280	165	48	1	0	0	0	8	63	165		
	HDD65	5385	719	689	745	612	470	293	153	97	171	327	481	628		
	CDD50	1362	0	0	0	3	42	158	319	380	280	146	31	3		
	CDD65	21	0	0	0	0	0	7	13	1	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	17.9	21.3	20.3	19.7	16.4	15.9	15.6	14.1	14.6	16.5	19.8	20.1	21.1		
(15) Precipitation	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3		
	PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2		
	PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0		
	PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	49.1	48.5	54.1	60.6	64.3	70.7	71.1	67.8	63.0	58.8	53.6		
		MCWB	48.0	46.7	46.2	49.9	56.4	60.8	66.2	67.1	64.3	59.7	56.0	51.1		
	2%	DB	48.9	47.6	46.9	51.7	57.6	62.1	68.6	69.6	65.7	61.4	56.7	52.2		
		MCWB	46.8	45.7	45.1	48.6	54.6	59.3	64.9	66.4	62.4	58.5	54.1	49.9		
	5%	DB	47.6	46.4	46.0	50.2	55.9	60.6	66.9	68.2	64.5	60.4	55.4	51.1		
		MCWB	45.6	44.6	44.3	47.8	53.3	58.2	63.6	65.1	61.5	57.6	52.6	48.8		
	10%	DB	46.7	45.2	45.1	48.9	54.4	59.2	65.3	66.7	63.4	59.3	54.1	49.9		
		MCWB	44.7	43.5	43.4	46.9	52.0	56.7	62.3	63.6	60.4	56.6	51.1	47.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	47.6	46.8	50.9	57.6	61.4	67.4	68.4	64.7	60.3	56.7	52.0		
		MCDB	49.7	48.3	47.7	52.7	59.4	63.3	69.9	70.1	66.8	62.1	58.1	53.0		
	2%	WB	47.3	46.1	45.7	49.2	55.2	59.8	65.5	67.0	63.2	59.2	54.8	50.6		
		MCDB	48.4	47.1	46.5	51.0	56.9	61.6	67.9	69.1	65.1	61.0	56.5	51.9		
	5%	WB	46.1	45.0	44.8	48.2	53.7	58.5	64.0	65.3	62.1	58.3	53.1	49.3		
		MCDB	47.2	46.0	45.7	49.8	55.4	60.3	66.4	67.7	63.9	60.1	55.1	50.8		
	10%	WB	45.0	43.8	43.9	47.1	52.3	57.2	62.6	63.9	61.0	57.2	51.5	48.0		
		MCDB	46.4	45.0	44.9	48.7	54.0	58.9	64.9	66.3	63.1	59.1	53.6	49.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	3.7	3.5	3.4	3.4	3.3	3.3	3.3	3.3	3.8	3.9	4.1		
		MCDBR	4.1	4.0	4.1	5.0	5.1	4.9	4.5	4.3	3.8	4.1	4.4	4.2		
	5% WB	MCWBR	4.8	4.3	4.0	3.6	3.8	4.1	3.7	4.0	4.2	4.6	5.2	5.4		
		MCWBR	4.0	3.8	3.9	4.6	4.8	4.9	4.2	3.9	3.7	4.1	4.3	4.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.335	0.349	0.372	0.403	0.387	0.394	0.397	0.396	0.383	0.360	0.339	0.319		
		taud	2.253	2.325	2.311	2.266	2.393	2.391	2.394	2.404	2.423	2.394	2.304	2.250		
	Ebn at Noon	Ebn at Noon	184	230	252	260	272	271	267	260	247	223	181	162		
		Edh at Noon	19	25	31	37	35	35	35	32	28	23	18	16		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	161	370	806	1359	1773	1818	1734	1442	946	495	200	117		
	RadStd	RadStd	21	56	74	134	121	131	167	113	96	51	21	15		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-252	+97	N/A

Nomenclature: See separate page