

AMSTERDAM AP SCHIPHOL, NetherlandsWMO: **062400**Lat: **52.317N**Lon: **4.790E**Elev: **-11**StdP: **14.70**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	25.0	14.5	11.5	24.1	19.0	14.3	26.5	36.9	48.9	33.8	49.2	8.8	80	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	82.6	68.0	78.6	66.5	75.0	64.6	69.6	79.2	67.6	76.0	66.1	73.1	9.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.7	73.5	64.6	91.2	71.3	63.2	86.6	69.6	33.6	79.4	32.0	76.3	30.8	73.1	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.7	25.7	22.6	DB	16.7	89.8	6.1	2.7	12.3	91.8	8.7	93.3	5.3	94.8	0.9	96.7	(4)
(5)			WB	16.0	73.5	6.1	1.3	11.6	74.5	8.0	75.2	4.6	76.0	0.1	76.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	38.6	39.4	43.5	49.7	55.8	60.5	64.6	64.3	59.4	52.8	45.5	40.1	(6)
(7)		DBStd	11.01	7.05	6.62	5.79	6.27	6.16	5.23	5.23	4.68	4.49	5.40	5.68	7.07	(7)
(8)		HDD50	1452	353	297	210	81	13	0	0	0	0	33	153	312	(8)
(9)		HDD65	5161	817	716	666	460	293	154	72	69	178	379	584	773	(9)
(10)		CDD50	1915	1	1	9	72	194	316	452	445	282	120	19	4	(10)
(11)		CDD65	146	0	0	0	1	9	20	59	48	9	0	0	0	(11)
(12)		CDH74	985	0	0	0	8	71	159	404	302	40	1	0	0	(12)
(13)		CDH80	234	0	0	0	0	10	37	107	75	5	0	0	0	(13)
(14)	Wind	WSAvg	10.8	12.9	12.4	12.1	10.5	10.4	9.9	9.4	9.1	9.5	10.7	10.7	12.1	(14)
(15)	Precipitation	PrecAvg	36.5	3.1	2.5	2.1	1.8	2.3	2.7	3.4	4.1	3.5	3.7	3.8	3.5	(15)
(16)		PrecMax	49.3	5.9	5.2	4.9	3.9	4.2	6.9	6.5	8.9	7.5	7.4	6.9	6.5	(16)
(17)		PrecMin	26.6	0.4	0.8	0.4	0.0	0.9	0.8	1.0	0.9	0.6	0.7	0.4	0.9	(17)
(18)		PrecStd	5.3	1.4	1.2	1.2	1.0	1.0	1.5	1.7	2.2	1.8	1.7	1.6	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	56.6	63.6	74.8	80.1	85.0	88.2	86.9	78.7	70.2	60.5	55.7	(19)
(20)			MCWB	51.7	49.9	53.8	58.7	65.7	68.8	69.5	69.1	66.9	63.2	57.1	53.6	(20)
(21)		2%	DB	51.8	52.3	58.4	68.9	75.4	78.6	82.7	81.6	73.6	65.1	57.9	53.8	(21)
(22)			MCWB	49.7	48.8	51.0	56.9	61.9	66.7	68.4	67.8	64.8	60.4	55.4	51.7	(22)
(23)		5%	DB	49.5	50.3	54.6	64.2	71.3	73.9	78.5	76.7	69.9	62.7	55.8	51.8	(23)
(24)			MCWB	47.5	47.5	49.3	54.2	60.2	63.8	66.8	66.1	62.9	58.9	53.2	49.7	(24)
(25)		10%	DB	47.7	48.3	51.9	59.9	67.0	70.2	74.4	72.9	66.9	60.6	53.6	49.5	(25)
(26)			MCWB	45.9	46.0	48.0	52.6	58.1	61.7	65.0	64.3	61.1	57.2	51.3	47.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	51.6	55.0	60.9	67.5	70.9	72.2	71.8	68.5	63.5	57.8	54.1	(27)
(28)			MCD B	53.8	54.0	60.6	71.4	78.6	81.5	83.0	82.4	76.0	68.5	59.4	55.2	(28)
(29)		2%	WB	49.9	49.4	52.2	57.6	63.7	67.4	69.8	68.9	65.8	61.1	55.7	52.1	(29)
(30)			MCD B	51.5	51.6	56.5	66.5	72.1	76.0	79.7	77.9	72.1	64.4	57.6	53.5	(30)
(31)		5%	WB	47.8	47.7	50.2	55.4	61.0	64.9	67.9	67.0	63.7	59.5	53.6	50.0	(31)
(32)			MCD B	49.2	49.8	53.7	62.6	68.4	72.1	76.3	74.6	68.6	62.3	55.2	51.5	(32)
(33)		10%	WB	46.0	46.2	48.3	53.3	58.8	62.7	66.0	65.5	62.1	57.8	51.5	47.8	(33)
(34)			MCD B	47.6	48.2	51.4	59.0	66.1	68.9	73.0	71.6	66.1	60.2	53.3	49.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.3	11.7	14.3	14.5	14.3	14.4	14.3	12.8	11.1	8.8	7.9	(35)
(36)			MCDBR	8.2	10.8	16.5	20.8	21.4	21.1	21.0	20.6	16.8	12.6	9.5	8.0	(36)
(37)			MCWBR	7.8	8.3	10.8	11.4	10.8	11.0	9.9	9.6	9.4	8.9	8.0	7.5	(37)
(38)		5% WB	MCDBR	8.1	9.8	14.0	18.6	18.9	18.3	18.7	17.9	15.0	12.2	9.0	8.0	(38)
(39)			MCWBR	8.1	8.1	10.0	10.9	10.5	10.7	9.7	9.2	9.2	9.1	8.2	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.366	0.399	0.418	0.423	0.418	0.429	0.420	0.398	0.380	0.357	0.339	(40)	
(41)		taud	2.289	2.280	2.205	2.205	2.251	2.282	2.263	2.302	2.351	2.344	2.309	2.284	(41)	
(42)		Ebn at Noon	199	232	247	258	263	266	260	255	246	224	192	178	(42)	
(43)		Edh at Noon	21	28	36	41	41	40	40	36	31	26	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	218	436	826	1335	1628	1732	1646	1374	989	563	252	163	(44)	
(45)		RadStd	22	79	94	128	104	114	170	110	84	49	23	18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+117	N/A
(47)	Regional (77 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page