

AMSTERDAM AP SCHIPHOL, Netherlands

WMO: 062400

Lat: 52.317N

Lon: 4.790E

Elev: -3

StdP: 101.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.8	(c) -3.9	(d) -9.7	(e) 1.6	(f) -4.4	(g) -7.2	(h) 2.0	(i) -3.1	(j) 16.5	(k) 9.4	(l) 15.1	(m) 9.5	(n) 4.0	(o) 80	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	28.1	20.0	25.9	19.2	23.9	18.1	20.9	26.2	19.8	24.4	18.9	22.8	4.1	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	23.1	18.1	13.0	21.8	17.3	12.4	20.9	60.2	26.4	56.5	24.6	53.7	22.8	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.3	(b) 11.5	(c) 10.1	(e) -8.5	(f) 32.1	(g) 3.4	(h) 1.5	(i) -10.9	(j) 33.2	(k) -12.9	(l) 34.1	(m) -14.8	(n) 34.9	(o) -17.3	(p) 36.0		
(a) 13.3	(b) 11.5	(c) 10.1	(e) -8.9	(f) 23.1	(g) 3.4	(h) 0.7	(i) -11.3	(j) 23.6	(k) -13.3	(l) 24.0	(m) -15.2	(n) 24.4	(o) -17.7	(p) 24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	3.7	4.1	6.4	9.8	13.2	15.9	18.1	18.0	15.2	11.5	7.5	4.5
	DBStd	6.12	3.92	3.68	3.21	3.48	3.42	2.91	2.91	2.60	2.49	3.00	3.15	3.93
	HDD10.0	807	196	165	117	45	7	0	0	0	0	18	85	173
	HDD18.3	2867	454	398	370	256	163	86	40	38	99	211	324	429
	CDD10.0	1064	1	1	5	40	108	176	251	247	157	67	11	2
	CDD18.3	81	0	0	0	1	5	11	33	27	5	0	0	0
	CDH23.3	547	0	0	0	4	39	88	224	168	22	1	0	0
	CDH26.7	130	0	0	0	0	6	21	59	42	3	0	0	0
Wind	WSAvg	4.8	5.8	5.6	5.4	4.7	4.6	4.4	4.2	4.1	4.2	4.8	4.8	5.4
Precipitation	PrecAvg	927	78	64	54	45	58	69	86	103	90	95	96	89
	PrecMax	1251	150	133	124	99	106	175	164	227	190	188	176	165
	PrecMin	675	9	21	11	0	24	21	25	22	15	17	11	22
	PrecStd	135	36	30	30	25	25	38	44	57	46	42	41	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	13.7	17.5	23.8	26.7	29.4	31.2	30.5	26.0	21.2	15.8	13.2
		MCWB	11.0	9.9	12.1	14.8	18.7	20.4	20.8	20.6	19.4	17.3	14.0	12.0
	2%	DB	11.0	11.3	14.7	20.5	24.1	25.9	28.2	27.5	23.1	18.4	14.4	12.1
		MCWB	9.8	9.3	10.6	13.8	16.6	19.3	20.2	19.9	18.2	15.8	13.0	11.0
	5%	DB	9.7	10.2	12.6	17.9	21.9	23.3	25.8	24.8	21.1	17.1	13.2	11.0
		MCWB	8.6	8.6	9.6	12.4	15.7	17.7	19.3	18.9	17.2	14.9	11.8	9.8
	10%	DB	8.7	9.1	11.1	15.5	19.4	21.2	23.6	22.7	19.4	15.9	12.0	9.7
		MCWB	7.7	7.8	8.9	11.4	14.5	16.5	18.3	18.0	16.2	14.0	10.7	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.9	12.8	16.0	19.7	21.6	22.4	22.1	20.3	17.5	14.3	12.3
		MCDB	12.1	12.2	15.9	21.9	25.9	27.5	28.3	28.0	24.5	20.3	15.2	12.9
	2%	WB	10.0	9.7	11.2	14.2	17.6	19.7	21.0	20.5	18.8	16.2	13.2	11.1
		MCDB	10.8	10.9	13.6	19.2	22.3	24.4	26.5	25.5	22.3	18.0	14.2	11.9
	5%	WB	8.8	8.7	10.1	13.0	16.1	18.3	19.9	19.5	17.6	15.3	12.0	10.0
		MCDB	9.5	9.9	12.1	17.0	20.2	22.3	24.6	23.7	20.4	16.8	12.9	10.8
	10%	WB	7.8	7.9	9.1	11.8	14.9	17.1	18.9	18.6	16.7	14.3	10.8	8.8
		MCDB	8.7	9.0	10.8	15.0	18.9	20.5	22.8	22.0	19.0	15.7	11.9	9.7
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	6.5	8.0	8.1	8.0	8.0	7.9	7.1	6.2	4.9	4.4
		MCDBR	4.5	6.0	9.2	11.6	11.9	11.7	11.7	11.5	9.3	7.0	5.3	4.4
		MCWBR	4.3	4.6	6.0	6.3	6.0	6.1	5.5	5.3	5.2	5.0	4.5	4.2
	5% WB	MCDBR	4.5	5.4	7.8	10.3	10.5	10.2	10.4	10.0	8.4	6.8	5.0	4.5
		MCWBR	4.5	4.5	5.5	6.1	5.8	5.9	5.4	5.1	5.1	5.1	4.5	4.3
Clear-Sky Solar Irradiance	taub	0.345	0.366	0.399	0.418	0.423	0.418	0.429	0.420	0.398	0.380	0.357	0.339	
	taud	2.289	2.280	2.205	2.205	2.251	2.282	2.263	2.302	2.351	2.344	2.309	2.284	
	Ebn at Noon	628	730	778	814	830	837	819	805	777	706	606	561	
	Edh at Noon	66	88	114	128	129	126	126	115	98	82	64	57	
All-Sky Solar Radiation	RadAvg	0.69	1.38	2.60	4.21	5.13	5.46	5.19	4.33	3.12	1.78	0.80	0.51	
	RadStd	0.07	0.25	0.30	0.40	0.33	0.36	0.54	0.35	0.27	0.15	0.07	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		+0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+65	N/A
(47) Regional (77 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page