

VLIELAND, Netherlands

WMO: 062420

Lat: 53.2400N

Lon: 4.9208E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.5	26.7	17.2	13.1	25.5	20.8	15.6	27.9	45.0	44.8	42.2	44.7	16.8	90	0.800

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.8	76.8	67.8	73.1	66.0	70.4	64.3	68.9	75.0	66.9	71.8	65.3	69.5	11.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	97.4	72.6	64.8	91.8	70.4	63.3	87.1	68.5	33.1	75.4	31.5	72.0	30.2	69.5	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.9	35.9	32.2	DB	20.8	84.2	4.6	2.8	17.5	86.2	14.8	87.8	12.2	89.4	8.9	91.4	(4)
(5)			WB	19.7	72.6	4.5	1.4	16.5	73.6	13.8	74.4	11.3	75.2	8.1	76.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	38.9	38.9	42.5	48.2	54.2	59.0	63.3	64.2	60.2	53.5	46.5	41.8
	DBStd	10.25	6.43	5.78	4.84	5.11	5.00	4.11	4.22	3.86	3.93	4.70	5.13	5.98
	HDD50	1400	345	310	236	92	15	0	0	0	0	23	124	255
	HDD65	5194	810	730	699	503	337	187	86	61	151	358	554	718
	CDD50	1763	0	0	2	39	144	270	411	439	306	130	20	2
	CDD65	83	0	0	0	0	2	7	32	35	7	0	0	0
	CDH74	251	0	0	0	0	7	29	112	93	10	0	0	0
	CDH80	33	0	0	0	0	0	4	18	10	1	0	0	0
Wind	WSAvg	16.7	19.2	18.0	17.0	15.2	15.9	15.1	14.5	14.5	15.8	17.8	18.0	19.4
Precipitation	PrecAvg	32.3	2.7	2.1	1.7	1.5	1.9	2.2	2.8	3.3	3.4	3.8	3.7	3.2
	PrecMax	40.0	5.0	4.8	3.6	3.3	3.3	3.8	6.2	7.4	6.9	9.1	6.8	6.0
	PrecMin	22.6	0.4	0.7	0.2	0.0	0.7	0.8	0.8	0.7	0.4	1.2	0.5	1.3
	PrecStd	4.8	1.3	0.9	0.9	0.8	0.7	0.9	1.4	1.9	1.7	1.9	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	50.7	56.7	68.2	73.8	78.8	82.3	81.2	74.8	65.6	58.6	53.7
		MCWB	49.1	47.5	50.7	57.4	62.2	67.8	71.1	70.0	67.0	61.2	56.4	51.5
	2%	DB	49.3	48.6	52.1	62.1	68.5	71.8	76.9	76.3	70.4	63.0	56.7	51.9
		MCWB	47.3	46.4	48.3	54.3	60.0	64.6	67.7	68.3	64.3	59.5	54.4	49.9
	5%	DB	47.8	47.0	49.8	58.6	64.7	68.3	72.7	72.8	68.0	61.2	54.9	50.3
		MCWB	45.9	45.1	47.0	52.9	58.6	62.6	65.9	66.3	62.9	58.1	52.3	48.4
	10%	DB	46.4	45.7	48.1	55.4	61.6	65.5	69.8	70.1	66.0	59.8	53.3	48.8
		MCWB	44.7	44.0	45.8	51.1	56.4	60.4	64.2	64.5	61.6	56.8	50.4	46.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.7	48.3	51.8	58.3	64.0	68.9	72.3	71.2	67.8	62.0	56.8	52.1
		MCDB	50.8	49.7	55.4	65.6	70.0	76.2	81.2	78.2	73.2	64.9	58.1	53.1
	2%	WB	47.8	46.8	48.9	55.3	61.1	65.7	68.6	69.2	65.3	60.2	55.0	50.4
		MCDB	48.9	48.1	51.3	61.1	66.9	70.6	74.7	75.1	69.3	62.4	56.5	51.6
	5%	WB	46.3	45.5	47.4	53.1	59.0	63.0	66.6	67.2	63.7	58.8	52.8	48.8
		MCDB	47.4	46.9	49.4	57.7	64.3	67.5	71.4	71.9	67.1	60.7	54.5	50.0
	10%	WB	44.9	44.2	46.1	51.3	56.8	61.0	64.8	65.4	62.3	57.3	51.0	47.2
		MCDB	46.2	45.5	47.8	55.0	61.0	64.7	69.1	69.3	65.3	59.4	52.8	48.5
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.3	7.8	9.9	9.8	9.8	9.6	9.8	8.8	7.6	6.2	6.0
		MCDBR	5.0	6.4	10.2	15.4	15.2	15.1	14.9	14.2	11.3	8.3	6.2	5.6
		MCWBR	5.5	5.4	7.4	9.3	8.8	9.4	8.3	8.2	7.3	6.8	6.0	6.0
	5% WB	MCDBR	5.1	6.1	9.3	13.9	14.0	13.7	13.3	13.1	10.3	8.1	6.4	5.5
		MCWBR	5.7	5.5	7.2	8.9	8.7	9.3	8.1	8.1	7.3	7.1	6.3	6.0
Clear-Sky Solar Irradiance	taub		0.333	0.350	0.377	0.404	0.403	0.401	0.411	0.403	0.387	0.365	0.343	0.324
	taud		2.317	2.347	2.300	2.274	2.346	2.365	2.346	2.379	2.415	2.411	2.351	2.310
	Ebn at Noon		200	236	254	262	269	270	265	260	249	228	194	178
	Edh at Noon		19	25	32	38	37	36	37	34	29	24	19	16
All-Sky Solar Radiation	RadAvg		192	397	826	1356	1686	1756	1686	1406	972	534	227	144
	RadStd		18	67	76	128	103	112	167	103	82	48	20	16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page