

TERSCHELLING HOORN, Netherlands

WMO: 062510

Lat: 53.3911N

Lon: 5.3458E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.4	26.8	18.5	13.9	25.9	21.8	16.4	28.1	39.6	44.9	36.5	44.2	14.1	80	0.731

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.5	77.0	68.4	73.1	66.3	70.4	64.6	69.2	75.0	67.2	72.0	65.5	69.4	9.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	98.8	73.2	65.1	93.0	70.3	63.7	88.3	68.4	33.3	75.3	31.7	72.1	30.4	69.6	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
33.6	30.0	27.0	DB	20.6	84.6	4.0	2.5	17.7	86.4	15.4	87.9	13.2	89.3	10.3	91.1
			WB	19.7	73.9	4.2	1.6	16.7	75.1	14.2	76.1	11.9	77.0	8.8	78.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	38.4	38.2	41.7	47.6	53.3	58.1	62.5	62.8	59.0	52.4	45.5	40.4	(6)
(7)		DBStd	10.20	5.83	5.42	5.09	5.27	5.14	4.66	4.67	4.33	4.15	4.69	4.92	6.09	(7)
(8)		HDD50	1554	360	329	258	107	24	0	0	0	0	30	147	299	(8)
(9)		HDD65	5523	825	749	722	522	363	213	109	96	185	391	585	763	(9)
(10)		CDD50	1576	0	0	1	34	126	244	387	396	271	104	12	1	(10)
(11)		CDD65	72	0	0	0	0	1	7	31	28	5	0	0	0	(11)
(12)		CDH74	262	0	0	0	0	3	33	133	84	9	0	0	0	(12)
(13)		CDH80	37	0	0	0	0	0	3	24	9	1	0	0	0	(13)
(14)	Wind	WSAvg	14.1	16.4	15.6	14.8	13.2	13.4	12.5	12.4	12.2	13.0	14.8	15.0	16.0	(14)
(15)	Precipitation	PrecAvg	33.2	2.7	2.2	1.8	1.5	2.1	2.4	2.9	3.4	3.5	3.7	3.6	3.3	(15)
(16)		PrecMax	42.2	5.2	5.0	3.8	3.3	3.8	4.8	6.2	7.9	7.6	7.1	6.2	7.0	(16)
(17)		PrecMin	23.5	0.3	0.8	0.2	0.0	0.9	1.0	0.8	0.7	0.4	1.2	0.5	1.2	(17)
(18)		PrecStd	4.8	1.3	1.0	1.0	0.8	0.9	1.0	1.4	2.0	1.7	1.5	1.4	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.5	50.2	56.5	67.8	72.0	78.7	83.2	81.1	74.4	65.2	57.5	52.4	(19)
(20)			MCWB	48.7	48.0	51.5	59.0	62.6	69.8	71.4	70.6	67.9	61.6	55.7	50.7	(20)
(21)		2%	DB	48.6	48.1	52.2	61.6	67.9	72.3	77.6	76.0	70.1	62.4	55.7	50.6	(21)
(22)			MCWB	47.0	46.5	48.9	55.5	60.7	65.5	68.4	68.4	64.7	59.8	53.9	49.0	(22)
(23)		5%	DB	47.4	46.6	49.8	58.3	64.6	68.6	73.5	72.1	67.5	60.5	53.9	49.2	(23)
(24)			MCWB	45.8	45.1	47.4	53.7	58.9	63.0	66.5	66.0	63.2	58.0	51.9	47.7	(24)
(25)		10%	DB	46.0	45.3	48.1	55.3	61.6	65.8	70.2	69.6	65.4	58.9	52.2	47.9	(25)
(26)			MCWB	44.4	43.8	45.9	51.7	56.8	61.1	64.7	64.5	61.8	56.7	50.0	46.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	48.5	51.9	59.7	64.6	70.2	72.6	71.9	68.4	62.1	56.3	51.4	(27)
(28)			MCDB	50.5	49.5	55.1	66.2	69.5	76.6	82.3	78.6	73.4	64.4	57.1	52.2	(28)
(29)		2%	WB	47.5	46.9	49.4	56.3	61.5	66.3	69.2	69.0	65.6	60.1	54.4	49.4	(29)
(30)			MCDB	48.3	47.8	51.5	60.9	66.6	71.1	75.4	74.4	68.9	61.9	55.6	50.2	(30)
(31)		5%	WB	46.1	45.4	47.7	54.0	59.4	63.8	67.2	66.9	63.9	58.6	52.2	48.0	(31)
(32)			MCDB	47.1	46.4	49.4	57.6	64.0	67.9	72.2	71.2	66.6	60.1	53.5	48.9	(32)
(33)		10%	WB	44.7	44.0	46.4	52.1	57.3	61.5	65.4	65.2	62.5	57.1	50.4	46.5	(33)
(34)			MCDB	45.8	45.1	47.8	54.9	61.0	65.0	69.7	68.7	65.0	58.5	51.9	47.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.7	8.7	11.0	11.3	11.5	11.6	11.5	10.2	8.4	6.7	6.4	(35)
(36)			MCDBR	5.8	6.9	11.1	15.4	16.1	16.4	17.1	15.0	12.8	9.1	6.8	6.0	(36)
(37)			MCWBR	6.1	6.3	8.8	10.7	10.7	10.8	9.7	9.2	8.9	7.7	6.7	6.1	(37)
(38)		5% WB	MCDBR	5.9	6.8	10.2	14.5	14.5	14.8	15.3	13.7	11.9	8.9	6.9	6.0	(38)
(39)			MCWBR	6.2	6.3	8.5	10.4	10.1	10.3	9.4	9.0	8.7	7.9	7.1	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.332	0.349	0.377	0.404	0.402	0.401	0.410	0.404	0.388	0.364	0.343	0.324	(40)
(41)		taud		2.311	2.344	2.297	2.268	2.341	2.362	2.342	2.373	2.407	2.409	2.347	2.306	(41)
(42)		Ebn at Noon		199	236	253	261	269	270	265	259	248	228	193	177	(42)
(43)		Edh at Noon		19	25	32	38	37	37	37	34	29	24	19	16	(43)
(44)	All-Sky Solar Radiation	RadAvg		188	390	826	1360	1696	1760	1692	1412	969	529	223	141	(44)
(45)		RadStd		18	65	74	128	104	113	167	102	82	48	20	16	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page