

WIJK AAN ZEE, Netherlands

WMO: 062570

Lat: 52.5053N

Lon: 4.6029E

Elev: 10

StdP: 101.20

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.5	-3.5	-9.5	1.7	-3.8	-6.9	2.1	-2.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	27.2	19.2	24.7	18.1	22.7	17.5	20.3	25.3	19.2	23.1	18.4	21.6	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.4	22.1	17.8	12.8	21.1	17.1	12.2	20.2	58.3	25.4	54.9	23.3	52.2	21.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-8.8	32.4	2.9	2.1	-10.9	33.9	-12.6	35.1	-14.3	36.3	-16.4	37.8		
(5)			-9.2	22.5	2.8	0.9	-11.3	23.1	-12.9	23.6	-14.5	24.1	-16.5	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	4.4	4.1	6.0	9.4	12.4	15.2	17.6	17.7	15.4	12.0	8.2	5.3		
	DBStd	5.85	3.60	3.66	3.31	3.61	3.42	2.82	2.78	2.39	2.57	3.26	3.20	3.77		
	HDD10.0	771	174	166	128	54	12	1	0	0	0	18	69	148		
	HDD18.3	2857	433	399	382	269	187	101	47	41	94	197	303	404		
	CDD10.0	1017	0	1	4	34	87	157	235	238	162	81	16	2		
	CDD18.3	61	0	0	0	0	3	8	24	20	6	1	0	0		
	CDH23.3	377	0	0	0	4	29	59	157	102	24	1	0	0		
	CDH26.7	99	0	0	0	1	3	14	52	25	4	0	0	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	890	76	59	49	41	50	62	74	98	92	101	99	86		
	PrecMax	1199	153	121	121	100	90	155	172	237	201	196	180	157		
	PrecMin	679	7	19	9	0	17	20	12	20	10	28	10	23		
	PrecStd	131	35	28	29	24	19	33	38	53	47	47	38	35		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	13.7	17.4	23.6	26.2	28.9	32.1	29.7	25.9	21.5	16.2	12.9		
		MCWB	10.0	8.2	11.4	14.3	17.2	19.1	21.2	20.6	19.3	16.9	13.7	11.1		
	2%	DB	10.2	11.0	14.1	20.3	23.7	24.8	27.4	26.1	22.9	19.1	14.4	11.5		
		MCWB	8.9	8.3	9.9	13.1	15.8	18.3	19.5	19.2	17.9	15.6	12.7	10.2		
	5%	DB	9.2	9.5	11.9	17.6	20.9	21.9	24.2	23.3	20.9	17.3	13.4	10.6		
		MCWB	8.1	7.9	8.9	12.2	14.8	16.8	18.6	18.3	17.1	14.9	11.7	9.3		
	10%	DB	8.5	8.5	10.2	15.1	18.0	19.9	21.9	21.4	19.4	16.2	12.5	9.7		
		MCWB	7.5	7.1	8.1	11.0	13.7	15.9	17.9	17.5	16.4	14.1	10.7	8.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	9.7	12.1	15.4	18.9	20.9	21.8	21.5	20.2	17.5	14.2	11.6		
		MCDB	11.3	11.1	16.0	21.7	24.7	26.9	28.5	27.4	25.1	20.6	15.2	12.4		
	2%	WB	9.2	8.9	10.4	13.9	16.7	18.9	20.4	20.0	18.7	16.1	13.0	10.5		
		MCDB	9.8	10.3	13.1	19.1	21.5	23.5	25.5	24.6	21.8	18.4	14.2	11.4		
	5%	WB	8.4	8.1	9.2	12.5	15.3	17.5	19.3	19.0	17.8	15.3	12.1	9.6		
		MCDB	9.1	9.5	11.2	16.6	19.6	20.9	23.2	22.2	20.3	17.1	13.3	10.5		
	10%	WB	7.7	7.3	8.3	11.3	14.1	16.4	18.3	18.2	16.9	14.4	11.0	8.6		
		MCDB	8.4	8.4	10.0	14.7	17.6	19.2	21.5	20.8	19.1	16.1	12.1	9.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	4.5	6.1	7.8	7.4	7.1	7.0	6.7	6.6	5.6	4.5	4.0		
		MCDBR	3.3	5.6	9.0	11.9	12.4	11.6	11.6	10.5	9.2	6.4	4.5	3.4		
	5% WB	MCWBR	3.3	4.0	5.6	6.2	5.7	6.1	5.3	5.2	5.3	4.3	3.8	3.2		
		MCWBR	3.3	4.8	7.5	11.0	10.7	9.6	10.0	8.4	8.0	6.0	4.3	3.4		
(40) Clear-Sky Solar Irradiance	taub		0.341	0.360	0.392	0.412	0.416	0.412	0.422	0.414	0.394	0.375	0.353	0.335		
	taud		2.307	2.310	2.244	2.237	2.292	2.319	2.301	2.339	2.382	2.374	2.331	2.301		
	Ebn at Noon		632	737	787	819	836	842	825	811	782	712	611	565		
	Edh at Noon		64	85	109	124	123	121	121	111	95	79	63	55		
(44) All-Sky Solar Radiation	RadAvg		0.67	1.36	2.60	4.22	5.16	5.47	5.21	4.33	3.10	1.75	0.78	0.50		
	RadStd		0.07	0.24	0.28	0.39	0.31	0.34	0.52	0.34	0.26	0.15	0.07	0.05		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page