

SOESTERBERG, Netherlands

WMO: 062650

Lat: 52.127N

Lon: 5.276E

Elev: 20

StdP: 101.08

Time Zone: 1.00 (EUC)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.8	-5.5	-11.2	1.4	-6.2	-8.7	1.8	-4.5	12.0	8.9	10.8	9.2	2.4	80	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	29.5	19.8	27.2	19.3	25.1	18.2	21.0	26.9	20.1	25.3	19.1	23.9	4.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	22.8	18.2	13.1	21.9	17.3	12.4	21.1	60.7	26.8	57.4	25.3	54.4	24.0	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.4	7.4	DB	-11.8	33.1	3.3	1.5	-14.2	34.1	-16.1	35.0	-18.0	35.8	-20.4	36.9	(4)
(5)			WB	-12.4	22.9	2.9	1.1	-14.5	23.6	-16.2	24.3	-17.9	24.9	-20.0	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	3.2	3.9	5.8	9.0	13.2	15.6	18.0	18.0	14.7	10.6	6.7	3.4	(6)	
	DBStd	6.48	4.36	4.09	3.55	3.84	3.44	3.27	3.20	3.06	2.90	3.42	3.45	4.34	(7)	
	HDD10.0	940	211	172	135	63	9	0	0	0	1	34	107	208	(8)	
	HDD18.3	3051	468	403	387	279	163	94	46	44	114	238	349	464	(9)	
	CDD10.0	1021	1	2	6	34	107	168	248	248	142	54	8	2	(10)	
	CDD18.3	92	0	0	0	1	3	13	36	33	6	0	0	0	(11)	
	CDH23.3	859	0	0	0	12	58	136	328	288	37	0	0	0	(12)	
	CDH26.7	235	0	0	0	1	7	38	98	88	3	0	0	0	(13)	
(14) Wind	WSAvg	3.4	4.1	4.0	4.0	3.5	3.4	3.2	3.0	2.9	2.9	3.3	3.2	3.6	(14)	
(15) Precipitation	PrecAvg	819	68	54	59	47	62	67	82	78	73	78	81	79	(15)	
	PrecMax	1240	133	139	134	108	138	181	191	198	211	188	167	190	(16)	
	PrecMin	536	4	0	11	0	6	18	15	6	9	13	11	12	(17)	
	PrecStd	148	32	30	28	26	32	32	46	45	40	42	35	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	14.5	17.8	25.1	27.2	30.9	32.0	31.6	26.8	20.2	15.8	13.4	(19)	
		MCWB	10.9	10.4	11.8	15.4	17.5	20.9	20.4	20.2	19.1	16.4	13.0	12.0	(20)	
	2%	DB	11.3	12.0	15.1	20.9	24.8	27.3	29.5	29.3	24.2	18.2	14.0	12.0	(21)	
		MCWB	10.0	9.6	10.4	13.8	15.7	19.1	20.1	19.6	18.4	15.4	12.6	10.9	(22)	
	5%	DB	10.1	10.8	12.9	17.9	22.8	24.3	27.2	26.7	21.7	16.8	12.9	10.8	(23)	
		MCWB	8.8	9.0	9.7	11.9	15.1	17.6	19.6	19.5	17.1	14.6	11.6	9.9	(24)	
	10%	DB	8.9	9.6	11.4	15.6	20.2	22.1	24.8	24.0	19.8	15.7	11.6	9.6	(25)	
		MCWB	7.8	8.1	9.1	11.0	14.2	16.7	18.7	18.4	16.1	13.8	10.4	8.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	11.2	13.1	16.3	18.9	21.5	22.6	22.1	20.3	17.5	14.0	12.4	(27)	
		MCDB	12.2	12.9	16.4	22.8	25.6	28.4	28.0	29.0	24.7	19.8	15.0	13.0	(28)	
	2%	WB	10.2	10.1	11.3	14.2	17.2	19.9	21.2	20.7	18.9	16.0	12.9	11.2	(29)	
		MCDB	11.2	11.3	13.5	19.1	22.0	25.6	27.1	26.2	22.7	17.5	13.9	11.8	(30)	
	5%	WB	9.0	9.2	10.3	12.8	15.8	18.5	20.2	19.7	17.7	15.0	11.8	10.0	(31)	
		MCDB	9.8	10.5	12.3	16.6	20.3	23.1	25.6	24.7	20.8	16.4	12.8	10.8	(32)	
	10%	WB	7.8	8.2	9.2	11.5	14.7	17.3	19.2	18.9	16.7	14.1	10.6	8.6	(33)	
		MCDB	8.8	9.6	11.1	14.8	19.4	21.3	24.0	23.2	19.2	15.4	11.4	9.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.3	7.6	9.6	9.7	9.7	9.4	9.5	8.8	7.6	5.8	5.0	(35)	
		MCDBR	5.1	6.8	10.1	12.9	14.2	13.6	13.4	13.2	11.6	8.1	6.2	4.7	(36)	
	5% WB	MCWBR	4.6	5.0	6.6	7.0	6.9	7.0	6.1	5.5	6.4	5.7	5.0	4.4	(37)	
		MCWBR	5.3	5.6	8.0	11.4	12.2	11.8	11.9	11.7	9.3	7.5	5.6	4.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.364	0.398	0.418	0.423	0.419	0.430	0.421	0.396	0.378	0.354	0.337	(40)	
		taud	2.293	2.273	2.192	2.192	2.224	2.254	2.232	2.278	2.333	2.337	2.309	2.283	(41)	
	Ebn at Noon		635	733	780	814	830	836	818	804	779	710	613	568	(42)	
		Edh at Noon	66	89	116	130	132	130	130	118	100	82	65	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.70	1.39	2.60	4.20	5.10	5.45	5.16	4.33	3.14	1.80	0.81	0.53	(44)	
	RadStd		0.07	0.26	0.31	0.41	0.35	0.38	0.55	0.36	0.27	0.15	0.08	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (84 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page