

LELYSTAD AP, Netherlands

WMO: 062690

Lat: 52.457N

Lon: 5.520E

Elev: -13

StdP: 14.70

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.5	23.5	14.0	11.2	21.9	18.6	14.0	24.8	33.0	49.2	29.5	49.4	8.3	70	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	82.8	68.0	78.8	66.6	75.3	64.6	70.1	79.7	68.1	76.0	66.3	73.1	8.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	98.3	74.2	65.1	92.7	72.0	63.6	87.8	69.9	34.0	80.0	32.4	76.1	30.9	73.1	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	22.6	19.9	DB	14.9	91.0	8.1	3.1	9.1	93.3	4.4	95.1	-0.2	96.9	-6.0	99.2	(4)
(5)			WB	14.5	74.4	7.4	1.7	9.3	75.6	4.9	76.6	0.8	77.6	-4.5	78.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	37.7	38.5	42.7	49.3	56.1	60.5	64.0	63.2	58.9	51.9	44.7	39.1	(6)	
	DBStd	11.25	7.36	6.88	6.21	6.26	6.12	5.07	5.14	4.60	4.71	5.82	5.92	7.41	(7)	
	HDD50	1606	384	324	234	87	12	0	0	0	1	48	176	340	(8)	
	HDD65	5374	848	743	690	471	285	154	81	90	192	408	610	802	(9)	
	CDD50	1831	1	1	8	67	201	315	435	410	268	106	16	3	(10)	
	CDD65	122	0	0	0	0	9	19	51	35	8	0	0	0	(11)	
	CDH74	1057	0	0	0	14	112	180	418	266	66	1	0	0	(12)	
	CDH80	262	0	0	0	1	17	44	120	70	10	0	0	0	(13)	
(14) Wind	WSAvg	9.7	11.6	11.0	10.5	9.5	9.5	8.7	8.4	8.2	8.5	9.8	10.0	11.1	(14)	
(15) Precipitation	PrecAvg	34.6	3.0	2.5	2.2	1.8	2.4	3.0	3.8	3.4	3.1	3.0	3.1	3.1	(15)	
	PrecMax	46.1	5.8	5.5	4.6	3.6	4.1	6.5	7.4	8.6	7.0	8.1	6.0	6.4	(16)	
	PrecMin	25.4	0.4	0.8	0.5	0.0	1.4	1.1	1.3	0.5	0.4	0.6	0.5	1.0	(17)	
	PrecStd	4.8	1.4	1.2	1.3	0.9	0.7	1.3	1.7	2.0	1.5	1.5	1.3	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	56.6	64.0	75.7	81.9	86.0	89.7	86.8	80.4	70.7	60.8	55.7	(19)	
		MCWB	51.6	49.8	54.0	58.7	64.3	70.1	70.1	68.8	67.7	62.6	57.2	53.5	(20)	
	2%	DB	51.8	52.4	58.7	69.8	76.9	79.1	83.0	80.9	75.0	65.3	57.6	53.5	(21)	
		MCWB	49.7	49.2	51.1	56.8	61.1	66.8	68.6	68.2	65.5	60.3	55.1	51.5	(22)	
	5%	DB	49.4	50.1	54.8	65.0	72.7	74.2	78.4	76.0	70.7	62.4	55.2	51.5	(23)	
		MCWB	47.5	47.2	49.7	54.8	60.1	64.4	67.3	66.1	63.4	58.3	52.8	49.6	(24)	
	10%	DB	47.4	47.8	52.0	60.5	68.2	70.6	74.4	72.4	67.2	60.2	53.0	48.9	(25)	
		MCWB	45.6	45.5	48.1	52.9	58.5	62.5	65.5	64.0	61.3	56.9	50.8	47.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	51.8	55.3	60.9	67.3	71.8	72.6	72.3	69.2	63.6	57.6	54.0	(27)	
		MCDB	53.9	54.3	60.4	72.2	77.5	83.1	82.4	83.3	77.2	68.8	59.5	55.1	(28)	
	2%	WB	50.0	49.6	52.5	57.8	64.0	68.2	70.4	69.1	66.2	60.8	55.4	51.9	(29)	
		MCDB	51.4	51.7	56.6	67.4	73.5	76.3	80.2	77.7	73.0	64.4	57.5	53.3	(30)	
	5%	WB	47.7	47.5	50.4	55.6	61.3	65.7	68.4	67.1	64.2	59.1	53.1	49.6	(31)	
		MCDB	49.1	49.7	54.2	63.2	69.5	72.2	76.7	74.0	69.6	61.9	54.9	51.1	(32)	
	10%	WB	45.7	45.5	48.4	53.5	59.2	63.4	66.4	65.2	62.3	57.3	51.0	47.3	(33)	
		MCDB	47.2	47.7	51.6	59.4	66.3	69.3	72.9	70.7	66.2	59.7	52.7	48.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.7	13.1	16.3	16.3	15.5	15.5	15.7	14.6	11.9	9.0	7.7	(35)	
		MCDBR	8.5	12.3	18.8	24.2	24.8	23.1	23.4	22.4	20.0	13.8	9.9	8.0	(36)	
	5% WB	MCWBR	8.0	9.6	12.7	13.3	12.2	12.7	11.5	11.4	11.5	9.4	8.2	7.5	(37)	
		MCWBR	8.7	11.0	16.3	21.5	20.6	20.0	20.8	19.6	17.7	12.9	9.5	8.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.339	0.360	0.390	0.413	0.416	0.413	0.424	0.416	0.393	0.373	0.351	0.333	(40)	
		taud	2.304	2.297	2.224	2.218	2.255	2.280	2.258	2.299	2.351	2.362	2.326	2.299	(41)	
	Ebn at Noon		201	234	250	259	265	267	261	256	248	226	194	180	(42)	
		Edh at Noon	20	27	35	40	41	40	40	37	31	25	20	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		215	433	825	1336	1633	1732	1651	1373	984	558	248	160	(44)	
	RadStd		21	77	91	126	101	110	167	108	83	49	23	17	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page