

HOOGVEEN, Netherlands

WMO: 062790

Lat: 52.7489N

Lon: 6.5731E

Elev: 16

StdP: 101.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.0	-5.2	-10.2	1.6	-5.4	-7.8	2.0	-4.6	13.2	9.2	12.0	9.0	3.4	70	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.7	19.8	26.3	19.2	24.3	18.1	21.0	26.8	20.0	24.8	19.0	23.1	3.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	23.2	18.2	13.1	21.9	17.3	12.4	20.9	60.8	26.8	57.2	24.9	53.9	23.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.2	8.2	-9.3	32.8	3.7	2.0	-12.0	34.2	-14.1	35.4	-16.2	36.5	-18.8	37.9		
			-9.7	23.2	3.6	1.0	-12.3	24.0	-14.4	24.6	-16.4	25.2	-19.0	25.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	2.6	3.4	5.8	9.5	13.1	15.8	17.5	17.1	14.4	10.5	6.6	3.5
	DBStd	6.33	4.10	3.77	3.48	3.65	3.49	3.03	3.03	2.63	2.69	3.30	3.33	4.27
	HDD10.0	957	228	186	134	52	9	0	0	0	1	34	109	202
	HDD18.3	3098	486	419	389	264	167	89	54	56	121	242	352	459
	CDD10.0	967	1	1	4	38	106	173	232	221	134	51	7	2
	CDD18.3	67	0	0	0	1	4	12	28	18	3	0	0	0
	CDH23.3	661	0	0	0	10	52	127	272	162	36	1	0	0
	CDH26.7	175	0	0	0	1	8	32	83	47	5	0	0	0
Wind	WSAvg	4.0	4.9	4.7	4.5	4.1	4.0	3.6	3.3	3.1	3.2	4.0	4.2	4.8
Precipitation	PrecAvg	865	77	63	58	47	64	74	93	83	76	74	76	80
	PrecMax	1155	145	143	120	107	173	161	197	177	151	260	165	169
	PrecMin	638	7	23	12	1	23	16	32	11	9	23	8	24
	PrecStd	128	37	33	33	25	31	32	38	43	38	42	35	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	13.4	17.7	24.9	27.8	30.4	32.4	31.2	26.9	21.3	15.8	13.1
		MCWB	10.7	9.5	12.0	14.8	17.9	20.9	20.6	20.7	20.0	16.9	13.9	11.8
	2%	DB	10.7	11.1	15.0	21.2	24.5	26.7	28.9	27.4	23.9	18.2	13.9	11.8
		MCWB	9.5	9.2	10.6	13.7	16.1	19.1	20.1	19.9	18.6	15.5	12.6	10.7
	5%	DB	9.3	9.8	12.5	18.7	22.4	24.2	26.3	24.7	21.4	16.6	12.6	10.6
		MCWB	8.3	8.3	9.6	12.6	15.3	18.0	19.5	18.9	17.2	14.3	11.3	9.5
	10%	DB	8.2	8.6	10.9	16.2	20.0	21.9	24.0	22.6	19.4	15.2	11.3	9.1
		MCWB	7.2	7.2	8.6	11.7	14.4	16.8	18.5	17.7	16.0	13.5	10.2	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	10.9	12.8	16.0	19.4	22.1	22.5	22.1	20.5	17.4	14.1	12.1
		MCDB	12.1	12.3	15.9	22.0	25.0	28.0	28.5	27.7	25.6	20.5	15.0	12.8
	2%	WB	9.7	9.5	11.2	14.4	17.5	20.1	21.1	20.5	18.9	15.8	12.8	10.9
		MCDB	10.6	10.6	13.7	19.8	22.7	24.9	27.0	25.5	22.9	18.0	13.9	11.6
	5%	WB	8.4	8.4	10.0	13.2	16.2	18.8	20.1	19.4	17.7	14.7	11.5	9.6
		MCDB	9.2	9.7	12.2	17.5	20.7	23.1	25.4	23.6	20.7	16.2	12.4	10.5
	10%	WB	7.3	7.3	8.9	12.0	14.9	17.5	19.0	18.4	16.6	13.8	10.3	8.3
		MCDB	8.1	8.5	10.8	15.5	19.3	21.0	22.9	21.7	18.9	15.1	11.2	9.1
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.2	7.2	9.7	9.6	9.6	9.6	9.5	8.8	7.0	5.0	4.2
		MCDBR	4.6	6.8	10.5	14.0	13.5	13.6	13.9	13.2	12.0	8.3	5.6	4.7
		MCWBR	4.2	5.2	6.9	7.4	6.7	7.1	6.7	6.8	6.9	5.7	4.7	4.3
	5% WB	MCDBR	4.6	6.1	9.4	11.8	11.6	11.9	12.5	11.5	10.9	7.8	5.5	4.7
		MCWBR	4.3	5.0	6.5	6.8	6.3	6.8	6.5	6.5	6.6	5.7	4.8	4.4
Clear-Sky Solar Irradiance	taub	0.326	0.346	0.375	0.406	0.407	0.405	0.417	0.410	0.388	0.360	0.339	0.319	
	taud	2.332	2.335	2.268	2.225	2.258	2.280	2.258	2.297	2.352	2.401	2.357	2.320	
	Ebn at Noon	650	754	804	824	843	848	829	812	785	729	627	583	
	Edh at Noon	62	82	106	125	127	126	126	115	97	76	60	53	
All-Sky Solar Radiation	RadAvg	0.65	1.31	2.47	4.04	4.95	5.23	5.00	4.18	3.02	1.74	0.78	0.51	
	RadStd	0.07	0.22	0.31	0.42	0.43	0.39	0.62	0.34	0.33	0.17	0.08	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page