

LICHELAND GOEREE, Netherlands

WMO: 063200

Lat: 51.926N

Lon: 3.670E

Elev: 62

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.4	31.0	18.5	14.0	30.4	22.6	17.1	33.1	44.2	44.8	41.3	45.1	15.5	70	0.786

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	74.0	65.5	71.0	64.6	68.7	63.6	67.0	71.7	65.7	69.7	64.6	67.9	12.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	93.5	69.1	64.1	89.8	68.1	62.9	86.2	67.0	31.5	71.8	30.6	69.9	29.7	68.2	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.7	34.9	31.8	27.3	82.3	3.5	4.6	24.8	85.5	22.8	88.2	20.8	90.8	18.3	94.1		
(5)			24.8	70.0	4.0	1.9	21.9	71.3	19.5	72.4	17.2	73.4	14.3	74.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	41.7	41.2	43.7	48.5	54.2	59.2	63.3	64.8	62.0	55.9	49.1	43.7	(6)	(7)
	DBStd	9.45	4.92	4.84	4.41	4.68	4.52	4.01	3.72	3.27	3.36	4.29	4.50	5.41	(7)	(8)
	HDD50	1065	258	246	198	83	10	0	0	0	0	7	65	198	(8)	(9)
	HDD65	4696	723	666	659	494	337	181	77	41	102	281	476	659	(9)	(10)
	CDD50	1928	0	0	4	38	140	277	414	460	360	192	39	4	(10)	(11)
	CDD65	83	0	0	0	0	1	8	26	36	12	0	0	0	(11)	(12)
	CDH74	118	0	0	0	0	4	20	44	41	9	0	0	0	(12)	(13)
	CDH80	19	0	0	0	0	1	2	11	3	2	0	0	0	(13)	(14)
(14) Wind	WSAvg	17.1	20.1	18.9	17.1	15.0	15.6	14.6	14.7	14.9	15.9	18.4	19.5	20.2	(14)	(15)
(15) Precipitation	PrecAvg	33.5	2.7	2.5	1.8	1.6	2.2	2.8	3.1	3.3	3.3	3.2	3.7	3.3	(15)	(16)
	PrecMax	43.0	6.7	4.8	4.7	3.0	4.4	5.3	6.5	6.9	8.3	7.1	5.8	6.7	(16)	(17)
	PrecMin	23.9	0.2	0.7	0.5	0.0	0.7	0.8	0.6	0.5	0.6	0.6	0.4	0.7	(17)	(18)
	PrecStd	4.5	1.4	1.1	1.0	0.8	1.0	1.3	1.7	1.9	2.1	1.5	1.3	1.5	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	52.0	58.0	65.0	71.2	77.0	78.7	78.6	73.7	67.4	59.8	54.4	(19)	(20)
		MCWB	49.1	46.7	50.3	54.3	58.7	64.9	67.1	67.4	66.0	61.6	56.8	51.3	(20)	(21)
	2%	DB	50.0	49.8	52.8	60.7	65.9	70.1	73.1	73.9	69.9	64.2	57.7	52.9	(21)	(22)
		MCWB	47.8	46.7	48.0	53.2	57.9	62.9	65.5	66.0	64.0	60.6	54.9	50.2	(22)	(23)
	5%	DB	48.8	48.4	50.1	57.1	62.3	66.2	70.0	70.9	67.8	62.6	56.5	51.5	(23)	(24)
		MCWB	46.6	45.9	47.1	51.5	56.6	61.5	64.5	65.3	63.1	59.2	53.5	48.9	(24)	(25)
	10%	DB	47.7	46.9	48.5	54.3	59.7	63.5	67.8	68.4	66.2	61.2	55.0	50.1	(25)	(26)
		MCWB	45.5	44.7	46.1	50.5	55.5	59.8	63.4	64.1	62.1	57.7	51.6	47.6	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	48.6	51.5	56.3	61.8	66.8	68.7	69.3	67.2	62.7	57.6	52.2	(27)	(28)
		MCDB	50.8	50.0	55.9	62.1	67.5	73.1	75.1	75.0	73.2	65.6	58.9	53.5	(28)	(29)
	2%	WB	48.4	47.4	48.9	53.9	59.0	63.9	66.6	67.3	65.3	61.1	55.8	50.8	(29)	(30)
		MCDB	49.5	49.0	51.6	58.3	63.1	68.4	71.2	71.5	68.7	63.7	57.6	52.4	(30)	(31)
	5%	WB	47.2	46.1	47.6	52.3	57.3	61.9	65.3	66.0	63.9	59.7	54.0	49.3	(31)	(32)
		MCDB	48.4	47.9	49.4	55.9	60.9	65.6	69.1	69.8	66.7	62.2	56.1	51.0	(32)	(33)
	10%	WB	45.9	44.9	46.5	50.8	55.9	60.2	63.9	64.8	62.8	58.5	52.2	48.0	(33)	(34)
		MCDB	47.4	46.6	48.2	54.0	59.3	63.0	67.1	68.2	65.9	61.0	54.5	49.8	(34)	(35)
(36) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	5.0	5.8	5.2	5.0	4.5	4.6	4.5	4.8	4.7	4.9	(35)	(36)
		MCDBR	4.8	5.6	7.8	11.4	10.7	10.7	8.8	8.7	6.9	5.7	5.4	4.8	(36)	(37)
	5% WB	MCWBR	5.1	4.8	5.6	6.0	5.9	6.5	5.3	5.2	5.1	5.3	5.7	5.0	(37)	(38)
		MCWBR	4.5	5.1	7.1	10.2	9.2	9.2	7.7	6.8	5.8	5.5	5.0	4.7	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.355	0.388	0.411	0.419	0.414	0.420	0.411	0.392	0.371	0.348	0.330	(39)	(40)
		taud	2.358	2.357	2.280	2.255	2.295	2.322	2.316	2.355	2.399	2.416	2.376	2.344	(40)	(41)
	Ebn at Noon	Ebn at Noon	208	239	253	261	265	267	263	259	250	231	201	188	(41)	(42)
		Edh at Noon	20	26	34	39	39	38	38	35	30	24	20	17	(42)	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	228	452	852	1405	1678	1796	1703	1446	1043	583	269	171	(43)	(44)
	RadStd	RadStd	20	81	98	125	112	117	177	111	72	52	26	20	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page