

EURO PLATFORM, Netherlands

WMO: 063210

Lat: 51.998N

Lon: 3.275E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.8	32.2	19.5	14.7	32.1	23.5	17.8	34.1	44.3	45.3	41.3	45.5	18.1	80	0.799

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	70.8	65.1	68.7	64.1	67.3	63.2	66.2	69.2	65.0	67.9	63.9	66.7	12.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	91.9	68.0	63.7	88.4	67.1	62.6	85.1	66.2	30.9	69.5	30.0	68.1	29.3	66.9	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.0	35.6	32.4	DB	29.6	77.6	3.1	4.7	27.4	80.9	25.6	83.6	23.8	86.2	21.6	89.6	(4)
(5)			WB	26.5	68.7	3.6	1.7	23.9	69.9	21.8	70.9	19.8	71.8	17.2	73.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	42.6	42.1	43.9	47.9	53.1	58.0	62.4	64.2	62.0	56.4	50.0	44.9	(6)
(7)		DBStd	8.78	4.99	4.73	4.06	4.07	3.79	3.57	3.23	2.79	3.14	4.06	4.13	5.11	(7)
(8)		HDD50	961	231	222	190	86	13	1	0	0	0	5	48	165	(8)
(9)		HDD65	4667	695	642	653	512	368	214	95	49	100	266	451	622	(9)
(10)		CDD50	1816	1	0	2	24	110	240	383	439	359	203	47	8	(10)
(11)		CDD65	49	0	0	0	0	0	3	14	23	9	0	0	0	(11)
(12)		CDH74	27	0	0	0	0	1	3	14	7	2	0	0	0	(12)
(13)		CDH80	4	0	0	0	0	0	0	4	0	0	0	0	0	(13)
(14)	Wind	WSAvg	17.4	20.9	19.6	17.1	15.1	15.4	14.4	14.6	15.0	16.2	19.1	20.4	21.2	(14)
(15)	Precipitation	PrecAvg	32.9	2.6	2.4	1.8	1.5	2.0	2.7	3.0	3.3	3.2	3.3	3.7	3.3	(15)
(16)		PrecMax	40.3	6.5	4.6	5.0	3.1	4.2	5.7	6.7	7.2	8.1	7.3	5.9	6.5	(16)
(17)		PrecMin	23.6	0.2	0.8	0.5	0.0	0.7	0.6	0.7	0.4	0.6	0.7	0.4	0.7	(17)
(18)		PrecStd	4.3	1.4	1.1	1.0	0.8	1.0	1.3	1.7	1.9	2.1	1.5	1.4	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	51.8	54.0	61.0	65.5	71.5	74.2	74.5	71.4	66.2	60.3	55.5	(19)
(20)			MCWB	50.7	48.4	48.4	53.0	57.4	62.5	65.7	67.0	65.6	61.6	57.4	52.6	(20)
(21)		2%	DB	51.1	50.1	51.1	57.1	61.4	66.6	69.9	71.2	68.6	64.2	58.6	54.2	(21)
(22)			MCWB	48.9	47.5	47.6	51.5	56.1	61.4	64.6	65.7	64.1	60.7	55.7	51.6	(22)
(23)		5%	DB	50.0	48.9	49.5	54.6	59.2	63.6	67.9	69.0	67.3	62.8	57.2	52.7	(23)
(24)			MCWB	47.7	46.4	46.7	50.6	55.3	59.9	63.7	64.5	63.2	59.4	54.1	50.0	(24)
(25)		10%	DB	48.7	47.7	48.5	52.7	57.5	61.8	66.2	67.4	66.1	61.6	55.5	51.2	(25)
(26)			MCWB	46.3	45.3	46.1	49.5	54.4	58.7	62.6	63.6	62.4	58.2	52.2	48.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	49.5	49.5	54.0	59.3	64.4	67.3	68.2	66.9	62.5	57.7	53.7	(27)
(28)			MCD B	52.4	50.8	52.0	58.0	62.8	69.2	71.6	72.3	70.4	64.8	59.4	55.0	(28)
(29)		2%	WB	49.7	48.3	48.4	52.2	57.1	62.1	65.5	66.4	65.4	61.2	56.3	52.1	(29)
(30)			MCD B	50.7	49.6	50.3	55.8	59.8	65.3	68.9	69.6	67.9	63.7	58.3	53.8	(30)
(31)		5%	WB	48.2	46.9	47.5	51.0	55.8	60.3	64.2	65.3	64.1	60.0	54.6	50.5	(31)
(32)			MCD B	49.6	48.4	49.2	54.1	58.4	62.9	67.2	68.2	66.6	62.4	56.8	52.2	(32)
(33)		10%	WB	46.8	45.7	46.5	49.8	54.7	59.2	63.0	64.2	63.0	58.8	52.7	49.0	(33)
(34)			MCD B	48.4	47.4	48.2	52.4	57.2	61.4	65.5	67.0	65.7	61.3	55.1	50.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	4.2	4.2	4.8	4.4	4.4	4.0	4.0	3.9	4.3	4.5	4.6	(35)
(36)			MCDBR	4.7	4.7	5.5	7.9	7.6	7.8	6.7	6.2	5.1	5.0	5.1	4.9	(36)
(37)			MCWBR	5.6	4.4	4.6	4.5	4.8	5.3	4.4	4.5	4.4	5.1	5.9	5.7	(37)
(38)		5% WB	MCDBR	4.7	4.3	5.1	7.3	6.9	6.7	6.4	5.3	4.7	4.9	5.0	4.8	(38)
(39)			MCWBR	5.7	4.5	4.7	4.4	4.8	5.2	4.7	4.6	4.5	5.4	6.0	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.352	0.386	0.409	0.416	0.413	0.417	0.408	0.390	0.369	0.345	0.328	(40)	
(41)		taud	2.366	2.373	2.298	2.274	2.315	2.340	2.338	2.378	2.416	2.428	2.386	2.350	(41)	
(42)		Ebn at Noon	209	241	254	262	266	267	264	260	251	232	202	189	(42)	
(43)		Edh at Noon	20	26	33	38	38	38	37	34	30	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	226	452	858	1422	1698	1816	1724	1465	1052	582	269	170	(44)	
(45)		RadStd	18	81	95	123	110	113	178	109	69	53	26	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page